

SECTION 03 35 00
CONCRETE FINISHING

PART 1 GENERAL

1.01 SUMMARY

- A. Coordinate with standards in Section 03 30 00.

1.02 SUBMITTALS

- A. Specify site samples for all special concrete finishes.

PART 2 PRODUCTS No Requirements

PART 3 EXECUTION

3.01 FLOOR FLATNESS AND LEVELNESS REQUIREMENTS

- A. Maximum Variation of Surface Flatness:
 - 1. Exposed Concrete Floors: 1/4" in 10 feet
 - 2. Under Seamless Resilient Flooring: 1/4" in 10 feet
 - 3. Under Carpeting: 1/4" in 10 feet

3.02 CONCRETE FINISHING

- A. Exposed interior concrete floors to receive carpeting: Troweled finish.
- B. Floors to receive thin-set ceramic tile, resilient flooring and vinyl tile: Flat troweled finish.
- C. Exterior stoop slabs: Broom finish (or similar non-slip finish).

END OF SECTION 03 35 00