

**SECTION 03 60 00**

**GROUTING**

**PART 1 GENERAL**

**1.01 TESTING**

- A. Contractor shall perform quality control testing for structural grout to assure minimum load carrying capacities are met. Such testing shall be at the Contractor's expense. Provide test results to Architect and Owner.
- B. Owner may request testing by Owner's Testing Agent if Owner so desires. Contractor shall fully cooperate in providing access and samples for Testing Agent.

**PART 2 PRODUCTS**

**2.01 GENERAL DESIGN GUIDELINES**

- A. All structural and non-structural grout shall contain no metallic elements.
- B. All grouts shall be non-shrink.

**PART 3 EXECUTION No Requirements**

**END OF SECTION 03 60 00**