

## SECTION 10 26 13

### CORNER GUARDS

#### PART 1 GENERAL No Requirements

#### PART 2 PRODUCTS

##### 2.01 MATERIALS

- A. Galvanized sheet steel:
  - 1. Paint lock for field painting.
  - 2. Minimum 18 gauge.
  - 3. 'C' style with 2 1/2" x 2 1/2 " legs with beveled edges.
  - 4. 48" length
  - 5. Field paint: Prime front of wall surface and back of guard before attachment to wall.
- B. Stainless steel (Required in kitchens, restrooms and other wet areas.):
  - 1. Type 304 alloy, minimum 16 gauge.
  - 2. Type 430 alloy, factory standard embossed pattern, minimum 16 gauge.
  - 3. 48" length
  - 4. #4 Satin Finish.
- C. Fasteners:
  - 1. All fasteners to be non-corrosive and compatible with galvanized steel. All necessary fasteners to be supplied by the manufacturer.
  - 2. All components shall be isolated from dissimilar metals as recommended by the manufacturer and as approved by the architect.
  - 3. Chemical welds are not acceptable at gypsum wallboard corners.
  - 4. Use heavy-duty adhesive on concrete block units.
  - 5. All corner guards shall be mechanically attached. Provide Philips oval head, size 10 screws, or tamperproof screws.

#### PART 3 EXECUTION

##### 3.01 INSTALLATION

- A. Attach corner guards with adhesive and screws every 12 inches on center starting two inches from bottom.

END OF SECTION 10 26 13