

## Legacy Options High School (1012) – Sampled 11/8/2016

All results <15 ppb – No further action at this time.

### Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
1012-H14-DF-01	Drinking fountain, hallway H14, next to south gymnasium entrance, left bubbler	0.2	µg/L	
1012-H14-DF-02	Drinking fountain, hallway H14, next to south gymnasium entrance, right bubbler	0.2	µg/L	
1012-128-SK-03	Nurse sink, room 128	1.4	µg/L	
1012-H4-DF-04	Drinking fountain, hallway H4, next to room 116	0.2	µg/L	
1012-116-SK-05	Food prep sink, kitchen 116	0.6	µg/L	
1012-H5-DF-06	Drinking fountain, hallway H5, next to restrooms, far left bubbler	0.2	µg/L	
1012-H5-DF-07	Drinking fountain, hallway H5, next to restrooms, center left bubbler	0.1	µg/L	
1012-H5-DF-08	Drinking fountain, hallway H5, next to restrooms, center right bubbler	0.1	µg/L	
1012-H5-DF-09	Drinking fountain, hallway H5, next to restrooms, far right bubbler	0.3	µg/L	