

P.R.E.P. Academy Middle and High School at Columbine PEC (105)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/28/2016 & 11/03/2016

Sample ID	Sample Description	Lead Result	Units	Action
105-111-DF-01	Bottle filler, hallway 111, next to room 111A	1.0	µg/L	
105-111-DF-02	Drinking fountain, hallway 111, next to room 111A	1.0	µg/L	
105-100-DF-03	Bottle filler, hallway 100, next to room 118B	<1.0*	µg/L	
105-100-DF-04	Drinking fountain, hallway 100, next to room 118B	<1.0	µg/L	
105-117-SK-05	Faculty lounge sink, room 117	<1.0	µg/L	
105-134-DF-06	Bottle filler, hallway 134, next to room 134A	<1.0	µg/L	
105-134-DF-07	Bottle filler, hallway 134, next to room 134A	<1.0	µg/L	
105-139-SK-08	Faculty lounge sink, room 139	1.0	µg/L	
105-001-DF-09	Bottle filler, room 001, north wall	<1.0	µg/L	
105-001-DF-10	Drinking fountain, room 001, north wall	<1.0	µg/L	
105-002-DF-11	Drinking fountain, room 002, north wall	<1.0	µg/L	
105-116-SK-12	Kitchen prep sink, room 116, west wall	<1.0	µg/L	

Phase II Sampled on 9/28/2017

105-113-SK-13	Classroom sink, room 113	1.2	µg/L	
105-103-SK-14	Classroom sink, room 103	1.0	µg/L	
105-108-SK-15	Classroom sink, room 108	1.5	µg/L	
105-122-SK-16	Classroom sink, room 122	0.8	µg/L	
105-126-SK-17	Classroom sink, room 126	0.6	µg/L	
105-001-SK-18	Classroom sink, room 001	2.0	µg/L	
105-002-SK-19	Classroom sink, room 002	0.8	µg/L	
105-129-SK-20	Office sink, room 129	0.6	µg/L	
105-137-SK-21	Classroom sink, room 137	0.7	µg/L	
105-138-SK-22	Classroom sink, room 138	0.7	µg/L	
105-140-SK-23	Classroom sink, room 140	1.6	µg/L	
105-131-SK-24	Classroom sink, room 131	1.5	µg/L	
105-132-SK-25	Classroom sink, room 132	1.8	µg/L	

*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.