

STRIVE Prep – Federal @ Valdez Achievement Campus (1102)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/13-14/2016				
Sample ID	Sample Description	Lead Result	Units	Action
1102-102A-SK-01	Staff lounge sink, room 102A	<1.0* ¹	µg/L	
1102-101A-SK-02	Nurse sink, room 101A	<1.0	µg/L	
1102-109-DF-03	Drinking fountain, room 109	1.2	µg/L	
1102-109-SK-04	Classroom sink, room 109	<1.0	µg/L	
1102-110-DF-05	Drinking fountain, room 110	<1.0	µg/L	
1102-110-SK-06	Classroom sink, room 110	<1.0	µg/L	
1102-100-DF-07	Drinking fountain, hallway 100, next to room 111, left bubbler	<1.0	µg/L	
1102-100-DF-08	Drinking fountain, hallway 100, next to room 111, right bubbler	<1.0	µg/L	
1102-100-DF-09	Bottle fill, hallway 100, next to room 111	<1.0	µg/L	
1102-100-DF-10	Drinking fountain, hallway 100, next to room 100C, left bubbler	<1.0	µg/L	
1102-100-DF-11	Bottle fill, hallway 100, next to room 100C	<1.0	µg/L	
1102-100-DF-12	Drinking fountain, hallway 100, next to room 100C, right bubbler	<1.0	µg/L	
1102-128-DF-13	Drinking fountain, hallway 128, next to elevator, left bubbler	<1.0	µg/L	
1102-128-DF-14	Bottle fill, hallway 128, next to elevator	<1.0	µg/L	
1102-128-DF-15	Drinking fountain, hallway 128, next to elevator, right bubbler	<1.0	µg/L	
1102-001-DF-16	Drinking fountain, hallway 001, next to elevator, left bubbler	<1.0	µg/L	
1102-001-DF-17	Bottle fill, hallway 001, next to elevator	<1.0	µg/L	
1102-001-DF-18	Drinking fountain, hallway 001, next to elevator, right bubbler	<1.0	µg/L	
1102-003-DF-19	Drinking fountain, all-purpose room 003, left bubbler	<1.0	µg/L	
1102-003-DF-20	Bottle fill, all-purpose room 003	<1.0	µg/L	
1102-003-DF-21	Drinking fountain, all-purpose room 003, right bubbler	<1.0	µg/L	
1102-004-DF-22	Drinking fountain, hallway 004, next to 004C, left bubbler	<1.0	µg/L	
1102-004-DF-23	Bottle fill, hallway 004, next to 004C	<1.0	µg/L	
1102-004-DF-24	Drinking fountain, hallway 004, next to 004C, right bubbler	<1.0	µg/L	
1102-005-SK-25	Classroom sink, room 005	<1.0	µg/L	
1102-200-DF-26	Drinking fountain, hallway 200, across from room 221, left bubbler	<1.0	µg/L	
1102-200-DF-27	Bottle fill, hallway 200, across from room 221	<1.0	µg/L	
1102-200-DF-28	Drinking fountain, hallway 200, across from room 221, right bubbler	<1.0	µg/L	
1102-218-DF-29	Drinking fountain, hallway 213, across from room 219, left bubbler	<1.0	µg/L	
1102-218-DF-30	Bottle fill, hallway 213, across from room 219	<1.0	µg/L	
1102-218-DF-31	Drinking fountain, hallway 213, across from room 219, right bubbler	<1.0	µg/L	
1102-205-DF-32	Drinking fountain, hallway 205, across from room 208, left bubbler	<1.0	µg/L	
1102-205-DF-33	Bottle fill, hallway 205, across from room 208	<1.0	µg/L	

1102-205-DF-34	Drinking fountain, hallway 205, across from room 208, right bubbler	<1.0	µg/L
1102-300-DF-35	Drinking fountain, hallway 300, next to 300B, left bubbler	<1.0	µg/L
1102-300-DF-36	Bottle fill, hallway 300, next to 300B	<1.0	µg/L
1102-300-DF-37	Drinking fountain, hallway 300, next to 300B, right bubbler	<1.0	µg/L
1102-300-DF-38	Drinking fountain, hallway 300, next to 327C, left bubbler	<1.0	µg/L
1102-300-DF-39	Bottle fill, hallway 300, next to 327C	<1.0	µg/L
1102-300-DF-40	Drinking fountain, hallway 300, next to 327C, right bubbler	<1.0	µg/L
1102-313-DF-41	Drinking fountain, hallway 313, next to 318, left bubbler	<1.0	µg/L
1102-313-DF-42	Bottle fill, hallway 313, next to 318	<1.0	µg/L
1102-313-DF-43	Drinking fountain, hallway 300, next to 318, right bubbler	<1.0	µg/L
1102-324-SK-44	Staff lounge sink, room 324	<1.0	µg/L
1102-209-SK-45	Staff lounge sink, room 209	<1.0	µg/L

Phase II Sampled on 5/9/2017

1102-114-SK-46	Classroom sink, room 114, left sink	<1.0	µg/L
1102-114-SK-47	Classroom sink, room 114, right sink	<1.0	µg/L
1102-115-SK-48	Classroom sink, room 115, left sink	2.0	µg/L
1102-115-SK-49	Classroom sink, room 115, right sink	<1.0	µg/L
1102-116-SK-50	Faculty lounge sink, room 116	2.0	µg/L
1102-118-SK-51	Classroom sink, room 118, left sink	<1.0	µg/L
1102-118-SK-52	Classroom sink, room 118, right sink	<1.0	µg/L
1102-119-SK-53	Classroom sink, room 119	<1.0	µg/L
1102-120-SK-54	Classroom sink, room 120	<1.0	µg/L
1102-121-SK-55	Classroom sink, room 121	<1.0	µg/L
1102-123-SK-56	Classroom sink, room 123	<1.0	µg/L
1102-124-SK-57	Classroom sink, room 124	<1.0	µg/L
1102-126-SK-58	Classroom sink, room 126	<1.0	µg/L
1102-129-SK-59	Classroom sink, room 129	1.0	µg/L
1102-224-SK-60	Classroom sink, room 224	<1.0	µg/L
1102-222-SK-61	Classroom sink, room 222	9.0	µg/L
1102-332-SK-62	Classroom sink, room 332	<1.0	µg/L
1102-331-SK-63	Classroom sink, room 331, east wall, left sink	<1.0	µg/L
1102-331-SK-64	Classroom sink, room 331, east wall, right sink	<1.0	µg/L
1102-331-SK-65	Classroom sink, room 331, south wall, far left sink	<1.0	µg/L
1102-331-SK-66	Classroom sink, room 331, south wall, center left sink	<1.0	µg/L
1102-331-SK-67	Classroom sink, room 331, south wall, center right sink	<1.0	µg/L
1102-331-SK-68	Classroom sink, room 331, south wall, far right sink	<1.0	µg/L
1102-323-SK-69	Classroom sink, room 323	<1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.