

STRIVE Prep – Rise at Regis Groff Campus (1103)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/10/2016				
Sample ID	Sample Description	Lead Result	Units	Action
1103-114E-SK-01	Faculty lounge sink, room 114E	0.6	µg/L	
1103-113-SK-02	Food prep sink, kitchen 113, east wall	0.2	µg/L	
1103-110-DF-03	Drinking fountain, hallway 110, across from room 112A, left bubbler	<0.1*	µg/L	
1103-110-DF-04	Drinking fountain, hallway 110, across from room 112A, right bubbler	<0.1	µg/L	
1103-110-DF-05	Bottle fill, hallway 110, across from room 112A	<0.1	µg/L	
1103-111-SK-06	Faculty lounge sink, room 111	0.1	µg/L	
1103-100-DF-07	Drinking fountain, hallway 100, next to elevator, left bubbler	<0.1	µg/L	
1103-100-DF-08	Drinking fountain, hallway 100, next to elevator, right bubbler	<0.1	µg/L	
1103-100-DF-09	Bottle fill, hallway 100, next to elevator	<0.1	µg/L	
1103-102-DF-10	Drinking fountain, hallway 102, next to room 107, left bubbler	<0.1	µg/L	
1103-102-DF-11	Drinking fountain, hallway 102, next to room 107, right bubbler	<0.1	µg/L	
1103-102-DF-12	Bottle fill, hallway 102, next to room 107	<0.1	µg/L	
1103-117-DF-13	Drinking fountain, hallway 117, next to room 120, left bubbler	<0.1	µg/L	
1103-117-DF-14	Drinking fountain, hallway 117, next to room 120, right bubbler	<0.1	µg/L	
1103-117-DF-15	Bottle fill, hallway 117, next to room 120	<0.1	µg/L	
1103-210-DF-16	Drinking fountain, hallway 210, next to room 213, left bubbler	<0.1	µg/L	
1103-210-DF-17	Drinking fountain, hallway 210, next to room 213, right bubbler	<0.1	µg/L	
1103-210-DF-18	Bottle fill, hallway 210, next to room 213	<0.1	µg/L	
1103-200-DF-19	Drinking fountain, hallway 200, next to elevator, left bubbler	<0.1	µg/L	
1103-200-DF-20	Drinking fountain, hallway 200, next to elevator, right bubbler	<0.1	µg/L	
1103-200-DF-21	Bottle fill, hallway 200, next to elevator	<0.1	µg/L	
1103-201-DF-22	Drinking fountain, hallway 201, next to room 207, left bubbler	<0.1	µg/L	
1103-201-DF-23	Drinking fountain, hallway 201, next to room 207, right bubbler	<0.1	µg/L	
1103-201-DF-24	Bottle fill, hallway 201, next to room 207	<0.1	µg/L	
1103-116-DF-25	Drinking fountain, gymnasium 116, left bubbler	<0.1	µg/L	
1103-116-DF-26	Drinking fountain, gymnasium 116, right bubbler	<0.1	µg/L	
1103-116-DF-27	Bottle fill, gymnasium 116	<0.1	µg/L	
Phase II Sampled on 10/12/2017				
1103-131AA-SK-28	Nurse's bathroom sink, room 131AA	1.3	µg/L	
1103-145-SK-29	Community room sink, left	1.2	µg/L	
1103-145-SK-30	Community room sink, right	0.7	µg/L	

1103-130-DF-31	Drinking fountain, hallway 130, across from elevator, left bubbler	<0.1	µg/L
1103-130-DF-32	Drinking fountain, hallway 130, across from elevator, right bubbler	<0.1	µg/L
1103-130-DF-33	Bottle filler, hallway 130, across from elevator	<0.1	µg/L
1103-146-SK-34	Art room sink, room 146, southwest wall, left sink	0.3	µg/L
1103-146-SK-35	Art room sink, room 146, southwest wall, right sink	0.3	µg/L
1103-146-SK-36	Art room sink, room 146, northeast corner, utility sink	0.1	µg/L
1103-147-SK-37	Classroom sink, southwest wall, left sink	1.7	µg/L
1103-147-SK-38	Classroom sink, southwest wall, right sink	0.7	µg/L
1103-166-DF-39	Bottle filler, hallway 166, next to room 167	<0.1	µg/L
1103-166-DF-40	Drinking fountain, hallway 166, next to room 167, left bubbler	<0.1	µg/L
1103-166-DF-41	Drinking fountain, hallway 166, next to room 167, right bubbler	<0.1	µg/L
1103-166B-SK-42	Fitting room sink, room 166B	2.0	µg/L
1103-166C-SK-43	Fitting room sink, room 166C	0.5	µg/L
1103-149-DF-44	Drinking fountain, hallway 149, next to elevator, left bubbler	<0.1	µg/L
1103-149-DF-45	Drinking fountain, hallway 149, next to elevator, right bubbler	<0.1	µg/L
1103-149-DF-46	Bottle filler, hallway 149, next to elevator	<0.1	µg/L
1103-165-SK-47	Classroom sink, room 165, left sink	0.3	µg/L
1103-165-SK-48	Classroom sink, room 165, right sink	0.2	µg/L
1103-158-DF-49	Drinking fountain, hallway 158, next to room 164, left bubbler	<0.1	µg/L
1103-158-DF-50	Drinking fountain, hallway 158, next to room 164, right bubbler	<0.1	µg/L
1103-158-DF-51	Bottle filler, hallway 158, next to room 164	<0.1	µg/L
1103-162-SK-52	Workroom sink, room 162, left sink	0.2	µg/L
1103-162-SK-53	Workroom sink, room 162, right sink	0.5	µg/L
1103-150-DF-54	Drinking fountain, hallway 150, next to room 152, left bubbler	<0.1	µg/L
1103-150-DF-55	Drinking fountain, hallway 150, next to room 152, right bubbler	<0.1	µg/L
1103-150-DF-56	Bottle filler, hallway 150, next to room 152	<0.1	µg/L
1103-154-SK-57	Workroom sink, room 154, left sink	1.6	µg/L
1103-154-SK-58	Workroom sink, room 154, right sink	0.8	µg/L
1103-235-DF-59	Drinking fountain, hallway 235, next to room 238, left bubbler	<0.1	µg/L
1103-235-DF-60	Drinking fountain, hallway 235, next to room 238, right bubbler	<0.1	µg/L
1103-235-DF-61	Bottle filler, hallway 235, next to room 238	<0.1	µg/L
1103-237-SK-62	Science lab sink, room 237, demo sink	0.9	µg/L
1103-237-SK-63	Science lab sink, room 237, northeast wall, left sink	1.3	µg/L
1103-237-SK-64	Science lab sink, room 237, northeast wall, right sink	0.4	µg/L
1103-237-SK-65	Science lab sink, room 237, southeast wall, left sink	1.3	µg/L
1103-237-SK-66	Science lab sink, room 237, southeast wall, right sink	0.5	µg/L
1103-237A-SK-67	Science lab sink, prep room 237A	1.0	µg/L
1103-236-SK-68	Classroom sink, room 236	1.2	µg/L
1103-234-DF-69	Drinking fountain, hallway 234, next to elevator, left bubbler	<0.1	µg/L
1103-234-DF-70	Drinking fountain, hallway 234, next to elevator, right bubbler	<0.1	µg/L
1103-234-DF-71	Bottle filler, hallway 234, next to elevator	<0.1	µg/L
1103-244-DF-72	Drinking fountain, hallway 244, next to room 250, left bubbler	<0.1	µg/L
1103-244-DF-73	Drinking fountain, hallway 244, next to room 250, right bubbler	<0.1	µg/L

1103-244-DF-74	Bottle filler, hallway 244, next to room 250	<0.1	µg/L
1103-251-SK-75	Science lab sink, room 251, demo sink	1.4	µg/L
1103-251-SK-76	Science lab sink, room 251, north wall, left sink	0.5	µg/L
1103-251-SK-77	Science lab sink, room 251, north wall, right sink	0.1	µg/L
1103-251-SK-78	Science lab sink, room 251, east wall, left sink	0.9	µg/L
1103-251-SK-79	Science lab sink, room 251, east wall, right sink	0.5	µg/L
1103-251A-SK-80	Science lab sink, prep room 251A	1.9	µg/L
1103-232-SK-81	Classroom sink, room 232	0.3	µg/L
1103-220-DF-82	Drinking fountain, hallway 220, across from elevator, left bubbler	<0.1	µg/L
1103-220-DF-83	Drinking fountain, hallway 220, across from elevator, right bubbler	<0.1	µg/L
1103-220-DF-84	Bottle filler, hallway 220, across from elevator	<0.1	µg/L
1103-230-SK-85	Workroom sink, room 230, left sink	0.6	µg/L
1103-230-SK-86	Workroom sink, room 230, right sink	0.6	µg/L
1103-101A-SK-87	Faculty lounge sink, room 101A, left sink	4.0	µg/L
1103-101A-SK-88	Faculty lounge sink, room 101A, right sink	0.5	µg/L
1103-108-SK-89	Classroom sink, room 108	0.2	µg/L
1103-218-SK-90	Classroom sink, room 218	14.6	µg/L
1103-212-SK-91	Science lab sink, room 212, demo sink	0.2	µg/L
1103-212-SK-92	Science lab sink, room 212, southwest wall, left sink	<0.1	µg/L
1103-212-SK-93	Science lab sink, room 212, southwest wall, right sink	<0.1	µg/L
1103-212-SK-94	Science lab sink, room 212, northwest wall, left sink	<0.1	µg/L
1103-212-SK-95	Science lab sink, room 212, northwest wall, right sink	<0.1	µg/L
1103-212-SK-96	Science lab sink, room 212, northeast wall, left sink	0.1	µg/L
1103-212-SK-97	Science lab sink, room 212, northeast wall, right sink	<0.1	µg/L
1103-212A-SK-98	Science lab sink, prep room 212A	<0.1	µg/L
1103-209-SK-99	Classroom sink, room 209	0.9	µg/L
1103-208-SK-100	Science lab sink, room 208, demo sink	2.8	µg/L
1103-208-SK-101	Science lab sink, room 208, north wall, left sink	0.9	µg/L
1103-208-SK-102	Science lab sink, room 208, north wall, right sink	0.6	µg/L
1103-208-SK-103	Science lab sink, room 208, east wall, left sink	1.2	µg/L
1103-208-SK-104	Science lab sink, room 208, east wall, right sink	0.6	µg/L
1103-208-SK-105	Science lab sink, room 208, south wall, left sink	2.1	µg/L
1103-208-SK-106	Science lab sink, room 208, south wall, right sink	0.1	µg/L
1103-208A-SK-107	Science lab sink, prep room 208A	0.2	µg/L
1103-252-SK-108	Classroom sink, room 252	1.2	µg/L
1103-233-SK-109	Classroom sink, room 233	1.8	µg/L

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.