

Sandra Todd Williams (1107) – Sampled 5/9/2017

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Sample ID	Sample Description	Lead Result	Units	Action
1107-103-SK-01	Multi-purpose room 103, hand sink on left	1.0	µg/L	
1107-103-SK-02	Multi-purpose room 103, hand sink on right	<1.0* ¹	µg/L	
1107-103-SK-03	Multi-purpose room 103, regular sink	<1.0	µg/L	
1107-101B-SK-04	Nurse sink, room 101B	<1.0	µg/L	
1107-101C-SK-05	Faculty workroom sink, room 101C	<1.0	µg/L	
1107-100-DF-06	Drinking fountain, left bubbler, hallway 100	<1.0	µg/L	
1107-100-DF-07	Drinking fountain, right bubbler, hallway 100	<1.0	µg/L	
1107-100-DF-08	Bottle fill station, hallway 100	<1.0	µg/L	
1107-114-SK-09	Faculty workroom sink, room 114	<1.0	µg/L	
1107-106-SK-10	Classroom sink, room 106, on left	<1.0	µg/L	
1107-106-DF-11	Drinking fountain, room 106	<1.0	µg/L	
1107-106-SK-12	Classroom sink, room 106, on right	1.0	µg/L	
1107-113-SK-13	Classroom sink, room 113, on left	<1.0	µg/L	
1107-113-DF-14	Drinking fountain, room 113	<1.0	µg/L	
1107-113-SK-15	Classroom sink, room 113, on right	1.0	µg/L	
1107-107-SK-16	Classroom sink, room 107, on left	<1.0	µg/L	
1107-107-DF-17	Drinking fountain, room 107	<1.0	µg/L	
1107-107-SK-18	Classroom sink, room 107, on right	1.0	µg/L	
1107-112-SK-19	Classroom sink, room 112, on left	<1.0	µg/L	
1107-112-DF-20	Drinking fountain, room 112	<1.0	µg/L	
1107-112-SK-21	Classroom sink, room 112, on right	<1.0	µg/L	
1107-108-SK-22	Classroom sink, room 108, on left	1.0	µg/L	
1107-108-DF-23	Drinking fountain, room 108	<1.0	µg/L	
1107-108-SK-24	Classroom sink, room 108, on right	<1.0	µg/L	
1107-111-SK-25	Classroom sink, room 111, on left	<1.0	µg/L	
1107-111-DF-26	Drinking fountain, room 111	<1.0	µg/L	
1107-111-SK-27	Classroom sink, room 111, on right	1.0	µg/L	
1107-109-SK-28	Classroom sink, room 109, on left	<1.0	µg/L	
1107-109-DF-29	Drinking fountain, room 109	<1.0	µg/L	
1107-109-SK-30	Classroom sink, room 109, on right	2.0	µg/L	
1107-110-SK-31	Classroom sink, room 110, on left	2.0	µg/L	
1107-110-DF-32	Drinking fountain, room 110	<1.0	µg/L	
1107-110-SK-33	Classroom sink, room 110, on right	<1.0	µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.