

Swigert International @ Swigert-McAuliffe Elementary (174)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/12/2016				
Sample ID	Sample Description	Lead Result	Units	Action
174-124A-SK-01	Kitchen prep sink, northwest corner	0.9	µg/L	
174-124A-SK-02	Kitchen kettle fill, center of kitchen	1.1	µg/L	
174-124A-SK-03	Kitchen prep sink, southwest corner	1.4	µg/L	
174-100-DF-04	Drinking fountain, hallway 100, next to room 123	0.4	µg/L	
174-122-DF-05	Drinking fountain, gymnasium, next to boys locker room	0.5	µg/L	
174-122-DF-06	Drinking fountain, gymnasium, next to girls locker room	0.4	µg/L	
174-102B-SK-07	Lounge sink, room 102B, lower counter	0.6	µg/L	
174-115-DF-08	Drinking fountain, hallway 115, across from room 107	0.2	µg/L	
174-115-DF-09	Drinking fountain, hallway 115, across from room 109	0.2	µg/L	
174-127-DF-10	Drinking fountain, room 127	0.4	µg/L	
174-127-SK-11	Classroom sink, room 127, southeast corner	0.4	µg/L	
174-129-DF-12	Drinking fountain, room 129	0.4	µg/L	
174-131-DF-13	Drinking fountain, room 131	1.0	µg/L	
174-137-SK-14	Classroom sink, room, 137	0.5	µg/L	
174-136-SK-15	Classroom sink, room 136, lower counter	0.6	µg/L	
174-135-DF-16	Drinking fountain, room 135	0.4	µg/L	
174-135-SK-17	Classroom sink, room 135, south end of room	1.3	µg/L	
174-100E-SK-18	Nurse sink, room 100E	1.1	µg/L	
174-200-DF-19	Drinking fountain, hallway 200, next to room 203, left bubbler	0.5	µg/L	
174-200-DF-20	Drinking fountain, hallway 200, next to room 203, right bubbler	0.5	µg/L	
174-200-DF-21	Drinking fountain, hallway 200, across from room 207	0.3	µg/L	
174-200-DF-22	Drinking fountain, hallway 200, across from room 208	0.2	µg/L	
174-300-DF-23	Drinking fountain, hallway 300, next to room 303, left bubbler	0.4	µg/L	
174-300-DF-24	Drinking fountain, hallway 300, next to room 303, right bubbler	0.5	µg/L	
174-300-DF-25	Drinking fountain, hallway 300, across from room 307	0.2	µg/L	
174-300-DF-26	Drinking fountain, hallway 300, across from room 309	0.4	µg/L	
Phase II Sampled on 5/3/2017				
174-135-SK-27	Classroom sink, room 135, north wall	<1.0* ¹	µg/L	
174-136-SK-28	Classroom sink, room 136, south wall	<1.0	µg/L	
174-137-SK-29	Classroom sink, room 137, south wall	<1.0	µg/L	
174-131-SK-30	Classroom sink, room 131, upper counter, left sink	<1.0	µg/L	
174-131-SK-31	Classroom sink, room 131, lower counter, right sink	<1.0	µg/L	
174-129-SK-32	Classroom sink, room 129, upper counter, left sink	<1.0	µg/L	
174-129-SK-33	Classroom sink, room 129, lower counter, right sink	<1.0	µg/L	
174-127-SK-34	Classroom sink, room 127, lower counter, left sink	<1.0	µg/L	
174-125-SK-35	Classroom sink, room 125, far left sink	<1.0	µg/L	
174-125-SK-36	Classroom sink, room 125, center left sink	<1.0	µg/L	

174-125-SK-37	Classroom sink, room 125, center right sink	<1.0	µg/L
174-125-SK-38	Classroom sink, room 125, far right sink	<1.0	µg/L
174-125-SK-39	Classroom sink, room 125, utility sink on east wall	<1.0	µg/L
174-126-SK-40	Classroom sink, room 126	<1.0	µg/L
174-126-DF-41	Drinking fountain, room 126	<1.0	µg/L
174-123-SK-42	Classroom sink, room 123	<1.0	µg/L
174-103-SK-43	Classroom sink, room 103	<1.0	µg/L
174-104-SK-44	Classroom sink, room 104	<1.0	µg/L
174-105-SK-45	Classroom sink, room 105	<1.0	µg/L
174-106-SK-46	Classroom sink, room 106	<1.0	µg/L
174-107-SK-47	Classroom sink, room 107	<1.0	µg/L
174-109-SK-48	Classroom sink, room 109	<1.0	µg/L
174-111-SK-49	Classroom sink, room 111	<1.0	µg/L
174-112-SK-50	Classroom sink, room 112	<1.0	µg/L
174-113-SK-51	Classroom sink, room 113	<1.0	µg/L
174-114-SK-52	Classroom sink, room 114	<1.0	µg/L
174-220-SK-53	Faculty workroom sink, room 220	<1.0	µg/L
174-206A-SK-54	Prep room sink, room 206A	1.0	µg/L
174-211-SK-55	Classroom sink, room 211	<1.0	µg/L
174-212-SK-56	Classroom sink, room 212	<1.0	µg/L
174-213-SK-57	Classroom sink, room 213	<1.0	µg/L
174-214-SK-58	Classroom sink, room 214	<1.0	µg/L
174-306-SK-59	Classroom sink, room 306	<1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.