

SOAR @ Evie Dennis Campus Bldg. #4 (175)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/12/2016				
Sample ID	Sample Description	Lead Result	Units	Action
175-124-DF-01	Drinking fountain, room 4-124, next to restroom, fountain-sink combination	0.3	µg/L	
175-119-DF-02	Drinking fountain, hallway 4-119, next to restrooms, left bubbler	0.4	µg/L	
175-119-DF-03	Drinking fountain, hallway 4-119, next to restrooms, right bubbler	0.3	µg/L	
175-113-SK-04	Staff workroom sink, room 4-113	0.3	µg/L	
175-110-SK-05	Admin office sink, room 4-110	0.5	µg/L	
175-140-DF-06	Drinking fountain, room 4-140, next to restroom, fountain-sink combination	0.4	µg/L	
175-136-DF-07	Drinking fountain, room 4-136, next to restroom, fountain-sink combination	0.6	µg/L	
175-135-DF-08	Drinking fountain, room 4-135, next to restroom, fountain-sink combination	0.3	µg/L	
175-131-DF-09	Drinking fountain, room 4-131, next to restroom, fountain-sink combination	0.5	µg/L	
175-201-DF-10	Drinking fountain, lobby 4-201, next to room 4-223, left bubbler (right side inoperable)	0.2	µg/L	
175-218-DF-12	Drinking fountain, room 4-218, fountain-sink combination	1.2	µg/L	
175-208-DF-14	Drinking fountain, hallway 4-208, next to restrooms, right bubbler (left side inoperable)	0.4	µg/L	
175-207-DF-15	Drinking fountain, room 4-207, fountain-sink combination	0.2	µg/L	
175-120-DF-16	Drinking fountain, room 4-120, next to restroom, fountain-sink combination	0.4	µg/L	
Phase II Sampled on 5/11/2017				
175-4-120-SK-17	Classroom sink, room 120	<1.0* ¹	µg/L	
175-4-124-SK-18	Classroom sink, room 124	<1.0	µg/L	
175-4-114-SK-19	Classroom sink, utility sink, room 114	17.0	µg/L	Hand wash / cleaning only notice
175-4-140-SK-20	Classroom sink, room 140	<1.0	µg/L	
175-4-136-SK-21	Classroom sink, room 136	<1.0	µg/L	
175-4-135-SK-22	Classroom sink, room 135	<1.0	µg/L	
175-4-131-SK-23	Classroom sink, room 131	<1.0	µg/L	
175-4-218-SK-24	Classroom sink, room 218	<1.0	µg/L	
175-4-214-DF-25	Bottle fill station, hallway 214, next to room 223	<1.0	µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

NOTE: Sample numbers 11 & 13 not collected due to inoperable fixtures at the time of sampling.