

Escalante-Biggs Academy (179)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

| Phase I Sampled on 10/7/2016 | | | | | |
|------------------------------|---|--------------------|------------------|-------|--------|
| Sample ID | Sample Description | Lead Result | Follow Up Sample | Units | Action |
| 179-136-SK-01 | Staff lounge sink, room 136 | 0.7 | | µg/L | |
| 179-102-DF-02 | Drinking fountain, room 102 | 0.5 | | µg/L | |
| 179-102-SK-03 | Classroom sink, room 102 | 0.5 | | µg/L | |
| 179-103-SK-04 | Classroom sink, room 103 | 0.4 | | µg/L | |
| 179-103-DF-05 | Drinking fountain, room 103 | 0.3 | | µg/L | |
| 179-104-DF-06 | Drinking fountain, room 104 | 0.3 | | µg/L | |
| 179-104-SK-07 | Classroom sink, room 104 | 0.4 | | µg/L | |
| 179-107-SK-08 | Drinking fountain, room 107 | 0.8 | | µg/L | |
| 179-107-DF-09 | Classroom sink, room 107 | 0.2 | | µg/L | |
| 179-108-DF-10 | Drinking fountain, room 108 | 0.3 | | µg/L | |
| 179-109-DF-11 | Drinking fountain, room 109 | 0.3 | | µg/L | |
| 179-110-SK-12 | Classroom sink, room 110 | 0.8 | | µg/L | |
| 179-110-DF-13 | Drinking fountain, room 110 | 0.3 | | µg/L | |
| 179-100-DF-14 | Drinking fountain, hallway 100, next to room 110, left bubbler | 0.2 | | µg/L | |
| 179-100-DF-15 | Drinking fountain, hallway 100, next to room 110, right bubbler | 0.2 | | µg/L | |
| 179-111-SK-16 | Classroom sink, room 111 | 0.9 | | µg/L | |
| 179-111-DF-17 | Drinking fountain, room 111 | 0.2 | | µg/L | |
| 179-112-DF-18 | Drinking fountain, room 112, left bubbler | 0.5 | | µg/L | |
| 179-112-DF-19 | Drinking fountain, room 112, right bubbler | 0.2 | | µg/L | |
| 179-113-DF-20 | Drinking fountain, room 113, left bubbler | 0.6 | | µg/L | |
| 179-113-DF-21 | Drinking fountain, room 113, right bubbler | 0.3 | | µg/L | |
| 179-116-DF-22 | Drinking fountain, hallway 116, next to room 113, left bubbler | 0.1 | | µg/L | |
| 179-116-DF-23 | Drinking fountain, hallway 116, next to room 113, right bubbler | 0.1 | | µg/L | |
| 179-116-DF-24 | Drinking fountain, hallway 116, next to room 114, left bubbler | 0.1 | | µg/L | |
| 179-116-DF-25 | Drinking fountain, hallway 116, next to room 114, right bubbler | <0.1* ¹ | | µg/L | |
| 179-114-DF-26 | Drinking fountain, room 114, northwest corner | 0.2 | | µg/L | |
| 179-114-DF-27 | Drinking fountain, room 114, next to sink | 2.8 | | µg/L | |
| 179-115-DF-28 | Drinking fountain, room 115, next to sink | 0.2 | | µg/L | |
| 179-115-DF-29 | Drinking fountain, room 115, west corner | 0.2 | | µg/L | |
| 179-117-DF-30 | Drinking fountain, all purpose room 117, left bubbler | 0.1 | | µg/L | |
| 179-117-DF-31 | Drinking fountain, all purpose room 117, right bubbler | 0.1 | | µg/L | |
| 179-118-DF-32 | Drinking fountain, room 118, next to sink | 0.2 | | µg/L | |
| 179-118-DF-33 | Drinking fountain, room 118, south corner | 1.3 | | µg/L | |

| | | | | | |
|-------------------------------------|--|--------------------|-------------------|------|------------------|
| 179-119-DF-34 | Drinking fountain, staff lounge, room 119 | 19.6 | 4.0* ² | µg/L | Filter installed |
| 179-120-DF-35 | Drinking fountain, room 120, next to sink | 0.4 | | µg/L | |
| 179-120-DF-36 | Drinking fountain, room 120, southeast corner | 0.2 | | µg/L | |
| 179-121-DF-37 | Drinking fountain, room 121 | 0.2 | | µg/L | |
| 179-122-SK-38 | Classroom sink, room 122 | 0.3 | | µg/L | |
| 179-122-DF-39 | Drinking fountain, room 122 | 0.3 | | µg/L | |
| 179-123-DF-40 | Drinking fountain, room 123 | 0.4 | | µg/L | |
| 179-126-DF-41 | Drinking fountain, room 126 | 0.3 | | µg/L | |
| 179-127-DF-42 | Drinking fountain, room 127 | 0.4 | | µg/L | |
| 179-128-DF-43 | Drinking fountain, room 128 | 0.4 | | µg/L | |
| 179-129-DF-44 | Drinking fountain, all purpose room 129, west wall | 0.1 | | µg/L | |
| 179-130-SK-45 | Kitchen sink, left faucet | 0.7 | | µg/L | |
| 179-130-SK-46 | Kitchen sink, right faucet | 1.4 | | µg/L | |
| 179-100-DF-47 | Drinking fountain, hallway 100, next to room 100B, left bubbler | 0.2 | | µg/L | |
| 179-100-DF-48 | Drinking fountain, hallway 100, next to room 100B, right bubbler | 0.2 | | µg/L | |
| 179-131-SK-49 | Nurse sink, room 131 | 1.6 | | µg/L | |
| 179-105-SK-50 | Staff lounge sink, room 105 | 0.6 | | µg/L | |
| Phase II Sampled on 5/2/2017 | | | | | |
| 179-136-SK-51 | Staff lounge sink, room 136 | <1.0* ³ | | µg/L | |
| 179-108-SK-52 | Classroom sink, room 108 | <1.0 | | µg/L | |
| 179-109-SK-53 | Classroom sink, room 109 | <1.0 | | µg/L | |
| 179-128-SK-54 | Classroom sink, room 128 | <1.0 | | µg/L | |
| 179-127-SK-55 | Classroom sink, room 127 | <1.0 | | µg/L | |
| 179-126-SK-56 | Classroom sink, room 126 | <1.0 | | µg/L | |
| 179-123-SK-57 | Classroom sink, room 123 | <1.0 | | µg/L | |
| 179-121-SK-58 | Classroom sink, room 121 | <1.0 | | µg/L | |
| 179-112-SK-59 | Classroom sink, room 112 | <1.0 | | µg/L | |
| 179-113-SK-60 | Classroom sink, room 113 | 1.0 | | µg/L | |
| 179-120-SK-61 | Classroom sink, room 120 | 1.0 | | µg/L | |
| 179-119-SK-62 | Staff lounge sink, room 119 | <1.0 | | µg/L | |
| 179-119-DF-63 | Drinking fountain, staff lounge, room 119 | 5.0 | | µg/L | |
| 179-118-SK-64 | Classroom sink, room 118 | 1.0 | | µg/L | |
| 179-114-SK-65 | Classroom sink, room 114 | <1.0 | | µg/L | |
| 179-115-SK-66 | Classroom sink, room 115 | <1.0 | | µg/L | |
| 179-124-SK-67 | Staff lounge sink, room 124 | 1.0 | | µg/L | |

*1. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.

*2. Follow up samples are field tested with a Palintest SA1100 scanning analyzer.

*3. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.