

## Roberts Elementary (194)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/5-6/2016

Sample ID	Sample Description	Lead Result	Units	Action
194-143B-SK-01	Kitchen prep sink, room 143B, center	<1.0* <sup>1</sup>	µg/L	
194-143B-SK-02	Kitchen sink, north wall, on left	<1.0	µg/L	
194-100-DF-03	Drinking fountain, hallway 100, across from all purpose room, left bubbler	<1.0	µg/L	
194-100-DF-04	Drinking fountain, hallway 100, across from all purpose room, right bubbler	<1.0	µg/L	
194-144-DF-05	Drinking fountain, room 144	<1.0	µg/L	
194-142-DF-06	Drinking fountain, gymnasium, east wall	<1.0	µg/L	
194-101B-DF-07	Drinking fountain, nurse sink, room 101B	<1.0	µg/L	
194-101M-DF-08	Drinking fountain, staff lounge sink, room 101M	<1.0	µg/L	
194-113-DF-09	Drinking fountain, room 113, northeast corner	<1.0	µg/L	
194-113-DF-10	Drinking fountain, room 113, southwest corner, next to rest rooms	<1.0	µg/L	
194-112-DF-11	Drinking fountain, room 112, southwest corner	<1.0	µg/L	
194-112-DF-12	Drinking fountain, room 112, next to restrooms	<1.0	µg/L	
194-111DF-13	Drinking fountain, room 111, southwest corner	<1.0	µg/L	
194-111-DF-14	Drinking fountain, room 111, next to restrooms	<1.0	µg/L	
194-110-DF-15	Drinking fountain, room 110, northeast corner	<1.0	µg/L	
194-110-DF-16	Drinking fountain, room 110, next to restrooms	<1.0	µg/L	
194-115-DF-17	Drinking fountain, room 115	<1.0	µg/L	
194-116-DF-18	Drinking fountain, room 116	<1.0	µg/L	
194-107-DF-19	Drinking fountain, room 107	1.2	µg/L	
194-118-DF-20	Drinking fountain, room 118	<1.0	µg/L	
194-119-DF-21	Drinking fountain, room 119	<1.0	µg/L	
194-114-DF-22	Drinking fountain, hallway 144, across from room 122, left bubbler	<1.0	µg/L	
194-114-DF-23	Drinking fountain, hallway 144, across from room 122, right bubbler	<1.0	µg/L	
194-122-DF-24	Drinking fountain, room 122	<1.0	µg/L	
194-123-DF-25	Drinking fountain, room 123	<1.0	µg/L	
194-125-DF-26	Drinking fountain, room 125	<1.0	µg/L	
194-126-DF-27	Drinking fountain, room 127	<1.0	µg/L	
194-128-DF-28	Drinking fountain, room 128	<1.0	µg/L	
194-127-DF-29	Drinking fountain, room 127	<1.0	µg/L	
194-105-DF-30	Drinking fountain, room 105	<1.0	µg/L	
194-106-DF-31	Drinking fountain, room 106	1.1	µg/L	
194-130B-DF-32	Drinking fountain, room 130B, LMC office	0.8	µg/L	
194-134-DF-33	Drinking fountain, room 134	0.3	µg/L	

<b>194-136-DF-34</b>	Drinking fountain, room 136	0.2	µg/L
<b>194-137-DF-35</b>	Drinking fountain, room 137	0.4	µg/L
<b>194-131-DF-36</b>	Drinking fountain, hallway 131, across from room 137, left bubbler	0.2	µg/L
<b>194-131-DF-37</b>	Drinking fountain, hallway 131, across from room 137, right bubbler	0.3	µg/L
<b>194-138-DF-38</b>	Drinking fountain, room 138	0.2	µg/L
<b>194-139-DF-39</b>	Drinking fountain, room 139	0.9	µg/L
<b>194-140-DF-40</b>	Drinking fountain, room 140	0.2	µg/L
<b>194-201-DF-41</b>	Drinking fountain, hallway 201, across from room 206, left bubbler	0.2	µg/L
<b>194-201-DF-42</b>	Drinking fountain, hallway 201, across from room 206, right bubbler	0.2	µg/L
<b>194-211-DF-43</b>	Drinking fountain, hallway 211, across from elevator	0.2	µg/L
<b>194-213-DF-44</b>	Drinking fountain, hallway 213, across from room 218, left bubbler	0.2	µg/L
<b>194-213-DF-45</b>	Drinking fountain, hallway 213, across from room 218, right bubbler	0.6	µg/L
<b>194-221-DF-46</b>	Drinking fountain, room 221	0.4	µg/L

**Phase II Sampled on 4/26/2017**

<b>194-143A-SK-47</b>	PTA kitchen sink, room 143A	<1.0	µg/L
<b>194-101B-SK-48</b>	Nurse sink, room 101B	<1.0	µg/L
<b>194-101M-SK-49</b>	Faculty lounge sink, room 101M	<1.0	µg/L
<b>194-140-SK-50</b>	Classroom sink, room 140	<1.0	µg/L
<b>194-139-SK-51</b>	Classroom sink, room 139	<1.0	µg/L
<b>194-138-SK-52</b>	Classroom sink, room 138	<1.0	µg/L
<b>194-137-SK-53</b>	Classroom sink, room 137	<1.0	µg/L
<b>194-136-SK-54</b>	Classroom sink, room 136	<1.0	µg/L
<b>194-134-SK-55</b>	Classroom sink, room 134	<1.0	µg/L
<b>194-132-SK-56</b>	Classroom sink, room 132, north wall	<1.0	µg/L
<b>194-132-SK-57</b>	Classroom sink, room 132, west wall	4.0	µg/L
<b>194-130B-SK-58</b>	LMC/IMC office sink, room 130B	<1.0	µg/L
<b>194-127-SK-59</b>	Classroom sink, room 127	<1.0	µg/L
<b>194-128-SK-60</b>	Classroom sink, room 128	<1.0	µg/L
<b>194-126-SK-61</b>	Classroom sink, room 126	<1.0	µg/L
<b>194-125-SK-62</b>	Classroom sink, room 125	<1.0	µg/L
<b>194-123-SK-63</b>	Classroom sink, room 123	<1.0	µg/L
<b>194-122-SK-64</b>	Classroom sink, room 122	<1.0	µg/L
<b>194-119-SK-65</b>	Classroom sink, room 119	<1.0	µg/L
<b>194-118-SK-66</b>	Classroom sink, room 118	<1.0	µg/L
<b>194-116-SK-67</b>	Classroom sink, room 116	<1.0	µg/L
<b>194-115-SK-68</b>	Classroom sink, room 115	<1.0	µg/L
<b>194-113-SK-69</b>	Classroom sink, room 113	<1.0	µg/L
<b>194-112-SK-70</b>	Classroom sink, room 112	<1.0	µg/L
<b>194-111-SK-71</b>	Classroom sink, room 111	<1.0	µg/L
<b>194-110-SK-72</b>	Classroom sink, room 110	<1.0	µg/L
<b>194-107-SK-73</b>	Classroom sink, room 107	<1.0	µg/L
<b>194-105-SK-74</b>	Classroom sink, room 105	1.0	µg/L

<b>194-212A-SK-75</b>	Prep room sink, room 212A, left sink	<1.0	µg/L
<b>194-212A-SK-76</b>	Prep room sink, room 212A, right sink	<1.0	µg/L
<b>194-217-SK-77</b>	Classroom sink, room 217, west wall, right sink	1.0	µg/L
<b>194-221-SK-78</b>	Classroom sink, room 221	<1.0	µg/L
<b>194-144-SK-79</b>	Classroom sink, room 144	<1.0	µg/L
<b>194-144-SK-80</b>	Classroom sink, room 144, utility sink	3.0	µg/L
<b>194-106-SK-81</b>	Classroom sink, room 106, east wall	<1.0	µg/L
<b>194-106-SK-82</b>	Classroom sink, room 106, west wall	<1.0	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.