

## Waller Elementary (195)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/7, 11, 12/2016				
Sample ID	Sample Description	Lead Result	Units	Action
195-105B-SK-01	PTA kitchen sink, room 105B	0.5	µg/L	
195-102C-DF-02	Drinking fountain, hallway 102C, next to restrooms, left bubbler	0.4	µg/L	
195-102C-DF-03	Drinking fountain, hallway 102C, next to restrooms, right bubbler	0.2	µg/L	
195-103E-DF-04	Drinking fountain, boys locker room 103E	<0.1* <sup>1</sup>	µg/L	
195-101A-SK-05	Nurse sink, room 101A	0.3	µg/L	
195-101R-SK-06	Staff lounge sink, room 101R	0.3	µg/L	
195-103B-DF-07	Drinking fountain, girls locker room 103B	0.2	µg/L	
195-107-SK-08	Community room sink, room 107	0.6	µg/L	
195-106A-SK-09	Kitchen sink, across from room 106AD	1.0	µg/L	
195-106A-SK-10	Kitchen sink, across from room 106AF	0.9	µg/L	
195-106A-SK-11	Kitchen sink near west wall, across from 106AA	0.4	µg/L	
195-106A-SK-12	Kitchen sink, on south wall	0.7	µg/L	
195-127-DF-13	Drinking fountain, room 127, west wall, left bubbler	1.0	µg/L	
195-127-DF-14	Drinking fountain, room 127, west wall, right bubbler	1.5	µg/L	
195-127-DF-15	Drinking fountain, room 127, south wall	0.1	µg/L	
195-128-DF-16	Drinking fountain, room 128, west wall, left sink	0.5	µg/L	
195-128-DF-17	Drinking fountain, room 128, north wall	0.1	µg/L	
195-129-DF-18	Drinking fountain, room 129, west wall, on left	0.6	µg/L	
195-129-DF-19	Drinking fountain, room 129, west wall, on right	0.3	µg/L	
195-129A-DF-20	Drinking fountain, hallway 129A, between rooms 129 and 130	0.2	µg/L	
195-130-DF-21	Drinking fountain, room 130, west wall, on right	0.6	µg/L	
195-125-DF-22	Drinking fountain, room 125, south wall, on left	0.7	µg/L	
195-125-DF-23	Drinking fountain, room 125, south wall, on right	0.5	µg/L	
195-125-DF-24	Drinking fountain, room 125, west wall	<0.1	µg/L	
195-131-DF-25	Drinking fountain, room 131, north wall, on left	0.6	µg/L	
195-131-DF-26	Drinking fountain, room 131, north wall, on right	0.4	µg/L	
195-131A-DF-27	Drinking fountain, hallway 131A, between rooms 131 and 132	0.1	µg/L	
195-132-DF-28	Drinking fountain, room 132, north wall, on left	0.2	µg/L	
195-132-DF-29	Drinking fountain, room 132, north wall, on left	0.5	µg/L	
195-124-DF-30	Drinking fountain, room 124, east wall	0.1	µg/L	
195-123-DF-31	Drinking fountain, room 123, south wall, on left	0.4	µg/L	
195-123-DF-32	Drinking fountain, room 123, south wall, on right	0.3	µg/L	
195-122-DF-33	Drinking fountain, room 122	0.2	µg/L	

195-121-DF-34	Drinking fountain, room 121	0.4	µg/L
195-120-DF-35	Drinking fountain, room 120	0.3	µg/L
195-119-DF-36	Drinking fountain, room 119	0.2	µg/L
195-118-DF-37	Drinking fountain, room 118	0.7	µg/L
195-116-DF-38	Drinking fountain, room 116, west wall, on left	0.3	µg/L
195-116-DF-39	Drinking fountain, room 116, west wall, on right	0.3	µg/L
195-109E-DF-40	Drinking fountain, hallway 109E, near room 116, left bubbler	0.2	µg/L
195-109E-DF-41	Drinking fountain, hallway 109E, near room 116, right bubbler	0.2	µg/L
195-115-DF-42	Drinking fountain, room 115, west wall, on left	0.2	µg/L
195-115-DF-43	Drinking fountain, room 115, west wall, on right	0.5	µg/L
195-114-DF-44	Drinking fountain, room 114, west wall	0.3	µg/L
195-112-DF-45	Drinking fountain, room 112, west wall	0.2	µg/L
195-136-DF-46	Drinking fountain, room 136, south wall	0.3	µg/L
195-137-DF-47	Drinking fountain, room 137, east wall	0.1	µg/L
195-138-DF-48	Drinking fountain, room 138, east wall	0.1	µg/L
195-140-DF-49	Drinking fountain, room 140, east wall	0.2	µg/L
195-142-DF-50	Drinking fountain, room 142, east wall	0.2	µg/L
195-143-DF-51	Drinking fountain, room 143, east wall	0.3	µg/L
195-144-DF-52	Drinking fountain, room 144, west wall	<0.1	µg/L
195-134B-DF-53	Drinking fountain, hallway 134B, across from 145, left bubbler	0.2	µg/L
195-134B-DF-54	Drinking fountain, hallway 134B, across from 145, right bubbler	0.2	µg/L
195-204E-DF-55	Drinking fountain, hallway 204E, near room 211, left bubbler	<0.1	µg/L
195-204E-DF-56	Drinking fountain, hallway 204E, near room 211, right bubbler	<0.1	µg/L
195-200-DF-57	Drinking fountain, hallway 200, across from room 201, left bubbler	<0.1	µg/L
195-200-DF-58	Drinking fountain, hallway 200, across from room 201, right bubbler	<0.1	µg/L
<b>Phase II Sampled on 5/2/2017</b>			
195-110-SK-59	Classroom sink, room 110	<1.0* <sup>2</sup>	µg/L
195-112-SK-60	Classroom sink, room 112	<1.0	µg/L
195-114-SK-61	Classroom sink, room 114	<1.0	µg/L
195-115-SK-62	Classroom sink, room 115, left sink	<1.0	µg/L
195-115-SK-63	Classroom sink, room 115, right sink	<1.0	µg/L
195-116-SK-64	Classroom sink, room 116, left sink	<1.0	µg/L
195-116-SK-65	Classroom sink, room 116, right sink	<1.0	µg/L
195-118-SK-66	Classroom sink, room 118	<1.0	µg/L
195-119-SK-67	Classroom sink, room 119, left sink	<1.0	µg/L
195-119-SK-68	Classroom sink, room 119, right sink	<1.0	µg/L
195-120-SK-69	Classroom sink, room 120, left sink	<1.0	µg/L
195-120-SK-70	Classroom sink, room 120, right sink	<1.0	µg/L
195-121-SK-71	Classroom sink, room 121	<1.0	µg/L
195-122-SK-72	Classroom sink, room 122, left sink	4.0	µg/L
195-122-SK-73	Classroom sink, room 122, right sink	<1.0	µg/L
195-123-SK-74	Classroom sink, room 123, left sink	<1.0	µg/L

<b>195-123-SK-75</b>	Classroom sink, room 123, right sink	<1.0	µg/L
<b>195-124-SK-76</b>	Classroom sink, room 124, left sink	<1.0	µg/L
<b>195-124-SK-77</b>	Classroom sink, room 124, right sink	<1.0	µg/L
<b>195-125-SK-78</b>	Classroom sink, room 125, left sink	<1.0	µg/L
<b>195-125-SK-79</b>	Classroom sink, room 125, right sink	<1.0	µg/L
<b>195-130-SK-80</b>	Classroom sink, room 130, left sink	<1.0	µg/L
<b>195-130-SK-81</b>	Classroom sink, room 130, right sink	<1.0	µg/L
<b>195-129-SK-82</b>	Classroom sink, room 129, left sink	<1.0	µg/L
<b>195-129-SK-83</b>	Classroom sink, room 129, right sink	<1.0	µg/L
<b>195-128-SK-84</b>	Classroom sink, room 128, left sink	<1.0	µg/L
<b>195-128-SK-85</b>	Classroom sink, room 128, right sink	<1.0	µg/L
<b>195-127-SK-86</b>	Classroom sink, room 127, left sink	<1.0	µg/L
<b>195-127-SK-87</b>	Classroom sink, room 127, right sink	<1.0	µg/L
<b>195-131-SK-88</b>	Classroom sink, room 131, left sink	1.0	µg/L
<b>195-131-SK-89</b>	Classroom sink, room 131, right sink	<1.0	µg/L
<b>195-132-SK-90</b>	Classroom sink, room 132, left sink	<1.0	µg/L
<b>195-132-SK-91</b>	Classroom sink, room 132, right sink	<1.0	µg/L
<b>195-133-SK-92</b>	Classroom sink, room 133	<1.0	µg/L
<b>195-136-SK-93</b>	Classroom sink, room 136	<1.0	µg/L
<b>195-137-SK-94</b>	Classroom sink, room 137	<1.0	µg/L
<b>195-138-SK-95</b>	Classroom sink, room 138	<1.0	µg/L
<b>195-140-SK-96</b>	Classroom sink, room 140	<1.0	µg/L
<b>195-142-SK-97</b>	Classroom sink, room 142	<1.0	µg/L
<b>195-143-SK-98</b>	Classroom sink, room 143	<1.0	µg/L
<b>195-144-SK-99</b>	Classroom sink, room 144	<1.0	µg/L
<b>195-145-SK-100</b>	Classroom sink, room 145, left sink	1.0	µg/L
<b>195-145-SK-101</b>	Classroom sink, room 145, right sink	<1.0	µg/L
<b>195-202B-SK-102</b>	LMC/IMC office sink, room 202B	<1.0	µg/L
<b>195-104-SK-103</b>	Classroom sink, room 104	<1.0	µg/L

\*1. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.

\*2. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.