

Omar D. Blair Elementary (196)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/6/2016				
Sample ID	Sample Description	Lead Result	Units	Action
196-123C-SK-01	Sink, left faucet, room 123C	0.6	µg/L	
196-123C-SK-02	Sink, right faucet, room 123C	0.5	µg/L	
196-124-SK-03	Kitchen sink, room 124, west wall	0.3	µg/L	
196-124-SK-04	Kitchen sink, room 124, south end	0.9	µg/L	
196-124-SK-05	Kitchen sprayer, room 124	0.4	µg/L	
196-124-SK-06	Kitchen kettle fill, room 124	0.3	µg/L	
196-123D-SK-07	PTA kitchen sink, room 123D	2.2	µg/L	
196-122-DF-08	Drinking fountain, next to stage/room 122	0.1	µg/L	
196-121-SK-09	Classroom sink, room 121	1.1	µg/L	
196-119-SK-10	Classroom sink, room 119	0.3	µg/L	
196-119-SK-11	Drinking fountain, room 119, left bubbler	<0.1* ¹	µg/L	
196-119-DF-12	Drinking fountain, room 119, right bubbler	<0.1	µg/L	
196-125-DF-13	Drinking fountain, hallway 125, across from room 125G, left bubbler	<0.1	µg/L	
196-125-DF-14	Drinking fountain, hallway 125, across from room 125G, right bubbler	<0.1	µg/L	
196-117-SK-15	Classroom sink, room 117, on north wall, left fixture	1.0	µg/L	
196-137-DF-16	Drinking fountain, hallway 137, next to room 138, left bubbler	<0.1	µg/L	
196-137-DF-17	Drinking fountain, hallway 137, next to room 138, right bubbler	<0.1	µg/L	
196-147-SK-18	Classroom sink, room 147	1.8	µg/L	
196-140-SK-19	Classroom sink, room 140	0.4	µg/L	
196-112-DF-20	Drinking fountain, room 112	<0.1	µg/L	
196-112-SK-21	Classroom sink, room 112, south wall	0.8	µg/L	
196-111-SK-22	Classroom sink, room 111 north wall	0.9	µg/L	
196-111-DF-23	Drinking fountain, room 111	<0.1	µg/L	
196-110-SK-24	Classroom sink, room 110, north wall	0.6	µg/L	
196-149-DF-25	Drinking fountain, hallway 149, next to room 150, left bubbler	<0.1	µg/L	
196-149-DF-26	Drinking fountain, hallway 149, next to room 150, right bubbler	<0.1	µg/L	
196-150-SK-27	Classroom sink, room 150, on west wall, left sink	1.4	µg/L	
196-150-SK-28	Classroom sink, room 150, on west wall, right sink	0.3	µg/L	
196-153-SK-29	Classroom sink, room 153, on east wall, left sink	0.5	µg/L	
196-153-SK-30	Classroom sink, room 153, on east wall, right sink	0.5	µg/L	
196-156-SK-31	Classroom sink, room 156, east wall, right sink	0.5	µg/L	
196-157-SK-32	Classroom sink, room 157, west wall, left sink	0.4	µg/L	
196-157-SK-33	Classroom sink, room 157, west wall, right sink	0.4	µg/L	

196-159-SK-34	Classroom sink, room 159, west wall, left sink	0.4	µg/L
196-159-SK-35	Classroom sink, room 159, west wall, right sink	0.4	µg/L
196-107-SK-36	Classroom sink, room 107	0.2	µg/L
196-100-DF-37	Drinking fountain, hallway 100, next to room 108, left bubbler	<0.1	µg/L
196-100-DF-38	Drinking fountain, hallway 100, next to room 108, right bubbler	<0.1	µg/L
196-101P-SK-39	Nurse sink, room 101P	0.2	µg/L
196-102-SK-40	Staff lounge sink, room 102	1.0	µg/L
Phase II Sampled on 4/25/2017			
196-122-SK-41	All-purpose stage sink, room 122	2.0	µg/L
196-116A-SK-42	Prep room sink, room 116A	6.0	µg/L
196-115A-SK-43	Prep room sink, room 115A	<1.0* ²	µg/L
196-113-SK-44	Classroom sink, room 113	<1.0	µg/L
196-138-SK-45	Classroom sink, room 138	<1.0	µg/L
196-139-SK-46	Classroom sink, room 139	<1.0	µg/L
196-141-SK-47	Classroom sink, room 141	<1.0	µg/L
196-144-SK-48	Classroom sink, room 144	<1.0	µg/L
196-145-SK-49	Classroom sink, room 145	<1.0	µg/L
196-146-SK-50	Classroom sink, room 146	<1.0	µg/L
196-112-SK-51	Classroom sink, room 112, next to restrooms, left sink	<1.0	µg/L
196-112-SK-52	Classroom sink, room 112, next to restrooms, right sink	<1.0	µg/L
196-110-SK-53	Classroom sink, room 110, next to restrooms, left sink	<1.0	µg/L
196-110-SK-54	Classroom sink, room 110, next to restrooms, right sink	<1.0	µg/L
196-110-SK-55	Classroom sink, room 110, south wall	<1.0	µg/L
196-151-SK-56	Classroom sink, room 151, left sink	<1.0	µg/L
196-151-SK-57	Classroom sink, room 151, right sink	<1.0	µg/L
196-152-SK-58	Classroom sink, room 152, left sink	1.0	µg/L
196-152-SK-59	Classroom sink, room 152, right sink	<1.0	µg/L
196-156-SK-60	Classroom sink, room 156, left sink	<1.0	µg/L
196-158-SK-61	Classroom sink, room 158, left sink	<1.0	µg/L
196-158-SK-62	Classroom sink, room 158, right sink	<1.0	µg/L
196-108-SK-63	Classroom sink, room 108	<1.0	µg/L
196-148-SK-64	Classroom sink, room 148	<1.0	µg/L
196-120-SK-65	Classroom sink, room 120, north counter, far left sink	<1.0	µg/L
196-120-SK-66	Classroom sink, room 120, north counter, center left sink	<1.0	µg/L
196-120-SK-67	Classroom sink, room 120, north counter, center right sink	<1.0	µg/L
196-120-SK-68	Classroom sink, room 120, north counter, far right sink	<1.0	µg/L
196-120-SK-69	Classroom sink, room 120, wall mounted, northeast corner	<1.0	µg/L

*1. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.

*2. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.