

Howell Elementary (197)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/7/2016				
Sample ID	Sample Description	Lead Result	Units	Action
197-109A-SK-01	Kitchen prep sink, south end of kitchen	0.4	µg/L	
197-109A-SK-02	Kitchen prep sink, north end of kitchen	0.9	µg/L	
197-111-DF-03	Drinking fountain, gymnasium, north wall, on left	<0.1* ¹	µg/L	
197-111-DF-04	Drinking fountain, gymnasium, north wall, on right	<0.1	µg/L	
197-110-SK-05	Classroom sink, room 110	0.5	µg/L	
197-107-DF-06	Drinking fountain, hallway 107, next to room 112A, left bubbler	<0.1	µg/L	
197-107-DF-07	Drinking fountain, hallway 107, next to room 112A, right bubbler	<0.1	µg/L	
197-112-SK-08	Classroom sink, room 112	0.7	µg/L	
197-101L-SK-09	Staff lounge sink, room 101L	0.3	µg/L	
197-101P-SK-10	Nurse sink, room 101P, south wall	0.7	µg/L	
197-101P-SK-11	Nurse sink, room 101P, east wall	0.7	µg/L	
197-118B-SK-12	LMC sink, room 118B	0.8	µg/L	
197-100-DF-13	Drinking fountain, hallway 100, across from room 118C, left bubbler	<0.1	µg/L	
197-100-DF-14	Drinking fountain, hallway 100, across from room 118C, right bubbler	<0.1	µg/L	
197-121-SK-15	Classroom sink, room 121	0.4	µg/L	
197-127-DF-16	Drinking fountain, hallway 127, next to room 128, left bubbler	<0.1	µg/L	
197-127-DF-17	Drinking fountain, hallway 127, next to room 128, right bubbler	<0.1	µg/L	
197-129A-DF-18	Drinking fountain, hallway 129A, between rooms 129 and 130	<0.1	µg/L	
197-135-DF-19	Drinking fountain, room 135	<0.1	µg/L	
197-136-DF-20	Drinking fountain, room 136	<0.1	µg/L	
197-134-DF-21	Drinking fountain, room 134	0.1	µg/L	
197-133-DF-22	Drinking fountain, room 133	<0.1	µg/L	
197-131A-DF-23	Drinking fountain, hallway 131A, between rooms 131 and 132	<0.1	µg/L	
197-219-DF-24	Drinking fountain, hallway 219, next to room 220, left bubbler	<0.1	µg/L	
197-219-DF-25	Drinking fountain, hallway 219, next to room 220, right bubbler	<0.1	µg/L	
197-218-SK-26	Classroom sink, room 218	0.4	µg/L	
197-200-DF-27	Drinking fountain, hallway 200, next to room 215, left bubbler	<0.1	µg/L	
197-200-DF-28	Drinking fountain, hallway 200, next to room 215, right bubbler	<0.1	µg/L	
197-208-DF-29	Drinking fountain, hallway 208, across from room 207, left bubbler	<0.1	µg/L	
197-208-DF-30	Drinking fountain, hallway 208, across from room 207, right bubbler	<0.1	µg/L	
Phase II Sampled on 5/5/2017				
197-114-SK-31	Classroom sink, room 114	<1.0* ²	µg/L	

197-115-SK-32	Classroom sink, room 115	1.0 µg/L
197-105-SK-33	Classroom sink, room 105	<1.0 µg/L
197-104-SK-34	Classroom sink, room 104	<1.0 µg/L
197-103-SK-35	Classroom sink, room 103	<1.0 µg/L
197-116-SK-36	Classroom sink, room 116	<1.0 µg/L
197-117-SK-37	Classroom sink, room 117	<1.0 µg/L
197-120-SK-38	Classroom sink, room 120	<1.0 µg/L
197-140-SK-39	Classroom sink, room 140, left sink	2.0 µg/L
197-140-SK-40	Classroom sink, room 140, right sink	<1.0 µg/L
197-139-SK-41	Classroom sink, room 139, left sink	<1.0 µg/L
197-139-SK-42	Classroom sink, room 139, right sink	1.0 µg/L
197-138-SK-43	Classroom sink, room 138, left sink	1.0 µg/L
197-138-SK-44	Classroom sink, room 138, right sink	<1.0 µg/L
197-122-SK-45	Classroom sink, room 122	<1.0 µg/L
197-123-SK-46	Classroom sink, room 123, right sink	<1.0 µg/L
197-123-SK-47	Classroom sink, room 123, left sink	4.0 µg/L
197-124-SK-48	Classroom sink, room 124, left sink	<1.0 µg/L
197-124-SK-49	Classroom sink, room 124, right sink	1.0 µg/L
197-125-SK-50	Classroom sink, room 125, left sink	3.0 µg/L
197-125-SK-51	Classroom sink, room 125, right sink	<1.0 µg/L
197-129-SK-52	Classroom sink, room 129, left sink	1.0 µg/L
197-129-SK-53	Classroom sink, room 129, right sink	<1.0 µg/L
197-129-SK-54	Classroom sink, room 129, hand wash sink	<1.0 µg/L
197-130-SK-55	Classroom sink, room 130, left sink	4.0 µg/L
197-130-SK-56	Classroom sink, room 130, right sink	<1.0 µg/L
197-130-SK-57	Classroom sink, room 130, hand wash sink	<1.0 µg/L
197-136-SK-58	Classroom sink, room 136, left sink	2.0 µg/L
197-136-SK-59	Classroom sink, room 136, right sink	<1.0 µg/L
197-136-SK-60	Classroom sink, room 136, hand wash sink, on left	<1.0 µg/L
197-136-SK-61	Classroom sink, room 136, hand wash sink, on right	<1.0 µg/L
197-135-SK-62	Classroom sink, room 135, left sink	<1.0 µg/L
197-135-SK-63	Classroom sink, room 135, right sink	<1.0 µg/L
197-135-SK-64	Classroom sink, room 135, hand wash sink, on left	<1.0 µg/L
197-135-SK-65	Classroom sink, room 135, hand wash sink, on right	<1.0 µg/L
197-131-SK-66	Classroom sink, room 131, left sink, lower counter	2.0 µg/L
197-131-SK-67	Classroom sink, room 131, right sink, upper counter	<1.0 µg/L
197-131-SK-68	Classroom sink, room 131, left sink, upper counter	<1.0 µg/L
197-132-SK-69	Classroom sink, room 131, right sink, lower counter	1.0 µg/L
197-132-SK-70	Classroom sink, room 132	<1.0 µg/L
197-132-SK-71	Classroom sink, room 132, hand wash sink	<1.0 µg/L
197-133-SK-72	Classroom sink, room 133, left sink, lower counter	<1.0 µg/L
197-133-SK-73	Classroom sink, room 133, right sink, upper counter	1.0 µg/L
197-133-SK-74	Classroom sink, room 133, left hand wash sink	<1.0 µg/L

197-133-SK-75	Classroom sink, room 133, right hand wash sink	<1.0	µg/L
197-134-SK-76	Classroom sink, room 134, left sink, upper counter	1.0	µg/L
197-134-SK-77	Classroom sink, room 134, right sink, lower counter	<1.0	µg/L
197-134-SK-78	Classroom sink, room 134, left hand wash sink	<1.0	µg/L
197-134-SK-79	Classroom sink, room 134, right hand wash sink	<1.0	µg/L
197-217-SK-80	Classroom sink, room 217, west wall, sink on far left	<1.0	µg/L
197-217-SK-81	Classroom sink, room 217, west wall, center left sink	<1.0	µg/L
197-216-SK-82	Classroom sink, room 216	<1.0	µg/L

*1. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.

*2. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.