

SECTION 10 26 13

CORNER GUARDS

PART 1 GENERAL No Requirements

PART 2 PRODUCTS

2.01 MATERIALS

- A. Galvanized sheet steel:
 - 1. Galvanized sheet metal phosphatized for field painting.
 - 2. Minimum 18 gauge.
 - 3. 'C' style with 2 1/2" x 2 1/2 " legs with beveled edges.
 - 4. Field paint: Prime front of wall surface and back of guard before attachment to wall.
- B. Stainless steel (Required in Kitchen):
 - 1. Type 304 alloy, minimum 16 gauge.
 - 2. Type 430 alloy, factory standard embossed pattern, minimum 16 gauge.
 - 3. #4 Satin Finish.
- C. Fasteners:
 - 1. All fasteners to be non-corrosive and compatible with galvanized steel. All necessary fasteners to be supplied by the manufacturer.
 - 2. All components shall be isolated from dissimilar metals as recommended by the manufacturer and as approved by the architect.
 - 3. Use heavy-duty adhesive on concrete block units.
 - 4. Provide Philips oval head, size 10 screws, or tamperproof screws.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Screw into drywall every 12 inches O.C. starting 2 inches from the bottom.

END OF SECTION 10 26 13