

SECTION 32 14 00

BRICK UNIT PAVING

PART 1 GENERAL

1.01 DELIVERY, STORAGE & HANDLING

- A. General: Comply with Division 1 Product Requirement Section.
- B. Comply with manufacturer's ordering instructions and lead-time requirements to avoid construction delays.
- C. Delivery: Deliver materials in manufacturer's original, unopened, undamaged containers packaging with identification labels intact.

PART 2 EXECUTION

2.01 MATERIALS

- A. Masonry paving shall not be used to construct "tree rings" or other site features where adjacent features can be expected to change or significantly settle over time.
- B. At a minimum, masonry paving shall be set on a 1" sand base set over 5" of compacted aggregate, set on compacted subgrade. However, manufacturer's recommendations will govern bedding requirements. Setting methods must be approved by A/E and DPS.
- C. Concrete bed:
 - 1. Design concrete bed with ¾" minimum width expansion joints spaced no further than 15 feet on center in each direction.
 - 2. Slab reinforcing shall be as that required for exterior concrete paving for the site.
 - 3. Refer to Section 32 13 13 – Concrete Paving for standards.
- D. Edging Material shall be so constructed that it will be permanent and shall withstand normal use, weathering and environmental conditions. Acceptable edging materials include:
 - 1. Steel edging.
 - 2. Concrete edging.

END OF SECTION 32 14 00