

FIRE PROTECTION SYSTEMS GENERAL NOTES:

1. ANY WORK DONE ON FIRE PROTECTION SUPPRESSION SYSTEMS SHALL BE BY A QUALIFIED AND OWNER APPROVED FIRE SUPPRESSION CONTRACTOR WITH A MINIMUM 5 YEARS EXPERIENCE.
2. PROVIDE TESTING AND REPORT ON ALL BACKFLOW PREVENTER DEVICES IN ACCORDANCE WITH DENVER WATER REQUIREMENTS AND THE COLORADO CROSS CONNECTION CONTROL MANUAL (LATEST ADDITION) REQUIREMENTS. ATTACH TESTING APPROVAL TAG TO ALL BACKFLOW PREVENTERS.
3. ALL FIRE PROTECTION WORK SHALL BE IN ACCORDANCE WITH NFPA, DENVER BUILDING DEPARTMENT, UL COMPLIANCE, FACTORY MUTUAL, UNIFORM FIRE CODE, NATIONAL ELECTRICAL CODE (NEC), THE COLORADO CROSS CONNECTION CONTROL MANUAL REQUIREMENTS AND ALL OTHER APPLICABLE CODES. FIRE PROTECTION WATER MAINS SHALL ALSO COMPLY WITH DENVER WATER DEPARTMENT.
4. PROVIDE 36" CLEAR ACCESS SPACE TO BACKFLOW PREVENTER TEST COCKS.

DENVER PUBLIC SCHOOLS DEPARTMENT OF FACILITIES MANAGEMENT		
DRAWN: DPS	BACKFLOW PREVENTER STANDARDS	
CHECKED: DPS	DOUBLE CHECK VALVE BFP	
APPROVED: DPS	GENERAL NOTES	
DATE: 11/20/03		
SCALE: NONE		
DWG. NO.	REV.	SHEET:
15432-FP03	0	3 / 3 OF: