

## Ana Marie Sandoval Elementary (201)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/5/2016

| Sample ID      | Sample Description   | Lead Result        | Units | Action |
|----------------|--|--------------------|-------|--------|
| 201-100-DF-01  | Drinking fountain, all purpose room 100, left bubbler                | 1.2                | µg/L  |        |
| 201-100-DF-02  | Bottle fill station, all purpose room 100                            | <1.0* <sup>1</sup> | µg/L  |        |
| 201-100-DF-03  | Drinking fountain, all purpose room 100, right bubbler               | <1.0               | µg/L  |        |
| 201-104-SK-04  | Kitchen prep sink, room 104  | <1.0               | µg/L  |        |
| 201-104-SK-05  | Kitchen prep sprayer, room 104                                       | 1.7                | µg/L  |        |
| 201-105-DF-06  | Drinking fountain, hallway 105, across from restrooms, left bubbler  | <1.0               | µg/L  |        |
| 201-105-DF-07  | Drinking fountain, hallway 105, across from restrooms, right bubbler | <1.0               | µg/L  |        |
| 201-114-SK-08  | Nurse sink, room 114   | <1.0               | µg/L  |        |
| 201-120H-SK-09 | Staff lounge sink, room, 120H  | 1.3                | µg/L  |        |
| 201-120B-SK-10 | Main office sink, room 120B  | <1.0               | µg/L  |        |
| 201-145-DF-11  | Drinking fountain, hallway 145, between rooms 141 and 143            | <1.0               | µg/L  |        |
| 201-151-DF-12  | Drinking fountain, hallway 151, between rooms 147 and 149            | <1.0               | µg/L  |        |
| 201-153-DF-13  | Drinking fountain, room 153  | <1.0               | µg/L  |        |
| 201-130-DF-14  | Drinking fountain, hallway 130, between rooms 126 and 128            | 2.0                | µg/L  |        |
| 201-135-DF-15  | Drinking fountain, hallway 135, south end, next to room 141          | <1.0               | µg/L  |        |
| 201-135-DF-16  | Drinking fountain, hallway 135, north end, next to room 140          | <1.0               | µg/L  |        |
| 201-144-DF-17  | Drinking fountain, hallway 144, between rooms 142 and 146            | <1.0               | µg/L  |        |
| 201-150-DF-18  | Drinking fountain, hallway 150, between rooms 146 and 148            | <1.0               | µg/L  |        |
| 201-152-DF-19  | Drinking fountain, room 152  | <1.0               | µg/L  |        |
| 201-235-DF-20  | Drinking fountain, hallway 235, north end, next to room 240          | <1.0               | µg/L  |        |
| 201-235-DF-21  | Drinking fountain, hallway 235, south end, next to room 241          | <1.0               | µg/L  |        |
| 201-236-SK-22  | Staff lounge sink, room 236  | <1.0               | µg/L  |        |

### Phase II Sampled on 4/25/2017

|               |  |      |      |  |
|---------------|--|------|------|--|
| 201-130-SK-23 | Sink, hallway 130, between rooms 126 and 128, left sink  | 1.0  | µg/L |  |
| 201-130-SK-24 | Sink, hallway 130, between rooms 126 and 128, right sink | <1.0 | µg/L |  |
| 201-145-SK-25 | Sink, hallway 145, between rooms 141 and 143, right sink | <1.0 | µg/L |  |
| 201-145-SK-26 | Sink, hallway 145, between rooms 141 and 143, left sink  | <1.0 | µg/L |  |
| 201-151-SK-27 | Sink, hallway 151, between rooms 147 and 149, right sink | <1.0 | µg/L |  |
| 201-151-SK-28 | Sink, hallway 151, between rooms 147 and 149, left sink  | <1.0 | µg/L |  |
| 201-155-SK-29 | Sink, room 155, next to classroom 153                    | <1.0 | µg/L |  |
| 201-154-SK-30 | Sink, room 154, next to classroom 152                    | <1.0 | µg/L |  |
| 201-150-SK-31 | Sink, hallway 150, between rooms 146 and 148, right sink | <1.0 | µg/L |  |

|                       |  |      |      |
|-----------------------|--|------|------|
| <b>201-150-SK-32</b>  | Sink, hallway 150, between rooms 146 and 148, left sink  | <1.0 | µg/L |
| <b>201-144-SK-33</b>  | Sink, hallway 144, between rooms 140 and 142, right sink | <1.0 | µg/L |
| <b>201-144-SK-34</b>  | Sink, hallway 144, between rooms 140 and 142, left sink  | <1.0 | µg/L |
| <b>201-245-SK-35</b>  | Sink, room 245, next to classroom 243, left sink         | <1.0 | µg/L |
| <b>201-245-SK-36</b>  | Sink, room 245, next to classroom 243, right sink        | 1.0  | µg/L |
| <b>201-251-SK-37</b>  | Sink, hallway 251, between rooms 247 and 249, right sink | <1.0 | µg/L |
| <b>201-251-SK-38</b>  | Sink, hallway 251, between rooms 247 and 249, left sink  | <1.0 | µg/L |
| <b>201-255-SK-39</b>  | Sink, room 255, next to classroom 253                    | <1.0 | µg/L |
| <b>201-254-SK-40</b>  | Sink, room 254, next to classroom 252                    | 1.0  | µg/L |
| <b>201-250-SK-41</b>  | Sink, hallway 250, between rooms 246 and 248, right sink | <1.0 | µg/L |
| <b>201-250-SK-42</b>  | Sink, hallway 250, between rooms 246 and 248, left sink  | <1.0 | µg/L |
| <b>201-242-SK-43</b>  | Sink, room 242, left sink                                | <1.0 | µg/L |
| <b>201-242-SK-44</b>  | Sink, room 242, right sink                               | <1.0 | µg/L |
| <b>201-136A-SK-45</b> | LMC/IMC office sink, room 136A                           | 2.0  | µg/L |

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.