

## Asbury Elementary (203)

*July 2017: All issues addressed, results below action level, no further actions at this time.*

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/25/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
203-003-SK-01	Kitchen sink, south	5.9		µg/L	
203-003-SK-02	Kitchen sink, north	1.4		µg/L	
203-100-DF-03	Drinking fountain, hallway 100, near room 113, left bubbler	2.6		µg/L	
203-100-DF-04	Drinking fountain, hallway 100, near room 113, right bubbler	2.0		µg/L	
203-109-DF-05	Drinking fountain, gym, left	<1.0* <sup>1</sup>		µg/L	
203-109-DF-06	Drinking fountain, gym, right	<1.0		µg/L	
203-100-DF-07	Drinking fountain, hallway 100, near room 101, left bubbler	1.5		µg/L	
203-100-DF-08	Drinking fountain, hallway 100, near room 101, right bubbler	3.1		µg/L	
203-106-DF-09	Drinking fountain, hallway 106, near room 105, left bubbler	3.6		µg/L	
203-106-DF-10	Drinking fountain, hallway 106, near room 105, right bubbler	4.4		µg/L	
203-106B-SK-11	Lounge sink, room 106B	1.9		µg/L	
203-105-DF-12	Drinking fountain, room 105	23.6	N/A	µg/L	Removed July 2017
203-207-DF-13	Drinking fountain, hallway 207, near room 204, left bubbler	8.5		µg/L	
203-207-DF-14	Drinking fountain, hallway 207, near room 204, right bubbler	6.2		µg/L	
203-200-DF-15	Drinking fountain, hallway 200, near room 201, left bubbler	3.2		µg/L	
203-200-DF-16	Drinking fountain, hallway 200, near room 201, right bubbler	1.3		µg/L	
203-200-DF-17	Drinking fountain, hallway 200, near room 213, left bubbler	1.1		µg/L	
203-200-DF-18	Drinking fountain, hallway 200, near room 213, right bubbler	<1.0		µg/L	
Phase II Sampled on 2/1/2017					
203-104-SK-19	Classroom sink, room 104	4.6		µg/L	
203-103-SK-20	Classroom sink, room 103	5.7		µg/L	
203-104-SK-21	Classroom sink, room 102	6.2		µg/L	
203-101-SK-22	Classroom sink, room 101	8.9		µg/L	
203-100FA-SK-23	Nurse sink, room 100FA	6.5		µg/L	
203-113-SK-24	Classroom sink, room 113	11.0		µg/L	
203-112-SK-25	Classroom sink, room 112	5.2		µg/L	
203-111-SK-26	Classroom sink, room 111	7.5		µg/L	

<b>203-211-SK-27</b>	Classroom sink, room 211	7.2		µg/L	
<b>203-212-SK-28</b>	Classroom sink, room 212	8.7		µg/L	
<b>203-213-SK-29</b>	Classroom sink, room 213	13.0		µg/L	
<b>203-202-SK-30</b>	LMC/IMC office sink, room 202	46.0	9.0* <sup>2</sup>	µg/L	Faucet replaced July 2017
<b>203-204-SK-31</b>	Classroom sink, room 204	1.8		µg/L	
<b>203-205-SK-32</b>	Classroom sink, room 205	3.0		µg/L	
<b>203-206-SK-33</b>	Classroom sink, room 206	2.6		µg/L	
<b>203-106-DF-35</b>	Drinking fountain, hallway 106, near 106B, replaces 203-105-DF-12		<2.0* <sup>2</sup>	µg/L	Installed July 2017
<b>203-106-BF-36</b>	Bottle fill station, hallway 106, near 106B, replaces 203-105-DF-12		<2.0* <sup>2</sup>	µg/L	Installed July 2017

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*2. Follow up samples collected on 8/29/2017 and tested with a Palintest SA1100 scanning analyzer.