

RMSEL at Ash Grove Elementary (204) – Sampled 9/13/16 & 2/23/17

All results at 15 ppb or below – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/13/2016			
Sample ID	Sample Description	Lead Result	Units
204-123-DF-01	Drinking fountain, hallway 123, next to school office	<1.0* ¹	µg/L
204-123-DF-02	Drinking fountain, hallway 123, next to 107	1.8	µg/L
204-200-DF-03	Drinking fountain, hallway 200, next to 207	3.4	µg/L
204-200-DF-04	Drinking fountain, hallway 200, next to 212	<1.0	µg/L
204-110A-SK-05	Sink, office 110A	1.4	µg/L
204-122-DF-06	Drinking fountain, gym, south wall	2.4	µg/L
204-122-DF-07	Drinking fountain, gym, north wall	2.3	µg/L
204-118-SK-08	Sink, all purpose room 118	2.3	µg/L
Phase II Sampled on 2/23/2017			
204-002-SK-09	Custodial office sink, room 002	14.1	µg/L
204-101E-SK-10	Admin office sink, room 101E	1.4	µg/L
204-103-SK-11	Classroom sink, room 103	2.2	µg/L
204-104-SK-12	Classroom sink, room 104	1.6	µg/L
204-105-SK-13	Classroom sink, room 105	2.5	µg/L
204-106-SK-14	Classroom sink, room 106, sink on left	2.3	µg/L
204-106-SK-15	Classroom sink, room 106, sink on right	1.2	µg/L
204-107-SK-16	Classroom sink, room 107, sink on left	2.7	µg/L
204-107-SK-17	Classroom sink, room 107, sink on right	1.3	µg/L
204-108-SK-18	LMC/IMC sink, room 108	2.7	µg/L
204-108A-SK-19	LMC/IMC office sink, room 108A	3.1	µg/L
204-110C-SK-20	Gymnasium office sink, room 110C	3.5	µg/L
204-112-SK-21	All purpose room sink, room 112	0.7	µg/L
204-114-SK-22	Classroom sink, room 114	0.7	µg/L
204-115-SK-23	Classroom sink, room 115	0.6	µg/L
204-116-SK-24	Classroom sink, room 116	1.6	µg/L
204-201-SK-25	Classroom sink, room 201	2.6	µg/L
204-202-SK-26	Classroom sink, room 202	1.8	µg/L
204-203-SK-27	Classroom sink, room 203	2.7	µg/L
204-204-SK-28	Classroom sink, room 204	1.3	µg/L
204-205-SK-29	Classroom sink, room 205	3.4	µg/L
204-206-SK-30	Classroom sink, room 206	1.9	µg/L
204-207-SK-31	Classroom sink, room 207	1.8	µg/L
204-208-SK-32	Classroom sink, room 208, sink on left	1.5	µg/L
204-208-SK-33	Classroom sink, room 208, sink on right	0.7	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.