

Barrett – 2900 Richard Allen Ct. (208)

SY 2019/2020 Long Term Sampling – Action Level 10 µg/L

Sample Date: September 2019

Sample ID	Location Description	Lead Result (µg/L)	Action
208-KIT-SK01-01	Kitchen sink, left faucet	2.8	
208-KIT-SK02-01	Kitchen sink, right faucet	3.1	
208-H100-DF01-01	Drinking fountain, hallway H100, across from kitchen	34.3	Shut down, POU filter pending
208-H100-DF02-01	Drinking fountain, hallway H100, across from elevator	3.7	
208-OFFC-SK01-01	Nurse sink, room OFFC	4.2	
208-GYM-DF02-01	Drinking fountain, gymnasium, SW corner	<1.0 ¹	
208-GYM-DF01-01	Drinking fountain, gymnasium, SE corner	7.7	
208-H110-DF01-01	Drinking fountain, hallway H100, across from room 101	5.6	
208-H110-DF02-01	Drinking fountain, hallway H100, across from room 102	1.2	
208-107-DF01-01	Drinking fountain, room 107	6.6	
208-106-DF01-01	Drinking fountain, room 106	6.2	
208-H210-DF02-01	Drinking fountain, hallway H210, next to H210DA	6.1	
208-H210-DF01-01	Drinking fountain, hallway H210, next to H210D	5.9	

Sample ID Key:

Building number – room number – fixture type count – long term count

1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

Phase I & II Sampling – Action Level 15 µg/L

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/22/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
208-OFFC-SK-01	Admin office sink, room OFFC	2.7		µg/L	
208-H100-DF-02	Drinking fountain, hallway H100, left bubbler, next to kitchen	22.0	7.0	µg/L	Bubbler replaced 1/2018
208-H100-DF-03	Drinking fountain, hallway H100, right bubbler, next to kitchen	4.6	2.0	µg/L	Bubbler replaced 1/2018
208-H100-DF-04	Drinking fountain, hallway H100, left bubbler, across from stage	2.2		µg/L	
208-H100-DF-05	Drinking fountain, hallway H100, right bubbler, across from stage	1.1		µg/L	
208-GYM-DF-06	Drinking fountain, gymnasium, south east corner	2.1		µg/L	
208-GYM-DF-07	Drinking fountain, gymnasium, south west corner	<1.0* ¹		µg/L	
208-H110-DF-08	Drinking fountain, hallway H110, left bubbler, across from room 101	3.5		µg/L	
208-H110-DF-09	Drinking fountain, hallway H110, right bubbler, across from room 101	2.6		µg/L	
208-H110-DF-10	Drinking fountain, hallway H110, right bubbler, next to restrooms	<1.0		µg/L	
208-107-SK-11	Classroom sink, room 107	1.1		µg/L	
208-107-DF-12	Drinking fountain, room 107	4.6		µg/L	
208-H210-DF-13	Drinking fountain, hallway H210, left bubbler, next to restrooms	4.2		µg/L	
208-H210-DF-14	Drinking fountain, hallway H210, right bubbler, next to restrooms	2.7		µg/L	
208-H210-DF-15	Drinking fountain, hallway H210, left bubbler, across from LMC	6.5		µg/L	
208-H210-DF-16	Drinking fountain, hallway H210, right bubbler, across from LMC	5.4		µg/L	
208-KIT-SK-17	Kitchen prep sink	4.9		µg/L	

Phase II Sampled on 3/23/2017

208-101-SK-18	Classroom sink, room 101	2.0		µg/L	
208-102-SK-19	Classroom sink, room 102	4.0		µg/L	
208-103-SK-20	Classroom sink, room 103	3.0		µg/L	
208-H110E-SK-21	Faculty lounge sink, room H110E	3.0		µg/L	
208-104-SK-22	Classroom sink, room 104	3.0		µg/L	
208-106-DF-23	Drinking fountain, room 106	5.0		µg/L	
208-106-SK-24	Classroom sink, room 106	2.0		µg/L	
208-105-SK-25	Classroom sink, room 105	2.0		µg/L	
208-202-SK-26	Classroom sink, room 202	4.0		µg/L	

208-207-SK-27	Classroom sink, room 207	4.0	µg/L
208-206-SK-28	Classroom sink, room 206	2.0	µg/L
208-205-SK-29	Classroom sink, room 205	3.0	µg/L
208-204-SK-30	Classroom sink, room 204	2.0	µg/L
208-203-SK-31	Classroom sink, room 203	3.0	µg/L
208-201A-SK-32	LMC/IMC office sink, room 201A	5.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.