

**Bradley Elementary (213) – 3051 S. Elm St.**

***SY 2019/2020 Long Term Sampling – Action Level 10 µg/L***

***Sample Date: 1/22/2020***

<b>Sample ID</b>	<b>Description</b>	<b>Lead Result (µg/L)</b>	<b>Action</b>
<b>213-126-SK01-01</b>	Kitchen sink, west wall, left faucet	6.9	
<b>213-126-SK02-01</b>	Kitchen sink, west wall, right faucet	<1.0 <sup>1</sup>	
<b>213-126-SK03-01</b>	Kitchen prep sink, southwest wall	<1.0	
<b>213-124-DF01-01</b>	Drinking fountain , gym, north end near hall	1.4	
<b>213-124-DF02-01</b>	Drinking fountain , gym, south end near restrooms	2.0	
<b>213-127-DF01-01</b>	Drinking fountain, cafeteria	6.3	
<b>213-101D-SK01-01</b>	Nurse sink, room 101D	<1.0	
<b>213-101F-SK01-01</b>	Office lounge sink, room 101F	2.8	
<b>213-100-BF01-01</b>	Bottle fill, high-low, hallway 100, next to room 120	<1.0	
<b>213-100-DF02-01</b>	Drinking fountain, hall 100, next to room 105	4.1	
<b>213-107A-DF01-01</b>	Drinking fountain, hall 107A, between rooms 107 and 108	13.7	Shut down, POU Filter pending
<b>213-100-DF01-01</b>	Drinking fountain, hall 100, next to room 114	4.5	
<b>213-110-DF01-01</b>	Drinking fountain, room 110	2.6	
<b>213-111-DF01-01</b>	Drinking fountain, room 111	4.4	
<b>213-112-DF01-01</b>	Drinking fountain, room 112	2.7	
<b>213-200-DF01-01</b>	Drinking fountain, hall 200, next to room 207	9.1	
<b>213-200-DF02-01</b>	Drinking fountain, hall 200, next to room 205	5.3	
<b>213-200-BF01-01</b>	Bottle fill station, hallway 200, next to stair A	<1.0	

**Sample ID Key:**

Building number – room number – fixture type count – long term count

1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

## Phase I & II Sampling – Action Level 15 µg/L

All results less than 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/9/16				
Sample ID	Sample Description	Lead Result	Units	Action
213-126-SK-01	Kitchen sink, west wall, left faucet	4.3	µg/L	
213-126-SK-02	Kitchen sink, west wall, right faucet	5.3	µg/L	
213-126-SK-03	Kitchen sink, southwest wall	<1.0* <sup>1</sup>	µg/L	
213-127-DF-04	Drinking fountain, cafeteria, left bubbler	5.5	µg/L	
213-127-DF-05	Drinking fountain, cafeteria, right bubbler	8.6	µg/L	
213-124-DF-06	Drinking fountain , gym, north end near hall	1.4	µg/L	
213-124-DF-07	Drinking fountain , gym, south end near rest rooms	1.5	µg/L	
213-1010-SK-08	Nurse sink, room 101D	1.4	µg/L	
213-101F-SK-09	Office sink, room 101F	2.1	µg/L	
213-100-DF-10	Drinking fountain, hall 100, next to room 120, left bubbler	7	µg/L	
213-100-DF-11	Drinking fountain, hall 100, next to room 120, right bubbler	4.8	µg/L	
213-119-SK-12	Classroom sink, room 119	9.2	µg/L	
213-100-DF-13	Drinking fountain, hall 100, next to room 105, left bubbler	3.6	µg/L	
213-100-DF-14	Drinking fountain, hall 100, next to room 105, right bubbler	2.7	µg/L	
213-107A-DF-15	Drinking fountain, hall 107A, between rooms 107 and 108, left bubbler	8.8	µg/L	
213-107A-DF-16	Drinking fountain, hall 107A, between rooms 107 and 108, right bubbler	6.5	µg/L	
213-100-DF-17	Drinking fountain, hall 100, next to room 114, left bubbler	2.9	µg/L	
213-100-DF-18	Drinking fountain, hall 100, next to room 114, right bubbler	1.4	µg/L	
213-110-DF-19	Drinking fountain, room 110	2.4	µg/L	
213-111-DF-20	Drinking fountain, room 111	3.4	µg/L	
213-112-DF-21	Drinking fountain, room 112	2.6	µg/L	
213-112-SK-22	Classroom sink, room 112	7.8	µg/L	
213-200-DF-23	Drinking fountain, hall 200, next to room 207, left bubbler	6.4	µg/L	
213-200-DF-24	Drinking fountain, hall 200, next to room 207, right bubbler	2.4	µg/L	
213-200-DF-25	Drinking fountain, hall 200, next to room 205, left bubbler	4.2	µg/L	
213-200-DF-26	Drinking fountain, hall 200, next to room 205, right bubbler	2.3	µg/L	
213-200-DF-27	Drinking fountain, hall 200, next to room 201, left bubbler	4.3	µg/L	
213-200-DF-28	Drinking fountain, hall 200, next to room 201, right bubbler	4.4	µg/L	
213-201-SK-29	LMC sink, room 201	13.2	µg/L	

<b>213-102-SK-30</b>	Classroom sink, room 102	4.6	µg/L
----------------------	--------------------------	-----	------

<b>Phase II Sampled on 3/2/17</b>			
-----------------------------------	--	--	--

<b>213-120-SK-31</b>	Classroom sink, room 120	10.0	µg/L
<b>213-103-SK-32</b>	Classroom sink, room 103	6.0	µg/L
<b>213-118-SK-33</b>	Classroom sink, room 118	9.0	µg/L
<b>213-104-SK-34</b>	Classroom sink, room 104	8.0	µg/L
<b>213-105-SK-35</b>	Classroom sink, room 105	4.0	µg/L
<b>213-106-SK-36</b>	Classroom sink, room 106	3.0	µg/L
<b>213-107-SK-37</b>	Classroom sink, room 107	4.0	µg/L
<b>213-108-SK-38</b>	Classroom sink, room 108	3.0	µg/L
<b>213-117-SK-39</b>	Classroom sink, room 117	3.0	µg/L
<b>213-116-SK-40</b>	Classroom sink, room 116	4.0	µg/L
<b>213-114-SK-41</b>	Classroom sink, room 114	5.0	µg/L
<b>213-115-SK-42</b>	Classroom sink, room 115	14.0	µg/L
<b>213-110-SK-43</b>	Classroom sink, room 110	4.0	µg/L
<b>213-111-SK-44</b>	Classroom sink, room 111	4.0	µg/L
<b>213-209-SK-45</b>	Classroom sink, room 209	3.0	µg/L
<b>213-213-SK-46</b>	Classroom sink, room 213	1.0	µg/L
<b>213-207-SK-47</b>	Classroom sink, room 207	9.0	µg/L
<b>213-214-SK-48</b>	Classroom sink, room 214	2.0	µg/L
<b>213-206-SK-49</b>	Classroom sink, room 206	3.0	µg/L
<b>213-205-SK-50</b>	Classroom sink, room 205	2.0	µg/L
<b>213-215-SK-51</b>	Classroom sink, room 215	5.0	µg/L
<b>213-216-SK-52</b>	Classroom sink, room 216	10.0	µg/L
<b>213-204-SK-53</b>	Classroom sink, room 204	3.0	µg/L
<b>213-217-SK-54</b>	Classroom sink, room 217	3.0	µg/L
<b>213-203-SK-55</b>	Classroom sink, room 203	6.0	µg/L
<b>213-218-SK-56</b>	Classroom sink, room 218	7.0	µg/L
<b>213-201B-SK-57</b>	LMC / IMC office sink, room 201B	3.0	µg/L
<b>213-122A-SK-58</b>	Music room sink, room 122A	5.0	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.