

## Cheltenham Elementary (218)

All results less than 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/19/2016				
Sample ID	Sample Description	Lead Result	Units	Action
218-137B-SK-01	Kitchen sink, northeast wall, left faucet	1.5	µg/L	
218-137B-SK-02	Kitchen sink, northeast wall, right faucet	2.6	µg/L	
218-137-DF-03	Drinking fountain, cafeteria, next to kitchen	3.6	µg/L	
218-130-DF-04	Drinking fountain, hallway 130, across from room 129, left bubbler	2.2	µg/L	
218-130-DF-05	Drinking fountain, hallway 130, across from room 129, right bubbler	1.0	µg/L	
218-131-DF-06	Drinking fountain, hallway 131, next to room 135, left bubbler	<1.0*	µg/L	
218-131-DF-07	Drinking fountain, hallway 131, next to room 135, right bubbler	1.5	µg/L	
218-133-SK-08	Classroom sink, room 133, on south wall	<1.0	µg/L	
218-102-DF-09	Drinking fountain, hallway 102, next to boys restroom, left bubbler	<1.0	µg/L	
218-102-DF-10	Drinking fountain, hallway 102, next to boys restroom, right bubbler	<1.0	µg/L	
218-102-DF-11	Bottle fill station, hallway 102, next to boys restroom	<1.0	µg/L	
218-102-DF-12	Drinking fountain, hallway 102, next to girls restroom, left bubbler	<1.0	µg/L	
218-102-DF-13	Drinking fountain, hallway 102, next to girls restroom, right bubbler	<1.0	µg/L	
218-102-DF-14	Bottle fill station, hallway 102, next to girls restroom	<1.0	µg/L	
218-103-DF-15	Drinking fountain, hallway 103, next to main office, left bubbler	2.5	µg/L	
218-103-DF-16	Drinking fountain, hallway 103, next to main office, right bubbler	1.8	µg/L	
218-141-SK-17	Staff lounge sink, room 141	1.6	µg/L	
218-140-DF-18	Drinking fountain, hallway 140, next to restrooms, left bubbler	12.5	µg/L	
218-140-DF-19	Drinking fountain, hallway 140, next to restrooms, right bubbler	2.5	µg/L	
218-200-DF-20	Drinking fountain, hallway 200, next to room 201, left bubbler	1.0	µg/L	
218-200-DF-21	Drinking fountain, hallway 200, next to room 201, right bubbler	<1.0	µg/L	
218-203-SK-22	Classroom sink, room 203, on north wall	<1.0	µg/L	
218-204-SK-23	Classroom sink, room 204, on north wall	1.3	µg/L	
218-101D-SK-24	Main office sink, room 101D	<1.0	µg/L	

<b>218-142-DF-25</b>	Drinking fountain, room 142, on south wall	11.9	µg/L
<b>218-143-DF-26</b>	Drinking fountain, room 143, on north wall	11.5	µg/L
<b>Phase II Sampled on 4/5/2017</b>			
<b>218-138B-SK-27</b>	LMC/IMC office sink, room 138B	6.0	µg/L
<b>218-148-SK-28</b>	Classroom sink, room 148	6.0	µg/L
<b>218-147-SK-29</b>	Classroom sink, room 147	1.0	µg/L
<b>218-146-SK-30</b>	Classroom sink, room 146	6.0	µg/L
<b>218-145-SK-31</b>	Classroom sink, room 145	1.0	µg/L
<b>218-144-SK-32</b>	Classroom sink, room 144	<1.0	µg/L
<b>218-143-SK-33</b>	Classroom sink, room 143	<1.0	µg/L
<b>218-142-SK-34</b>	Classroom sink, room 142	<1.0	µg/L
<b>218-101F-SK-35</b>	Nurse sink, room 101F	2.0	µg/L
<b>218-107-SK-36</b>	Resource room sink, room 107	5.0	µg/L
<b>218-108-SK-37</b>	Classroom sink, room 108	4.0	µg/L
<b>218-110-SK-38</b>	Classroom sink, room 110	4.0	µg/L
<b>218-110A-SK-39</b>	Workroom sink, room 110A	2.0	µg/L
<b>218-106A-SK-40</b>	Faculty workroom sink, room 106A	3.0	µg/L
<b>218-106-SK-41</b>	Faculty workroom sink, room 106	5.0	µg/L
<b>218-116-SK-42</b>	Conference room sink, room 116	<1.0	µg/L
<b>218-115-SK-43</b>	Classroom sink, room 115	1.0	µg/L
<b>218-114-SK-44</b>	Classroom sink, room 114	1.0	µg/L
<b>218-112-SK-45</b>	Classroom sink, room 112	<1.0	µg/L
<b>218-123-SK-46</b>	Resource room sink, room 123	<1.0	µg/L
<b>218-122-SK-47</b>	Classroom sink, room 122	<1.0	µg/L
<b>218-121-SK-48</b>	Classroom sink, room 121	13.0	µg/L
<b>218-120-SK-49</b>	Classroom sink, room 120	<1.0	µg/L
<b>218-129-SK-50</b>	Classroom sink, room 129	<1.0	µg/L
<b>218-128-SK-51</b>	Classroom sink, room 128	<1.0	µg/L
<b>218-127-SK-52</b>	Classroom sink, room 127	<1.0	µg/L
<b>218-126-SK-53</b>	Classroom sink, room 126	<1.0	µg/L
<b>218-135-SK-54</b>	Classroom sink, room 135	2.0	µg/L
<b>218-134-SK-55</b>	Classroom sink, room 134	<1.0	µg/L
<b>218-132-SK-56</b>	Classroom sink, room 132	2.0	µg/L
<b>218-201-SK-57</b>	Classroom sink, room 201	<1.0	µg/L
<b>218-202-SK-58</b>	Classroom sink, room 202	<1.0	µg/L
<b>218-136-DF-59</b>	Drinking fountain, gymnasium	<1.0	µg/L
<b>218-004-SK-60</b>	Custodial office sink, room 004	4.0	µg/L

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.