

## Colfax Elementary (219)

All results below 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/25/2016				
Sample ID	Sample Description	Lead Result	Units	Action
219-108-sk-01	Kitchen sink, south wall	1.0	µg/L	
219-108-sk-02	Kitchen sink, north wall, prep	4.7	µg/L	
219-101c-sk-03	Nurse sink	1.4	µg/L	
219-109-df-04	Drinking fountain, Gym	<1.0* <sup>1</sup>	µg/L	
219-121c-sk-05	Sink, faculty lounge	1.3	µg/L	
219-100-df-06	Drinking fountain, hallway 100, left, by restrooms	<1.0	µg/L	
219-100-df-07	Drinking fountain, hallway 100, right, by restrooms	<1.0	µg/L	
219-100-df-08	Drinking fountain, hallway 100, left, by room 112	<1.0	µg/L	
219-100-df-09	Drinking fountain, hallway 100, right, by room 112	<1.0	µg/L	
219-115-df-10	Drinking fountain, room 115, left	2.4	µg/L	
219-115-df-11	Drinking fountain, room 115, right	1.8	µg/L	
219-114-df-12	Drinking fountain, room 114	<1.0	µg/L	
219-200-df-13	Drinking fountain, hallway 200, left	<1.0	µg/L	
219-200-df-14	Drinking fountain, hallway 200, right	<1.0	µg/L	
Phase II Sampled on 1/24/2017				
219-104-SK-15	Classroom sink, room 104, west wall	2.0	µg/L	
219-120-SK-16	Classroom sink, room 120	1.7	µg/L	
219-119-SK-17	Classroom sink, room 119	2.3	µg/L	
219-118-SK-18	Classroom sink, room 118	0.3	µg/L	
219-117-SK-19	Classroom sink, room 117	0.6	µg/L	
219-116-SK-20	Classroom sink, room 116	0.3	µg/L	
219-115-SK-21	Classroom sink, room 115	2.6	µg/L	
219-114-SK-22	Classroom sink, room 114	1.7	µg/L	
219-113-SK-23	Classroom sink, room 113	2.9	µg/L	
219-112-SK-24	Classroom sink, room 112	<0.1* <sup>2</sup>	µg/L	
219-111-SK-25	Classroom sink, room 111	0.8	µg/L	
219-110-SK-26	Classroom sink, room 110	2.2	µg/L	
219-207-SK-27	Classroom sink, room 207	0.4	µg/L	
219-206-SK-28	Classroom sink, room 206	1.2	µg/L	
219-205-SK-29	Classroom sink, room 205	1.	µg/L	
219-204-SK-30	Classroom sink, room 204	1.3	µg/L	
219-203-SK-31	Classroom sink, room 203	1.1	µg/L	
219-202-SK-32	Classroom sink, room 202	0.6	µg/L	
219-201-SK-33	Classroom sink, room 201	3.3	µg/L	

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

\*2. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.