

University Prep @ Crofton Elementary (225)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF – drinking fountain, SK – sink) – consecutive sample number

Phase I Sampled on 8/24/2016				
Sample ID	Sample Description	Lead Result	Units	Action
225-103-DF-01	Drinking fountain room 103	<1.0* ¹	µg/L	
225-102-DF-02	Drinking fountain room 102	<1.0	µg/L	
225-100-DF-03	Drinking fountain hallway 100	<1.0	µg/L	
225-109-DF-04	Drinking fountain hallway 109, left	<1.0	µg/L	
225-109-DF-5	Drinking fountain hallway 109, right	<1.0	µg/L	
225-300-DF-6	Drinking fountain hallway 300, right, next to room 301	1.3	µg/L	
225-300-DF-7	Drinking fountain hallway 300, right, next to room 302	<1.0	µg/L	
225-200-DF-8	Drinking fountain hallway 200, right, next to room 201	5.6	µg/L	
225-202-DF-9	Plumbed water cooler room 202	<1.0	µg/L	
225-200-DF-10	Drinking fountain hallway 200, right, next to room 202	2.8	µg/L	
225-201-DF-11	Plumbed water cooler room 201	<1.0	µg/L	
225-212-DF-12	Drinking fountain hallway 212, left	<1.0	µg/L	
225-212-DF-13	Drinking fountain hallway 212, right	<1.0	µg/L	
225-107-SK-14	Kitchen sink, west end	<1.0	µg/L	
225-107-SK-15	Kitchen sink middle on north wall	<1.0	µg/L	
225-107-SK-16	Kitchen spray	13.7	µg/L	
Phase II Sampled on 1/25/2017				
225-102-SK-17	Classroom sink, room 102	<0.1* ²	µg/L	
225-103-SK-18	Classroom sink, room 103	0.3	µg/L	
225-213-SK-19	Classroom sink, room 213, on right	<0.1	µg/L	
225-208-SK-20	Faculty lounge sink, room 208	3.3	µg/L	
225-200-SK-21	Sink, hallway 200, next to room 201	11.9	µg/L	
225-201-SK-22	Classroom sink, room 201	1.9	µg/L	
225-206-SK-23	Classroom sink, room 206	<0.1	µg/L	
225-205-SK-24	Classroom sink, room 205	0.2	µg/L	
225-203-SK-25	Classroom sink, room 203	0.1	µg/L	
225-303-SK-26	Classroom sink, room 303	0.8	µg/L	
225-302-SK-27	Classroom sink, room 302	0.2	µg/L	
225-305-SK-28	Classroom sink, room 305	2.5	µg/L	
225-301-SK-29	Classroom sink, room 301	0.1	µg/L	
225-306-SK-30	Classroom sink, room 306	0.2	µg/L	

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.