

Ellis Elementary (231) – 1651 S. Dahlia St.

SY 2019/2020 Long Term Sampling – Action Level 10 µg/L

Sample Date: 11/22/2019

Sample ID	Location Description	Lead Result (µg/L)
231-104A-SK01-01	Kitchen sink, left faucet	<1.0 ¹
231-104A-SK02-01	Kitchen sink, right faucet	1.8
231-104-DF01-01	Drinking fountain, cafeteria, east wall	1.9
231-104BC-SK01-01	Sink, PTA kitchen, room 104BC	2.7
231-100-DF02-01	Drinking fountain, hallway 100, across from room 109	<1.0
231-117-DF01-01	Drinking fountain, gym, east wall	<1.0
231-101A-SK01-01	Sink, school office room 101A	2.1
231-101C-SK01-01	Sink, nurse room 101C	3.8
231-100-DF01-01	Drinking fountain, hallway 100, across from main office	3.1
231-118-BF01-01	Bottle fill station, hallway 118, across from room 128	<1.0
231-120A-DF01-01	Drinking fountain, hall 120A, between rooms 120 and 121	5.4
231-118-DF01-01	Drinking fountain, hallway 118, next to 125	6.2
231-123-DF01-01	Drinking fountain, room 123	<1.0
231-122-DF01-01	Drinking fountain, room 122	<1.0
231-200-DF01-01	Drinking fountain, hallway 200, next to 205	2.2
231-200-BF01-01	Bottle fill station, hallway 200, across from 208	<1.0

Sample ID Key:

Building number – room number – fixture type count – long term bout count

1. Result less than 1.0 µg/L which is the lowest level that can be reported by the lab.

Phase I & II Sampling – Action Level 15 µg/L

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/15/2017					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
231-104BC-SK-01	Sink, PTA kitchen, room 104BC, north wall	6.7		µg/L	
231-104BC-SK-02	Sink, PTA kitchen, room 104BC, south wall	5.0		µg/L	
231-104-DF-03	Drinking fountain, cafeteria, east wall, left bubbler	4.4		µg/L	
231-104-DF-04	Drinking fountain, cafeteria, east wall, right bubbler	2.2		µg/L	
231-104-DF-05	Drinking fountain, cafeteria, west wall, left bubbler	5.7		µg/L	
231-104-DF-06	Drinking fountain, cafeteria, west wall, right bubbler	5.4		µg/L	
231-106-SK-07	Sink, office 106	17.2	14.0	µg/L	Faucet replaced 7/2018
231-108-SK-08	Classroom sink, room 108	6.7		µg/L	
231-110-SK-09	Classroom sink, room 109	9.8		µg/L	
231-100-DF-10	Drinking fountain, hallway 100, across from room 109, right bubbler	<1.0*2		µg/L	
231-100-DF-11	Drinking fountain, hallway 100, across from room 109, left bubbler	1.2		µg/L	
231-114-SK-12	Classroom sink, room 114	2.3		µg/L	
231-117-DF-13	Drinking fountain, gym, west	<1.0		µg/L	
231-117-DF-14	Drinking fountain, gym, east	11.7		µg/L	
231-100-DF-15	Drinking fountain, hallway 100, across from school office	2.8		µg/L	
231-101A-SK-16	Sink, school office room 101A	3.7		µg/L	
231-101C-SK-17	Sink, nurse room 101C	6.8		µg/L	
231-127-SK-18	Classroom sink, room 127	8.4		µg/L	
231-126-SK-19	Classroom sink, room 126	5.1		µg/L	
231-125-SK-20	Classroom sink, room 125	4.5		µg/L	
231-118-DF-21	Drinking fountain, hallway 118, next to 125, left bubbler	4.9		µg/L	
231-118-DF-22	Drinking fountain, hallway 118, next to 125, right bubbler	3.0		µg/L	
231-124-SK-23	Sink, room 124	16.6	6.0	µg/L	Faucet replaced 7/2018
231-123-SK-24	Classroom sink, room 123	2.0		µg/L	
231-123-DF-25	Drinking fountain, room 123, left bubbler	17.5	14.0	µg/L	Bubbler replaced 1/2018, POU Filter
231-123-DF-26	Drinking fountain, room 123, right bubbler	6.7		µg/L	
231-122-SK-27	Classroom sink, room 122	1.6		µg/L	
231-122-DF-28	Drinking fountain, room 122, left bubbler	12.3		µg/L	
231-122-DF-29	Drinking fountain, room 122, right bubbler	10.5		µg/L	

231-120A-DF-30	Drinking fountain, hall 120A, between rooms 120 and 121, left bubbler	7.3	µg/L
231-120A-DF-31	Drinking fountain, hall 120A, between rooms 120 and 121, right bubbler	9.4	µg/L
231-118-DF-32	Drinking fountain, hallway 118, across from 128, left bubbler	6.7	µg/L
231-118-DF-33	Drinking fountain, hallway 118, across from 128, right bubbler	1.7	µg/L
231-001A-SK-34	Sink, custodial room 001A	7.4	µg/L
231-104A-SK-35	Kitchen sink, right	<1.0	µg/L
231-104A-SK-36	Kitchen sink, left	1.9	µg/L
231-104A-SK-37	Kitchen sink, west side	4.2	µg/L
231-210B-SK-38	Sink, LMC room 210B	9.3	µg/L
231-209-SK-39	Classroom sink, room 209	5.9	µg/L
231-208-SK-40	Classroom sink, room 208	4.6	µg/L
231-207-SK-41	Classroom sink, room 207	4.8	µg/L
231-206-SK-42	Classroom sink, room 206	3.8	µg/L
231-200-DF-43	Drinking fountain, hallway 200, next to 205, left bubbler	2.1	µg/L
231-200-DF-44	Drinking fountain, hallway 200, next to 205, right bubbler	3.6	µg/L
231-205-SK-45	Classroom sink, room 205	6.3	µg/L
231-204-SK-46	Classroom sink, room 204	4.8	µg/L
231-203-SK-47	Classroom sink, room 203	4.8	µg/L
231-202-SK-48	Classroom sink, room 202	4.3	µg/L
231-201-SK-49	Classroom sink, room 201	4.2	µg/L
231-200-DF-50	Drinking fountain, hallway 200, across from 208, left bubbler	2.7	µg/L
231-200-DF-51	Drinking fountain, hallway 200, across from 208, right bubbler	3.1	µg/L
231-PLAYGROUND-DF-52	Drinking fountain, outside by playground	<1.0	µg/L
Phase II Sampled on 3/9/2017			
231-112-SK-55	Classroom sink, room 112	6.0	µg/L
231-111-SK-56	Classroom sink, room 111	4.0	µg/L
231-113-SK-57	Classroom sink, room 113	10.0	µg/L
231-109-SK-58	Classroom sink, room 109	7.0	µg/L
231-115-SK-59	Classroom sink, room 115	4.0	µg/L
231-107-SK-60	Classroom sink, room 107	4.0	µg/L
231-116-SK-61	Classroom sink, room 116	2.0	µg/L
231-129-SK-62	Classroom sink, room 129	10.0	µg/L
231-128-SK-63	Classroom sink, room 128	5.0	µg/L
231-119-SK-64	Classroom sink, room 119	1.0	µg/L
231-120-SK-65	Classroom sink, room 120	2.0	µg/L
231-121-SK-66	Classroom sink, room 121	3.0	µg/L

*1. Follow up samples tested in the field with a Palintest SA1100 scanning analyzer.

*2. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.