

## Hallett Elementary (247) – 2950 N. Jasmine St.

*SY 2019/2020 Long Term Sampling – Action Level 10 µg/L*

*Sample Date: 11/14/2019*

Sample ID	Location Description	Lead Result (µg/L)	Follow Up Result (µg/L)	Action
247-005-SK01-01	Kitchen sink, left	11.7	<2.0 <sup>1</sup> (flush)	Flush notice, faucet Replacement 3/2020
247-005-SK02-01	Kitchen sink, right	2.2		
247-004-DF01-01	Drinking fountain, cafeteria	3.8		
247-115C-SK01-01	Sink, PTA room 115C	1.8		
247-100-DF01-01	Drinking fountain, hallway 100, next to 100G, left bubbler	4.1		
247-114CA2-SK01-01	Nurse sink, room 114CA2	4.7		
247-114CB-SK01-01	Admin office sink, room 114CB	2.6		
247-119-DF01-01	Drinking fountain, gymnasium	4.9		
247-113-DF01-01	Drinking fountain, room 113	<1.0 <sup>2</sup>		
247-112-DF01-01	Drinking fountain, room 112	16.3	Pending	POU Filter 3/2020
247-101-DF01-01	Drinking fountain, room 101	8.4		
247-102-DF01-01	Drinking fountain, room 102	6.2		
247-111-DF01-01	Drinking fountain, room 111	5.2		
247-110-DF01-01	Drinking fountain, room 110	<1.0		
247-103-DF01-01	Drinking fountain, room 103	<1.0		
247-100-DF02-01	Drinking fountain, hallway 100, across from room 110	11.5	Pending	POU Filter 3/2020
247-100-DF03-01	Drinking fountain, hallway 100, across from room 104	<1.0		
247-200-DF03-01	Drinking fountain, hallway 200, across from 204	1.1		
247-200-DF02-01	Drinking fountain, hallway 200, across from 212	6.8		
247-200-DF01-01	Drinking fountain, hallway 200, across from 215	8.1		

**Sample ID Key:**

Building number – room number – fixture type count – long term count

1. Flush sample confirmed in field with Palintest Analyzer.
2. Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab.

## Phase I & II Sampling – Action Level 15 µg/L

All results below 15 ppb – No further action at this time.

**Sample ID Key:**

*Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number*

Phase I Sampled on 9/7/16 & 9/14/16				
Sample ID	Sample Description	Lead Result	Units	Action
247-005-SK-01	Kitchen sink, left	3.8	µg/L	
247-005-SK-02	Kitchen sink, right	2.6	µg/L	
247-004-DF-03	Drinking fountain, cafeteria	3.1	µg/L	
247-115C-SK-04	Sink, PTA room 115C	3.9	µg/L	
247-100-DF-05	Drinking fountain, hallway 100, next to 100G, left bubbler	4.4	µg/L	
247-100-DF-06	Drinking fountain, hallway 100, next to 100G, right bubbler	2.2	µg/L	
247-119-DF-07	Drinking fountain, gym, left bubbler	4.0	µg/L	
247-119-DF-08	Drinking fountain, gym, right bubbler	2.5	µg/L	
247-113-DF-09	Drinking fountain, room 113, left bubbler	10.5	µg/L	
247-113-DF-10	Drinking fountain, room 113, right bubbler	5.2	µg/L	
247-101-DF-11	Drinking fountain, room 101, left bubbler	7.4	µg/L	
247-101-DF-12	Drinking fountain, room 101, right bubbler	3.6	µg/L	
247-112-DF-13	Drinking fountain, room 112, right bubbler	9.0	µg/L	
247-111-DF-14	Drinking fountain, room 114, left bubbler	6.9	µg/L	
247-111-DF-15	Drinking fountain, room 114, right bubbler	5.5	µg/L	
247-102-DF-16	Drinking fountain, room 102, left bubbler	7.2	µg/L	
247-102-DF-17	Drinking fountain, room 102, right bubbler	2.3	µg/L	
247-103-DF-18	Drinking fountain, room 103, left bubbler	10.7	µg/L	
247-103-DF-19	Drinking fountain, room 103, right bubbler	2.4	µg/L	
247-110-DF-20	Drinking fountain, room 110, left bubbler	10.5	µg/L	
247-110-DF-21	Drinking fountain, room 110, right bubbler	7.3	µg/L	
247-100-DF-22	Drinking fountain, hallway 100, across from room 110, left bubbler	8.6	µg/L	
247-100-DF-23	Drinking fountain, hallway 100, across from room 110, right bubbler	6.2	µg/L	
247-109-SK-24	Staff sink, office 109	13.4	µg/L	
247-100-DF-26	Drinking fountain, hallway 100, across from room 104, right bubbler	1.8	µg/L	
247-105-SK-27	Classroom sink, room 105	8.0	µg/L	
247-108-SK-28	Classroom sink, room 108	6.6	µg/L	
247-106-SK-29	Classroom sink, room 106	4.4	µg/L	
247-107-SK-30	Classroom sink, room 107	7.7	µg/L	
247-208-SK-31	Classroom sink, room 208	5.4	µg/L	
247-207-SK-32	Classroom sink, room 207	<1.0* <sup>1</sup>	µg/L	
247-209-SK-33	Classroom sink, room 209	8.7	µg/L	
247-200-DF-34	Drinking fountain, hallway 200, across from 104	2.1	µg/L	
247-200-DF-35	Bottle filler, hallway 200, across from 104	2.3	µg/L	

<b>247-204-SK-36</b>	Classroom sink, room 204	8.7	µg/L
<b>247-200-DF-37</b>	Drinking fountain, hallway 200, across from 212, left bubbler	4.5	µg/L
<b>247-200-DF-38</b>	Drinking fountain, hallway 200, across from 212, right bubbler	3.6	µg/L
<b>247-212-SK-39</b>	Classroom sink, room 212	5.8	µg/L
<b>247-203-SK-40</b>	Classroom sink, room 203	4.5	µg/L
<b>247-213-SK-41</b>	Classroom sink, room 213	6.2	µg/L
<b>247-202-SK-42</b>	Classroom sink, room 202	4.2	µg/L
<b>247-214-SK-43</b>	Classroom sink, room 214	10.1	µg/L
<b>247-201-SK-44</b>	Classroom sink, room 201	2.2	µg/L
<b>247-200-DF-45</b>	Drinking fountain, hallway 200, across from 215, left bubbler	8.3	µg/L
<b>247-200-DF-46</b>	Drinking fountain, hallway 200, across from 215, right bubbler	3.4	µg/L
<b>Phase II Sampled on 2/16/17</b>			
<b>247-114CB-SK-47</b>	Admin office sink, room 114CB	2.9	µg/L
<b>247-114CA2-SK-48</b>	Nurse sink, room 114CA2	3.5	µg/L
<b>247-113-SK-49</b>	Classroom sink, room 113	4.3	µg/L
<b>247-112-SK-50</b>	Classroom sink, room 112	2.5	µg/L
<b>247-101-SK-51</b>	Classroom sink, room 101	2.5	µg/L
<b>247-102-SK-52</b>	Classroom sink, room 102	3.9	µg/L
<b>247-111-SK-53</b>	Classroom sink, room 111	4.1	µg/L
<b>247-110-SK-54</b>	Classroom sink, room 110	3.1	µg/L
<b>247-103-SK-55</b>	Classroom sink, room 103	3.0	µg/L
<b>247-206-SK-56</b>	Classroom sink, room 206	5.7	µg/L
<b>247-215A-SK-57</b>	LMC/IMC office sink, room 215A	8.3	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.