

## Knapp Elementary (250) – 500 S. Utica St.

Sample ID	Location Description	Post-Mitigation Lead Result (µg/L)	Action
250-209-DF01-01	Drinking fountain, room 209	2.5	POU filter installed 2/2020

## Knapp Elementary (250) – 500 S. Utica St.

*SY 2019/2020 Long Term Sampling – Action Level 10 µg/L*

*Sample Date: 12/19/2019*

Sample ID	Location Description	Lead Result (µg/L)	Action
250-133-SK01-01	Kitchen sink, south wall, left faucet	2.3	
250-133-SK02-01	Kitchen sink, south wall, right faucet	1.9	
250-133-SK03-01	Kitchen prep sink, north wall	<1.0 <sup>1</sup>	
250-132-DF01-01	Drinking fountain, cafeteria, east wall	<1.0	
250-H100-DF01-01	Drinking fountain, hallway 100, next to auditorium	11.4	Shut down, Bottle fill install pending
250-128-SK01-01	Nurse sink, room 128, left	3.1	
250-128-SK02-01	Nurse sink, room 128, right	3.3	
250-H100-DF02-01	Drinking fountain, hallway 100, across from room 101	3.1	
250-H100-DF03-01	Drinking fountain, hallway 100, next to room 105	<1.0	
250-121A-DF01-01	Drinking fountain, gymnasium	5.8	
250-H200K-SK01-01	Staff lounge sink, room H200K	2.3	
250-H200-DF01-01	Drinking fountain, hallway 200, next to room 215	2.9	
250-H200-DF02-01	Drinking fountain, hallway 200, next to room 205	8.6	
250-210-DF01-01	Drinking fountain, room 210	<1.0	
250-209-DF01-01	Drinking fountain, room 209	12.8	Shut down
250-223-DF01-01	Drinking fountain, room 223	<1.0	
250-227-DF01-01	Drinking fountain, room 227	<1.0	
250-224-DF01-01	Drinking fountain, room 224	<1.0	
250-228-DF01-01	Drinking fountain, room 228	<1.0	
250-H236-DF01-01	Drinking fountain, H236, next to room 229	<1.0	
250-229-SK01-01	Staff workroom sink, room 229	<1.0	
250-231-DF01-01	Drinking fountain, room 231	<1.0	
250-235-DF01-01	Drinking fountain, room 235	<1.0	
250-230-DF01-01	Drinking fountain, room 230	<1.0	
250-234-DF01-01	Drinking fountain, room 234	<1.0	

**Sample ID Key:**

Building number – room number – fixture type count – long term bout count

1. Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab.

## Phase I & II Sampling – Action Level 15 µg/L

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/20/2016					
Sample ID	Sample Description	Lead Result	Follow Up Results	Units	Action
250-100-DF-01	Drinking fountain, hallway 100, next to auditorium, left bubbler	9.4		µg/L	
250-100-DF-02	Drinking fountain, hallway 100, next to auditorium, right bubbler	7.7		µg/L	
250-132-DF-03	Drinking fountain, cafeteria, left bubbler	26.0	14.0	µg/L	Bubbler replaced 2/2018
250-132-DF-04	Drinking fountain, cafeteria, right bubbler	12.9		µg/L	
250-133-SK-05	Kitchen sink, left faucet	1.2		µg/L	
250-133-SK-06	Kitchen sink, right faucet	<1.0* <sup>1</sup>		µg/L	
250-132-SK-07	Kitchen, spray	1.4		µg/L	
250-121A-DF-08	Drinking fountain, gymnasium	5.8		µg/L	
250-128-SK-09	Sink, nurse office, room 128	6.0		µg/L	
250-100-DF-10	Drinking fountain, hallway 100, across from room 101, left bubbler	2.3		µg/L	
250-100-DF-11	Drinking fountain, hallway 100, next to room 105, left bubbler	7.2		µg/L	
250-100-DF-12	Drinking fountain, hallway 100, next to room 105, right bubbler	13.4		µg/L	
250-235-DF-13	Drinking fountain, room 235	<1.0		µg/L	
250-231-DF-14	Drinking fountain, room 231	<1.0		µg/L	
250-234-DF-15	Drinking fountain, room 234	<1.0		µg/L	
250-230-DF-16	Drinking fountain, room 231	<1.0		µg/L	
250-229-DF-17	Drinking fountain, room 229	<1.0		µg/L	
250-227-DF-18	Drinking fountain, room 227	<1.0		µg/L	
250-223-DF-19	Drinking fountain, room 223	<1.0		µg/L	
250-228-DF-20	Drinking fountain, room 228	<1.0		µg/L	
250-224-DF-21	Drinking fountain, room 224	<1.0		µg/L	
250-200-DF-22	Drinking fountain, hallway 200, next to room 205, left bubbler	7.6		µg/L	
250-200-DF-23	Drinking fountain, hallway 200, next to room 205, right bubbler	2.9		µg/L	
250-200-DF-24	Drinking fountain, hallway 200, next to rest rooms, left bubbler	3.2		µg/L	
250-200-DF-25	Drinking fountain, hallway 200, next to rest rooms, right bubbler	2.0		µg/L	
Phase II Sampled on 3/10/2017					
250-116-SK-26	Classroom sink, room 116	5.0		µg/L	
250-117-SK-27	Classroom sink, room 117	4.0		µg/L	
250-118-SK-28	Classroom sink, room 118	3.0		µg/L	
250-119-SK-29	Classroom sink, room 119	2.0		µg/L	

<b>250-101B-SK-30</b>	LMC/IMC office sink, room 101B	4.0		µg/L	
<b>250-109-SK-31</b>	Staff office sink, room 109	8.0		µg/L	
<b>250-102-SK-32</b>	Classroom sink, room 102	11.0		µg/L	
<b>250-103-SK-33</b>	Classroom sink, room 103	12.0		µg/L	
<b>250-104-SK-34</b>	Classroom sink, room 104	13.0		µg/L	
<b>250-105-SK-35</b>	Classroom sink, room 105	15.0	8.0	µg/L	Faucet replaced 7/2017
<b>250-106-SK-36</b>	Classroom sink, room 106	9.0		µg/L	
<b>250-107-SK-37</b>	Classroom sink, room 107	9.0		µg/L	
<b>250-H200K-38</b>	Faculty lounge sink, room H200K	2.0		µg/L	
<b>250-201-SK-39</b>	Classroom sink, room 201	6.0		µg/L	
<b>250-215-SK-40</b>	Classroom sink, room 215	10.0		µg/L	
<b>250-202-SK-41</b>	Classroom sink, room 202	6.0		µg/L	
<b>250-214-SK-42</b>	Classroom sink, room 214	20.0	9.0	µg/L	Faucet replaced 7/2017
<b>250-203-SK-43</b>	Classroom sink, room 203	10.0		µg/L	
<b>250-204-SK-44</b>	Classroom sink, room 204	8.0		µg/L	
<b>250-213-SK-45</b>	Classroom sink, room 213	11.0		µg/L	
<b>250-212-SK-46</b>	Classroom sink, room 212	11.0		µg/L	
<b>250-205-SK-47</b>	Classroom sink, room 205	4.0		µg/L	
<b>250-206-SK-48</b>	Classroom sink, room 206	5.0		µg/L	
<b>250-211-SK-49</b>	Classroom sink, room 211	8.0		µg/L	
<b>250-207-SK-50</b>	Classroom sink, room 207	7.0		µg/L	
<b>250-208-SK-51</b>	Classroom sink, room 208	6.0		µg/L	
<b>250-210-SK-52</b>	Classroom sink, room 210	3.0		µg/L	
<b>250-210-DF-53</b>	Drinking fountain, room 210	28.0	<1.0	µg/L	Bubbler replaced 2/2018; filter installed 2/2019
<b>250-209-SK-54</b>	Classroom sink, room 209	25.0	7.0	µg/L	Faucet replaced 7/2017
<b>250-224-SK-55</b>	Classroom sink, room 224, left sink	<1.0		µg/L	
<b>250-224-SK-56</b>	Classroom sink, room 224, right sink	<1.0		µg/L	
<b>250-223-SK-57</b>	Classroom sink, room 223, left sink	18.0	2.0	µg/L	Faucet replaced 7/2017
<b>250-223-SK-58</b>	Classroom sink, room 223, right sink	2.0		µg/L	
<b>250-225-SK-59</b>	Classroom sink, room 225	<1.0		µg/L	
<b>250-228-SK-60</b>	Classroom sink, room 228, left sink	<1.0		µg/L	
<b>250-228-SK-61</b>	Classroom sink, room 228, right sink	1.0		µg/L	
<b>250-227-SK-62</b>	Classroom sink, room 227, left sink	<1.0		µg/L	
<b>250-227-SK-63</b>	Classroom sink, room 227, right sink	1.0		µg/L	
<b>250-229-SK-64</b>	Staff workroom sink, room 229	<1.0		µg/L	
<b>250-230-SK-65</b>	Classroom sink, room 230, left sink	<1.0		µg/L	
<b>250-230-SK-66</b>	Classroom sink, room 230, right sink	<1.0		µg/L	
<b>250-234-SK-67</b>	Classroom sink, room 234, left sink	<1.0		µg/L	
<b>250-234-SK-68</b>	Classroom sink, room 234, right sink	<1.0		µg/L	
<b>250-235-SK-69</b>	Classroom sink, room 235, left sink	<1.0		µg/L	
<b>250-235-SK-70</b>	Classroom sink, room 235, right sink	1.0		µg/L	
<b>250-231-SK-71</b>	Classroom sink, room 231, left sink	<1.0		µg/L	
<b>250-231-SK-72</b>	Classroom sink, room 231, right sink	<1.0		µg/L	

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.