

Knight Elementary (251) – 3245 E. Exposition Ave.

SY 2019/2020 Long Term Sampling – Action Level 10 µg/L

Sample Date: 01/17/2020

Sample ID	Location Description	Lead Result (µg/L)	Action
251-KITCH-SK01-01	Kitchen sink, left faucet	2.0	
251-KITCH-SK02-01	Kitchen sink, right faucet	2.6	
251-KITCHA-SK01-01	Kitchen sink, near dishwashing	12.0	Flush notice, faucet replacement pending
251-LUNCH-DF01-01	Drinking fountain, cafeteria	<1.0* ¹	
251-H160-DF01-01	Drinking fountain, hallway H160	3.1	
251-GYM-DF01-01	Drinking fountain, gymnasium	4.0	
251-CLINB-SK01-01	Nurse sink, room CLINB	<1.0	
251-H100B-SK01-01	Lounge sink, room H100B	<1.0	
251-H100-BF01-01	Bottle fill, high-low, hallway H100, next to room H100B	<1.0	
251-119-DF01-01	Drinking fountain, room 119	4.6	
251-118-DF01-01	Drinking fountain, room 118	3.4	
251-H191-DF01-01	Drinking fountain, hall H191	3.8	
251-116A-DF01-01	Drinking fountain, hall 116A	4.7	
251-H192-DF01-01	Drinking fountain, hall H192	32.3	Shut down, POU filter pending
251-H193-DF01-01	Drinking fountain, hall H193	6.3	
251-H110-DF01-01	Drinking fountain, hallway H110, across from 102	5.3	
251-H110-DF02-01	Drinking fountain, hallway H110, across from 108	5.1	

Sample ID Key:

Building number – room number – fixture type count – long term bout count

1. Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab.

Phase I & II Sampling – Action Level 15 µg/L

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/8/1				
Sample ID	Sample Description	Lead Result	Units	Action
251-CAFE-DF-01	Drinking fountain, cafeteria	6.2	µg/L	
251-KITCHA-SK-03	Kitchen sink, near dishwashing	3.6	µg/L	
251-KITCH-SK-04	Kitchen sink, right	6.6	µg/L	
251-KITCH-SK-05	Kitchen sink, left	6.0	µg/L	
251-CAFE-SK-06	Sink, cafeteria	1.3	µg/L	
251-H110-DF-07	Drinking fountain, hallway H110, across from 102, left bubbler	5.2	µg/L	
251-H110-DF-08	Drinking fountain, hallway H110, across from 102, right bubbler	2.2	µg/L	
251-H110-DF-09	Drinking fountain, hallway H110, across from 108, left bubbler	4.5	µg/L	
251-H110-DF-10	Drinking fountain, hallway H110, across from 108, right bubbler	3.5	µg/L	
251-GYM-DF-11	Drinking fountain, gym, left bubbler	5.7	µg/L	
251-GYM-DF-12	Drinking fountain, gym, right bubbler	3.9	µg/L	
251-H180-DF-13	Drinking fountain, hallway H180, left bubbler	2.3	µg/L	
251-H180-DF-14	Drinking fountain, hallway H180, right bubbler	1.9	µg/L	
251-CLINB-SK-15	Nurse sink, room CLINB	<1.0* ¹	µg/L	
251-121-SK-16	Lounge sink, room 121	2.0	µg/L	
251-H100B-SK-17	Lounge sink, room H100B	<1.0	µg/L	
251-H100-DF-18	Drinking fountain, hallway H100, across from 110, left bubbler	2.7	µg/L	
251-119-DF-19	Drinking fountain, room 119, left bubbler	4.2	µg/L	
251-119-DF-20	Drinking fountain, room 119, right bubbler	2.5	µg/L	
251-118-DF-21	Drinking fountain, room 118	<1.0	µg/L	
251-116A-DF-22	Drinking fountain, hall 116A, left bubbler	5.5	µg/L	
251-116A-DF-23	Drinking fountain, hall 116A, right bubbler	4.6	µg/L	
251-H193-DF-24	Drinking fountain, hall H193 (room 115), left bubbler	5.5	µg/L	
251-H193-DF-25	Drinking fountain, hall H193 (room 115), right bubbler	5.1	µg/L	
251-H192-DF-26	Drinking fountain, hall H192 (room 114), left bubbler	6.2	µg/L	
251-H192-DF-27	Drinking fountain, hall H192 (room 114), right bubbler	3.3	µg/L	
251-H191-DF-28	Drinking fountain, hall H191 (room 113), left bubbler	8.0	µg/L	
251-H191-DF-29	Drinking fountain, hall H191 (room 113), right bubbler	7.2	µg/L	
251-112-DF-30	Drinking fountain <u>on</u> sink, room 112	>50	µg/L	Cut, capped & removed
Phase II Sampled on 2/17/17				
251-115-SK-31	Classroom sink, room 115	1.2	µg/L	
251-114-SK-32	Classroom sink, room 114	1.0	µg/L	
251-113-SK-33	Classroom sink, room 113	0.5	µg/L	
251-116-SK-34	Classroom sink, room 116	3.1	µg/L	

251-112-SK-35	Classroom sink, room 112	0.5	µg/L
251-117-SK-36	Classroom sink, room 117	0.5	µg/L
251-118-SK-37	Classroom sink, room 118	0.6	µg/L
251-119-SK-38	Classroom sink, room 119	0.5	µg/L
251-111-SK-39	Classroom sink, room 111	0.6	µg/L
251-110-SK-40	Classroom sink, room 110	<0.5* ²	µg/L
251-109-SK-41	Classroom sink, room 109	<0.5	µg/L
251-102-SK-42	Classroom sink, room 102	1.8	µg/L
251-103-SK-43	Classroom sink, room 103	2.3	µg/L
251-108C-SK-44	Art room sink, room 108C	1.6	µg/L
251-104-SK-45	Classroom sink, room 104	2.2	µg/L
251-107-SK-46	Classroom sink, room 107	4.8	µg/L
251-105-SK-47	Classroom sink, room 105	5.2	µg/L
251-106-SK-48	Classroom sink, room 106	1.2	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Result less than 0.50 ppb which is the lowest level that can be reported by the external lab.