

## Westerly Creek (253)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/8/2016				
Sample ID	Sample Description	Lead Result	Units	Action
253-125-sk-01	Kitchen sink, food prep	<1.0*1	µg/L	
253-151-SK-02	Classroom sink, room 151	<1.0	µg/L	
253-147-SK-03	Classroom sink, room 147	<1.0	µg/L	
253-145-SK-04	Classroom sink, room 145	<1.0	µg/L	
253-141-SK-05	Classroom sink, room 141	<1.0	µg/L	
253-142-DF-06	Drinking fountain, room 142, sink/DF combination	<1.0	µg/L	
253-H140-DF-07	Left drinking fountain, in lobby between gym and room 142	<1.0	µg/L	
253-H140-DF-08	Right drinking fountain, in lobby between gym and room 142	<1.0	µg/L	
253-136-DF-09	Drinking fountain, gymnasium, left	<1.0	µg/L	
253-136-DF-10	Drinking fountain, gymnasium, right	<1.0	µg/L	
253-H100-DF-11	Drinking fountain, left, hall 100, next to room 120	<1.0	µg/L	
253-H100-DF-12	Drinking fountain, right, hall 100, next to room 120	<1.0	µg/L	
253-117-SK-13	Classroom sink, room 117	<1.0	µg/L	
253-118-DF-14	Drinking fountain, room 118, sink/DF combination	<1.0	µg/L	
253-118-SK-15	Classroom sink, room 118, sink/DF combination	<1.0	µg/L	
253-114-SK-16	Classroom sink, room 114	<1.0	µg/L	
253-115-SK-17	Classroom sink, room 115	<1.0	µg/L	
253-116-SK-18	Classroom sink, room 113	<1.0	µg/L	
253-111-SK-19	Classroom sink, room 111	<1.0	µg/L	
253-110-DF-20	Drinking fountain, room 110	<1.0	µg/L	
253-102-SK-21	Classroom sink, room 102, next to door	<1.0	µg/L	
253-102-SK-22	Classroom sink, room 102, next to restrooms	<1.0	µg/L	
253-104-SK-23	Classroom sink, room 104, next to restrooms	<1.0	µg/L	
253-104-SK-24	Classroom sink, room 104, next to door	<1.0	µg/L	
253-106-SK-25	Classroom sink, room 106, next to door	<1.0	µg/L	
253-106-SK-26	Classroom sink, room 106, next to restrooms	<1.0	µg/L	
253-108-SK-27	Classroom sink, room 105, next to door	<1.0	µg/L	
253-108-DF-28	Drinking fountain, room 108	<1.0	µg/L	
253-H227-DF-29	Drinking fountain, left, hall H227, across from elevator	<1.0	µg/L	
253-H227-DF-30	Drinking fountain, right, hall H227, across from elevator	<1.0	µg/L	
253-251-SK-31	Classroom sink, room 251	<1.0	µg/L	
253-247-SK-32	Classroom sink, room 247	1.6	µg/L	

<b>253-245-SK-33</b>	Classroom sink, room 245	<1.0	µg/L
<b>253-241-SK-34</b>	Classroom sink, room 241	<1.0	µg/L
<b>253-226-SK-35</b>	Classroom sink, room 226, on left	<1.0	µg/L
<b>253-226-SK-36</b>	Classroom sink, room 226, on right	<1.0	µg/L
<b>253-224-SK-37</b>	Classroom sink, room 224	2.0	µg/L
<b>253-214-SK-38</b>	Classroom sink, room 214	<1.0	µg/L
<b>253-217-SK-39</b>	Classroom sink, room 217	<1.0	µg/L
<b>253-215-SK-40</b>	Classroom sink, room 215	<1.0	µg/L
<b>253-213-SK-41</b>	Classroom sink, room 213	<1.0	µg/L
<b>253-211-SK-42</b>	Classroom sink, room 211	<1.0	µg/L
<b>253-205-SK-43</b>	Classroom sink, room 205	<1.0	µg/L
<b>253-133-SK-44</b>	Sink, all-purpose stage, room 133	<1.0	µg/L
<b>Phase II Sampled on 4/28/2017</b>			
<b>253-109-SK-45</b>	Nurse sink, room 109	<1.0	µg/L
<b>253-104-DF-46</b>	Drinking fountain, room 104	<1.0	µg/L
<b>253-110-SK-47</b>	Classroom sink, room 110	<1.0	µg/L
<b>253-122A-SK-48</b>	LMA/IMC office sink, room 122A	4.0	µg/L
<b>253-129A-SK-49</b>	All purpose room sink, room 129A	7.0	µg/L
<b>253-142-SK-50</b>	Classroom sink, room 142	<1.0	µg/L
<b>253-146-SK-51</b>	Classroom sink, room 146, left sink	<1.0	µg/L
<b>253-146-SK-52</b>	Classroom sink, room 146, right sink	<1.0	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.