

**McMeen Elementary (254) – 1000 S. Holly St.**

***SY 2019/2020 Long Term Sampling – Action Level 10 µg/L***

***Sample Date: 02/21/2020***

<b>Sample ID</b>	<b>Description</b>	<b>Lead Result (µg/L)</b>
254-118-SK01-01	Kitchen sink, 3 compartment, left faucet	2.0
254-118-SK02-01	Kitchen sink, 3 compartment, right faucet	2.8
254-118-SK03-01	Kitchen prep sink, south wall	<1.0
254-117-DF02-01	Drinking fountain, cafeteria, SW corner	1.9
254-117-DF01-01	Drinking fountain, cafeteria, NW corner	<1.0 <sup>1</sup>
254-120-DF01-01	Drinking fountain, gymnasium	3.4
254-115-DF01-01	Drinking fountain, hallway 115, across from main office	4.6
254-116C-SK01-01	Nurse sink, room 116C	3.6
254-116-SK01-01	Admin office sink, room 116	<1.0
254-100-DF01-01	Drinking fountain, hallway 100, across from room 113	3.2
254-102-DF01-01	Drinking fountain, room 102	7.7
254-103-DF01-01	Drinking fountain, room 103	4.1
254-100-DF02-01	Drinking fountain, hallway 100, across from room 109	2.2
254-100-DF03-01	Drinking fountain, hallway 100, across from room 105	2.2
254-200-DF03-01	Drinking fountain, hallway 200, across from room 206	<1.0
254-200-DF02-01	Drinking fountain, hallway 200, next to room 204	6.7
254-200-DF01-01	Drinking fountain, hallway 200, across from room 214	<1.0

**Sample ID Key:**

Building number – room number – fixture type count – long term bout count

1. Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab.

## Phase I & II Sampling – Action Level 15 µg/L

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 9/21/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
254-118-sk-01	Kitchen sink, left faucet	<1.0* <sup>1</sup>		µg/L	
254-118-SK-02	Kitchen sink, right faucet	1.4		µg/L	
254-117-DF-03	Drinking fountain, cafeteria, west wall, north side, left bubbler	10.6		µg/L	
254-117-DF-04	Drinking fountain, cafeteria, west wall, north side, right bubbler	2.9		µg/L	
254-117-DF-05	Drinking fountain, cafeteria, west wall, south side, left bubbler	3.2		µg/L	
254-117-DF-06	Drinking fountain, cafeteria, west wall, south side, right bubbler	<1.0		µg/L	
254-120-DF-07	Drinking fountain, gym	3.1		µg/L	
254-115-DF-08	Drinking fountain, lobby, left bubbler	4.4		µg/L	
254-115-DF-09	Drinking fountain, lobby, right bubbler	2.3		µg/L	
254-123-DF-10	Drinking fountain, first floor, next to elevator	5.0		µg/L	
254-100-DF-11	Drinking fountain, hallway 100, across from room 113, left bubbler	4.3		µg/L	
254-100-DF-12	Drinking fountain, hallway 100, across from room 113, right bubbler	4.9		µg/L	
254-102-DF-13	Drinking fountain, room 102, left bubbler	6.6		µg/L	
254-102-DF-14	Drinking fountain, room 102, right bubbler	2.3		µg/L	
254-103-DF-15	Drinking fountain, room 103, left bubbler	3.8		µg/L	
254-103-DF-16	Drinking fountain, room 103, right bubbler	3.0		µg/L	
254-100-DF-17	Drinking fountain, hallway 100, across from room 109, left bubbler	4.0		µg/L	
254-100-DF-18	Drinking fountain, hallway 100, across from room 109, right bubbler	3.5		µg/L	
254-100-DF-19	Drinking fountain, hallway 100, across from room 105	2.9		µg/L	
254-200-DF-20	Drinking fountain, hallway 200, across from room 214, left bubbler	1.5		µg/L	
254-200-DF-21	Drinking fountain, hallway 200, across from room 214, right bubbler	1.7		µg/L	
254-200-DF-22	Drinking fountain, hallway 200, across from room 210, left bubbler	6.6		µg/L	
254-200-DF-23	Drinking fountain, hallway 200, across from room 210, right bubbler	3.4		µg/L	
254-200-DF-24	Drinking fountain, hallway 200, across from room 206, left bubbler	1.7		µg/L	

<b>254-200-DF-25</b>	Drinking fountain, hallway 200, across from room 206, right bubbler	1.7		µg/L	
<b>Phase II Sampled on 3/16/2017</b>					
<b>254-107-SK-26</b>	Classroom sink, room 107	18.0	29	µg/L	Faucet replaced 6/2018, cleaning only notice
<b>254-106-SK-27</b>	Classroom sink, room 106	10.0		µg/L	
<b>254-108-SK-28</b>	Classroom sink, room 108	5.0		µg/L	
<b>254-105-SK-29</b>	Classroom sink, room 105	12.0		µg/L	
<b>254-100J-SK-30</b>	Office sink, room 100J	5.0		µg/L	
<b>254-109-SK-31</b>	Classroom sink, room 109	1.0		µg/L	
<b>254-103-SK-32</b>	Classroom sink, room 103	<1.0		µg/L	
<b>254-110-SK-33</b>	Classroom sink, room 110	<1.0		µg/L	
<b>254-102-SK-34</b>	Classroom sink, room 102	<1.0		µg/L	
<b>254-111-SK-35</b>	Classroom sink, room 111	1.0		µg/L	
<b>254-101-SK-36</b>	Classroom sink, room 101	3.0		µg/L	
<b>254-112-SK-37</b>	Classroom sink, room 112	6.0		µg/L	
<b>254-113-SK-38</b>	Classroom sink, room 113	6.0		µg/L	
<b>254-114-SK-39</b>	Classroom sink, room 114	4.0		µg/L	
<b>254-116-SK-40</b>	Admin office sink, room 116	2.0		µg/L	
<b>254-116C-SK-41</b>	Nurse sink, room 116C	3.0		µg/L	
<b>254-215A-SK-42</b>	LMC/IMC office sink, room 215A	4.0		µg/L	
<b>254-214-SK-43</b>	Classroom sink, room 214	2.0		µg/L	
<b>254-201-SK-44</b>	Classroom sink, room 201	2.0		µg/L	
<b>254-213-SK-45</b>	Classroom sink, room 213	2.0		µg/L	
<b>254-202-SK-46</b>	Classroom sink, room 202	3.0		µg/L	
<b>254-212-SK-47</b>	Classroom sink, room 212	4.0		µg/L	
<b>254-203-SK-48</b>	Classroom sink, room 203	2.0		µg/L	
<b>254-211-SK-49</b>	Classroom sink, room 211	<1.0		µg/L	
<b>254-204-SK-50</b>	Classroom sink, room 204	5.0		µg/L	
<b>254-210-SK-51</b>	Classroom sink, room 210	1.0		µg/L	
<b>254-200L-SK-52</b>	Classroom sink, room 200L	9.0		µg/L	
<b>254-206-SK-53</b>	Classroom sink, room 206	7.0		µg/L	
<b>254-209-SK-54</b>	Classroom sink, room 209	4.0		µg/L	
<b>254-207-SK-55</b>	Classroom sink, room 207	7.0		µg/L	
<b>254-208-SK-56</b>	Classroom sink, room 208	16.0	11	µg/L	Faucet replaced 6/2018

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.