

Greenwood Elementary (258)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

| Phase I Sampled on 10/6/2016 | | | | |
|-------------------------------|---|--------------------|-------|--------|
| Sample ID | Sample Description | Lead Result | Units | Action |
| 258-101E-SK-01 | Staff lounge sink, room 101E | 0.4 | µg/L | |
| 258-101E-DF-02 | Staff lounge, bottle fill, room 101E | <0.1* ¹ | µg/L | |
| 258-101F-SK-03 | Nurse sink, room 101F | 0.2 | µg/L | |
| 258-104-DF-04 | Drinking fountain, hallway 104, across from room 106, left bubbler | <0.1 | µg/L | |
| 258-104-DF-05 | Drinking fountain, hallway 104, across from room 106, right bubbler | <0.1 | µg/L | |
| 258-108-DF-06 | Drinking fountain, room 108 | 0.7 | µg/L | |
| 258-109-DF-07 | Drinking fountain, room 109 | 0.1 | µg/L | |
| 258-115-DF-08 | Drinking fountain, room 115 | <0.1 | µg/L | |
| 258-116-DF-03 | Drinking fountain, room 116 | <0.1 | µg/L | |
| 258-117-DF-10 | Drinking fountain, room 117 | 0.5 | µg/L | |
| 258-118-DF-11 | Drinking fountain, room 118 | 1.8 | µg/L | |
| 258-123-DF-12 | Drinking fountain, room 123 | 0.1 | µg/L | |
| 258-122-DF-13 | Drinking fountain, hallway 122, across from room 124, left bubbler | <0.1 | µg/L | |
| 258-122-DF-14 | Drinking fountain, hallway 122, across from room 124, right bubbler | 0.4 | µg/L | |
| 258-100-DF-15 | Drinking fountain, hallway 100, outside of gymnasium, left bubbler | <0.1 | µg/L | |
| 258-100-DF-16 | Drinking fountain, hallway 100, outside of gymnasium, right bubbler | <0.1 | µg/L | |
| 258-135-SK-17 | kitchen prep sink, west wall | 1.7 | µg/L | |
| 258-136-DF-18 | Drinking fountain, gymnasium, next to double doors | <0.1 | µg/L | |
| 258-139-DF-19 | Drinking fountain, hallway 139, across from room 140, left bubbler | 0.2 | µg/L | |
| 258-139-DF-20 | Drinking fountain, hallway 139, across from room 140, right bubbler | 0.3 | µg/L | |
| 258-155-DF-21 | Drinking fountain, hallway 155, across from room 157, left bubbler | 0.1 | µg/L | |
| 258-155-DF-22 | Drinking fountain, hallway 155, across from room 157, right bubbler | 0.1 | µg/L | |
| Phase II Sampled on 4/26/2017 | | | | |
| 258-162-SK-23 | Faculty workroom sink, room 162 | <1.0* ² | µg/L | |
| 258-159-SK-24 | Classroom sink, room 159 | 3.0 | µg/L | |
| 258-158-SK-25 | Classroom sink, room 158 | <1.0 | µg/L | |
| 258-157-SK-26 | Classroom sink, room 157 | <1.0 | µg/L | |
| 258-156-SK-27 | Classroom sink, room 156 | <1.0 | µg/L | |
| 258-153-SK-28 | Classroom sink, room 153 | <1.0 | µg/L | |
| 258-152-SK-29 | Classroom sink, room 152 | <1.0 | µg/L | |
| 258-148-SK-30 | Classroom sink, room 148 | <1.0 | µg/L | |
| 258-147-SK-31 | Classroom sink, room 147 | 1.0 | µg/L | |
| 258-146-SK-32 | Classroom sink, room 146 | <1.0 | µg/L | |

| | | | |
|----------------------|-----------------------------|------|------|
| 258-141-SK-33 | Classroom sink, room 141 | <1.0 | µg/L |
| 258-140-SK-34 | Classroom sink, room 140 | <1.0 | µg/L |
| 258-142-SK-35 | Classroom sink, room 142 | <1.0 | µg/L |
| 258-105-SK-36 | Classroom sink, room 105 | <1.0 | µg/L |
| 258-111-SK-37 | Admin office sink, room 111 | <1.0 | µg/L |
| 258-106-SK-38 | Classroom sink, room 106 | <1.0 | µg/L |
| 258-107-SK-39 | Classroom sink, room 107 | <1.0 | µg/L |
| 258-108-SK-40 | Classroom sink, room 108 | <1.0 | µg/L |
| 258-109-SK-41 | Classroom sink, room 109 | 1.0 | µg/L |
| 258-115-SK-42 | Classroom sink, room 115 | <1.0 | µg/L |
| 258-116-SK-43 | Classroom sink, room 116 | <1.0 | µg/L |
| 258-117-SK-44 | Classroom sink, room 117 | <1.0 | µg/L |
| 258-118-SK-45 | Classroom sink, room 118 | <1.0 | µg/L |
| 258-126-SK-46 | Classroom sink, room 126 | <1.0 | µg/L |
| 258-123-SK-47 | Classroom sink, room 123 | <1.0 | µg/L |
| 258-124-SK-48 | Classroom sink, room 124 | <1.0 | µg/L |
| 258-125-SK-49 | Classroom sink, room 125 | <1.0 | µg/L |
| 258-129-SK-50 | Classroom sink, room 129 | <1.0 | µg/L |
| 258-130-SK-51 | Classroom sink, room 130 | <1.0 | µg/L |
| 258-131-SK-52 | Classroom sink, room 131 | <1.0 | µg/L |
| 258-132-SK-53 | Classroom sink, room 132 | <1.0 | µg/L |

*1. Result less than 0.1 ppb which is the lowest level that can be reported by the external lab.

*2. Result less than 0.1 ppb which is the lowest level that can be reported by the lab.