

## Munroe Elementary (260)

All results less than 15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/22/2016				
Sample ID	Sample Description	Lead Result	Units	Action
260-119-sk-01	Kitchen prep sink, west wall, left faucet	<1.0* <sup>1</sup>	µg/L	
260-119-SK-02	Kitchen prep sink, west wall, right faucet	<1.0	µg/L	
260-120-DF-03	Drinking fountain, cafeteria, left bubbler	<1.0	µg/L	
260-120-DF-04	Drinking fountain, cafeteria, right bubbler	1.9	µg/L	
260-120A-SK-05	Sink, PTA kitchen, room 120A	1.1	µg/L	
260-121G0-SK-06	Sink, admin office, room 121G	<1.0	µg/L	
260-121E-SK-07	Sink, nurse office, room 121E	<1.0	µg/L	
260-100-DF-08	Drinking fountain, hallway 100, left bubbler, across from main office	1.8	µg/L	
260-100-DF-09	Drinking fountain, hallway 100, right bubbler, across from main office	1.9	µg/L	
260-100-DF-10	Drinking fountain, hallway 100, left bubbler, across from room 101	1.0	µg/L	
260-100-DF-11	Drinking fountain, hallway 100, right bubbler, across from room 101	<1.0	µg/L	
260-114-DF-12	Drinking fountain, room 114	3.1	µg/L	
260-114-SK-13	Classroom sink, room 114	3.5	µg/L	
260-113-DF-14	Drinking fountain, room 113	1.9	µg/L	
260-113-SK-15	Classroom sink, room 113	2.8	µg/L	
260-106-SK-16	Lounge sink, room 106	1.3	µg/L	
260-100-DF-17	Drinking fountain, hallway 100, next to room 112	<1.0	µg/L	
260-112-SK-18	Classroom sink, room 112	<1.0	µg/L	
260-107-SK-19	Classroom sink, room 107	1.4	µg/L	
260-200-DF-20	Drinking fountain, hallway 200, next to room 211	<1.0	µg/L	
260-200-DF-21	Drinking fountain, hallway 200, next to room 208	<1.0	µg/L	
260-200-DF-22	Drinking fountain, hallway 200, right bubbler, next to room 213	<1.0	µg/L	
260-200-DF-23	Drinking fountain, hallway 200, left bubbler, across from room 202	<1.0	µg/L	
260-200-DF-24	Drinking fountain, hallway 200, right bubbler, across from room 202	1.2	µg/L	
260-201A-SK-25	LMC sink, room 201A	4.3	µg/L	
260-118-DF-26	Drinking fountain, gymnasium, east wall	<1.0	µg/L	
Phase II Sampled on 3/24/2017				
260-118-DF-27	Drinking fountain, gymnasium, north wall	<1.0	µg/L	
260-115-SK-28	Classroom sink, room 115	5.0	µg/L	
260-114-SK-29	Classroom sink, room 114, on left	2.0	µg/L	
260-114-SK-30	Classroom sink, room 114, on right	8.0	µg/L	
260-100-DF-31	Drinking fountain, hallway 100, across from room 104, left bubbler	<1.0	µg/L	

<b>260-100-DF-32</b>	Drinking fountain, hallway 100, across from room 104, right bubbler	<1.0	µg/L
<b>260-113-SK-33</b>	Classroom sink, room 113, on left	6.0	µg/L
<b>260-113-SK-34</b>	Classroom sink, room 113, on right	2.0	µg/L
<b>260-112-SK-35</b>	Classroom sink, room 112, hand sink on left	<1.0	µg/L
<b>260-112-SK-36</b>	Classroom sink, room 112, on right	<1.0	µg/L
<b>260-111-SK-37</b>	Classroom sink, room 111, hand sink on left	<1.0	µg/L
<b>260-111-SK-38</b>	Classroom sink, room 111, on right	<1.0	µg/L
<b>260-110-SK-39</b>	Classroom sink, room 110, west wall	<1.0	µg/L
<b>260-110-SK-40</b>	Classroom sink, room 110, east wall	<1.0	µg/L
<b>260-109-SK-41</b>	Classroom sink, room 109, west wall	<1.0	µg/L
<b>260-109-SK-42</b>	Classroom sink, room 109, east wall	1.0	µg/L
<b>260-108-SK-43</b>	Classroom sink, room 108, west wall	<1.0	µg/L
<b>260-108-SK-44</b>	Classroom sink, room 108, east wall	<1.0	µg/L
<b>260-107-SK-45</b>	Classroom sink, room 107, east wall	<1.0	µg/L
<b>260-107-SK-46</b>	Classroom sink, room 107, west wall	<1.0	µg/L
<b>260-105-SK-47</b>	Classroom sink, room 105	1.0	µg/L
<b>260-104-SK-48</b>	Classroom sink, room 104	2.0	µg/L
<b>260-103-SK-49</b>	Classroom sink, room 103	2.0	µg/L
<b>260-102-SK-50</b>	Classroom sink, room 102	2.0	µg/L
<b>260-101-SK-51</b>	Classroom sink, room 101	5.0	µg/L
<b>260-209-SK-52</b>	Classroom sink, room 209	<1.0	µg/L
<b>260-208-SK-53</b>	Classroom sink, room 208	<1.0	µg/L
<b>260-210-SK-54</b>	Classroom sink, room 210	<1.0	µg/L
<b>260-211-SK-55</b>	Classroom sink, room 211	<1.0	µg/L
<b>260-206-SK-56</b>	Classroom sink, room 206	1.0	µg/L
<b>260-205-SK-57</b>	Classroom sink, room 205	3.0	µg/L
<b>260-204-SK-58</b>	Classroom sink, room 204	<1.0	µg/L
<b>260-203-SK-59</b>	Classroom sink, room 203	4.0	µg/L
<b>260-202-SK-60</b>	Classroom sink, room 202	3.0	µg/L
<b>260-215-SK-61</b>	Classroom sink, room 215	2.0	µg/L
<b>260-214-SK-62</b>	Classroom sink, room 214	1.0	µg/L
<b>260-213-SK-63</b>	Classroom sink, room 213	3.0	µg/L
<b>260-212-SK-64</b>	Classroom sink, room 212	4.0	µg/L
<b>260-001A-SK-65</b>	Custodial office sink, room 001A	<1.0	µg/L
<b>260-118DA-SK-66</b>	Gymnasium office sink, room 118DA	3.0	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.