

**Palmer Elementary (262) – 995 N. Grape St.**

***SY 2019/2020 Long Term Sampling – Action Level 10 µg/L***

***Sample Date: 03/13/2020***

<b>Sample ID</b>	<b>Location Description</b>	<b>Lead Result (µg/L)</b>
262-003-SK01-01	Facility Manager sink, room 003	4.7
262-126B-SK01-01	Kitchen sink, left faucet	2.0
262-126B-SK02-01	Kitchen sink, right faucet	2.1
262-127-DF01-01	Drinking fountain, gymnasium	<1.0 <sup>1</sup>
262-126E-SK01-01	PTA kitchen sink, room 126E	2.7
262-124-SK01-01	Lounge sink, room 124	<1.0
262-100-DF01-01	Drinking fountain, hallway 100, next to auditorium	7.6
262-104AA-SK01-01	Nurse restroom sink, room 104AA	2.2
262-102-DF01-01	Drinking fountain, hallway 102, across from room 106	4.5
262-118A-DF01-01	Drinking fountain, hallway 118A	<1.0
262-102-DF02-01	Drinking fountain, hallway 102, across from room 110	3.4
262-115-DF01-01	Drinking fountain, between rooms 114 and 115	<1.0
262-200-DF02-01	Drinking fountain, hallway 200, across from room 206	2.5
262-200-DF01-01	Drinking fountain, hallway 200, across from room 203	3.7
262-201A-SK01-01	Lounge sink, room 201A	5.4

**Sample ID Key:**

Building number – room number – fixture type count – long term bout count

1. <1.0 Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab

## Phase I & II Sampling – Action Level 15 µg/L

**Sample ID Key:**

*Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number*

Phase I Sampled on 9/7/2016					
Sample ID	Sample Description	Lead Result	Follow Up Results	Units	Action
262-126B-SK-01	Kitchen sink, left	2.7		µg/L	
262-126B-SK-02	Kitchen sink, right	1.8		µg/L	
262-100-DF-03	Drinking fountain, lobby, left bubbler	6.2		µg/L	
262-102-DF-04	Drinking fountain, hallway 102, across from room 106, left bubbler	8.4		µg/L	
262-102-DF-05	Drinking fountain, hallway 102, across from room 106, right bubbler	4.4		µg/L	
262-115A-DF-06	Drinking fountain, hall 115A, between rooms 119 and 118	<1.0* <sup>1</sup>		µg/L	
262-102-DF-07	Drinking fountain, hallway 102, across from 110, left bubbler	<1.0		µg/L	
262-102-DF-08	Drinking fountain, hallway 102, across from 110, right bubbler	<1.0		µg/L	
262-127-DF-09	Drinking fountain, hallway between rooms 114 and 115	<1.0		µg/L	
262-200-DF-10	Drinking fountain, hallway 200, next to room 215, left bubbler	2.3		µg/L	
262-200-DF-11	Drinking fountain, hallway 200, next to room 215, right bubbler	1.6		µg/L	
262-200-DF-12	Drinking fountain, hallway 200, next to room 217, left bubbler	7.6		µg/L	
262-200-DF-13	Drinking fountain, hallway 200, next to room 217, right bubbler	2.2		µg/L	
262-127-DF-14	Drinking fountain, gymnasium	<1.0		µg/L	
Phase II Sampled on 2/14/2017					
262-006-SK-15	Office sink, room 006	2.0		µg/L	
262-126E-SK-16	Faculty lounge sink, room 126E	2.0		µg/L	
262-124-SK-17	Faculty lounge sink, room 124	<1.0		µg/L	
262-104AA-SK-18	Nurse sink, room 104AA	3.0		µg/L	
262-106-SK-19	Classroom sink, room 106	3.0		µg/L	
262-119-SK-20	Classroom sink, room 119	<1.0		µg/L	
262-118-SK-21	Classroom sink, room 118	<1.0		µg/L	
262-107-SK-22	Classroom sink, room 107	1.0		µg/L	
262-108-SK-23	Classroom sink, room 108	2.0		µg/L	
262-109-SK-24	Classroom sink, room 109	1.0		µg/L	

<b>262-110-SK-25</b>	Faculty lounge sink, room 110	18.0	9.0	µg/L	Replaced 4/2018
<b>262-115-SK-26</b>	Classroom sink, room 115	<1.0		µg/L	
<b>262-114-SK-27</b>	Classroom sink, room 114, on left	<1.0		µg/L	
<b>262-114-SK-28</b>	Classroom sink, room 114, on right	<1.0		µg/L	
<b>262-210-SK-29</b>	Classroom sink, room 210	<1.0		µg/L	
<b>262-211-SK-30</b>	Classroom sink, room 211	<1.0		µg/L	
<b>262-212-SK-31</b>	Classroom sink, room 212	1.0		µg/L	
<b>262-206-SK-32</b>	Classroom sink, room 206	3.0		µg/L	
<b>262-215-SK-33</b>	Classroom sink, room 215	<1.0		µg/L	
<b>262-205-SK-34</b>	Classroom sink, room 205	3.0		µg/L	
<b>262-216-SK-35</b>	Classroom sink, room 216	5.0		µg/L	
<b>262-204-SK-36</b>	Classroom sink, room 204	6.0		µg/L	
<b>262-217-SK-37</b>	Classroom sink, room 217	<1.0		µg/L	
<b>262-203-SK-38</b>	Classroom sink, room 203	7.0		µg/L	
<b>262-201A-SK-39</b>	LMC/IMC office sink, room 201A	13.0		µg/L	

\*1. <1.0\* Result less than 1.0 ppb which is the lowest level that can be reported by the lab.