

Sabin Elementary (269) – 3050 S. Vrain St.

SY 2019/2020 Long Term Sampling – Action Level 10 µg/L

Sample Date: 01/30/2020

Sample ID	Location Description	Lead Result (µg/L)	Action
269-KIT-SK01-01	Kitchen sink, west wall, left faucet	<1.0 ¹	
269-KIT-SK02-01	Kitchen sink, west wall, right faucet	<1.0	
269-LR-DF01-01	Drinking fountain, cafeteria, west wall	5.4	
269-LR-DF02-01	Drinking fountain, cafeteria, east wall	4.0	
269-H100-BF01-01	Bottle fill station, single bubbler, H100, next to main office	2.0	
269-OFFC-SK01-01	Lounge sink, main office	1.6	
269-OFFB-SK01-01	Nurse sink, room OFFB, in main office	3.6	
269-H100-DF01-01	Drinking fountain, hallway H100, next to LMC	6.7	
269-H100-DF02-01	Drinking fountain, hallway H100, next to room 106	<1.0	
269-H110-DF01-01	Drinking fountain, hallway H110, next to room 111	1.3	
269-GYM-DF02-01	Drinking fountain, gymnasium, southeast corner	8.9	
269-GYM-DF01-01	Drinking fountain, gymnasium, northwest corner	3.7	
269-H130-DF01-01	Drinking fountain, hallway H130, across from room 132	4.1	
269-H130-DF02-01	Drinking fountain, hallway H130, next to room 140	5.6	
269-139-DF01-01	Drinking fountain, room 139	5.8	
269-138-DF01-01	Drinking fountain, room 138	10.8	Shut down, POU filter install pending
269-H140-DF01-01	Drinking fountain, hallway H140, next to room 119	4.1	
269-H140-DF02-01	Drinking fountain, hallway H140, next to room 121	<1.0	
269-H140-DF04-01	Drinking fountain, hallway H140, next to room 128	3.8	

Sample ID Key:

Building number – room number – fixture type count – long term count

1. Result less than 1.0 µg/L, which is the lowest level that can be reported by the lab.

Phase I & II Sampling – Action Level 15 µg/L

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/22/16					
Sample ID	Sample Description	Lead Result	Follow Up Results	Units	Action
269-KIT-SK-01	Kitchen sink, west wall	<1.0*		µg/L	
269-LR-DF-02	Drinking fountain, cafeteria, west wall	3.9		µg/L	
269-LR-DF-03	Drinking fountain, cafeteria, east wall	3.6		µg/L	
269-139-DF-04	Drinking fountain, room 139	5.8		µg/L	
269-138-DF-05	Drinking fountain, room 138	8.4		µg/L	
269-H130-DF-06	Drinking fountain, hallway H130, next to room 140, left bubbler	4.0		µg/L	
269-H130-DF-07	Drinking fountain, hallway H130, next to room 140, right bubbler	2.3		µg/L	
269-H130-DF-08	Drinking fountain, hallway H130, across from room 132	2.6		µg/L	
269-H140-DF-09	Drinking fountain, hallway H140, next to room 128	3.4		µg/L	
269-H140-DF-10	Drinking fountain, hallway H140, next to room 130	<1.0		µg/L	
269-H140-DF-11	Drinking fountain, hallway H140, next to room 121, left bubbler	2.5		µg/L	
269-H140-DF-13	Drinking fountain, hallway H140, next to room 119, left bubbler	4.7		µg/L	
269-H140-DF-14	Drinking fountain, hallway H140, next to room 119, right bubbler	3.8		µg/L	
269-H110-DF-15	Drinking fountain, hallway H110, next to room 111	1.1		µg/L	
269-OFFB-SK-16	Nurse sink, room OFFB, in main office	3.7		µg/L	
269-OFFC-SK-17	Lounge sink, main office	1.0		µg/L	
269-H100-DF-18	Drinking fountain, hallway H100, next to main office	<1.0		µg/L	
269-H100-DF-19	Drinking fountain, hallway H100, next to LMC	2.8		µg/L	
269-GYM-DF-20	Drinking fountain, gymnasium, northwest corner	6.2		µg/L	
269-GYM-DF-21	Drinking fountain, gymnasium, southeast corner	5.3		µg/L	
269-H100-DF-22	Drinking fountain, hallway H100, next to room 106	16.0	13.0	µg/L	Bubbler replaced 5/2018
Phase II Sampled on 3/23/17					
269-105-SK-23	Classroom sink, room 105	6.0		µg/L	
269-106-SK-24	Classroom sink, room 106	7.0		µg/L	
269-104-SK-25	Classroom sink, room 104	6.0		µg/L	
269-107-SK-26	Classroom sink, room 107	6.0		µg/L	
269-103-SK-27	Classroom sink, room 103	6.0		µg/L	
269-108-SK-28	Classroom sink, room 108	5.0		µg/L	
269-109-SK-29	Classroom sink, room 109	6.0		µg/L	

269-110-SK-30	Classroom sink, room 110	7.0		µg/L	
269-111-SK-31	Classroom sink, room 111	2.0		µg/L	
269-112-SK-32	Classroom sink, room 112	2.0		µg/L	
269-113-SK-33	Classroom sink, room 113	4.0		µg/L	
269-114-SK-34	Classroom sink, room 114	5.0		µg/L	
269-117-SK-35	Classroom sink, room 117	6.0		µg/L	
269-118-SK-36	Classroom sink, room 118	4.0		µg/L	
269-116-SK-37	Classroom sink, room 116	6.0		µg/L	
269-119-SK-38	Classroom sink, room 119	4.0		µg/L	
269-115-SK-39	Classroom sink, room 115	5.0		µg/L	
269-120-SK-40	Classroom sink, room 120	2.0		µg/L	
269-121-SK-41	Faculty workroom sink, room 121	4.0		µg/L	
269-131-SK-42	Faculty lounge sink, room 131	4.0		µg/L	
269-122-SK-43	Classroom sink, room 122	3.0		µg/L	
269-130-SK-44	Classroom sink, room 130	7.0		µg/L	
269-123-SK-45	Classroom sink, room 123	3.0		µg/L	
269-129-SK-46	Classroom sink, room 129	4.0		µg/L	
269-124-SK-47	Classroom sink, room 124	2.0		µg/L	
269-128-SK-48	Classroom sink, room 128	6.0		µg/L	
269-125-SK-49	Classroom sink, room 125	9.0		µg/L	
269-127-SK-50	Classroom sink, room 127	3.0		µg/L	
269-126-SK-51	Classroom sink, room 126	3.0		µg/L	
269-132-SK-52	Classroom sink, room 132	4.0		µg/L	
269-133-SK-53	Classroom sink, room 133	3.0		µg/L	
269-143-SK-54	Classroom sink, room 143	5.0		µg/L	
269-134-SK-55	Classroom sink, room 134	5.0		µg/L	
269-142-SK-56	Classroom sink, room 142	15.0	3.0	µg/L	Faucet replaced 6/2018
269-135-SK-57	Classroom sink, room 135	2.0		µg/L	
269-141-SK-58	Classroom sink, room 141	18.0	5.0	µg/L	Faucet replaced 6/2018
269-136-SK-59	Classroom sink, room 136	7.0		µg/L	
269-140-SK-60	Classroom sink, room 140	2.0		µg/L	
269-137-SK-61	Classroom sink, room 137	3.0		µg/L	
269-138-SK-62	Classroom sink, room 138	6.0		µg/L	
269-139-SK-63	Classroom sink, room 139	7.0		µg/L	

*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.