

**Smith Elementary (275) – 3590 Jasmine St.**

***SY 2019/2020 Long Term Sampling – Action Level 10 µg/L***

***Sample Date: 01/23/2020***

<b>Sample ID</b>	<b>Location Description</b>	<b>Lead Result (µg/L)</b>
<b>275-121-SK01-01</b>	Kitchen sink, east wall, left	7.7
<b>275-121-SK02-01</b>	Kitchen sink, east wall, center	3.5
<b>275-121-SK03-01</b>	Kitchen sink, east wall, right	3.5
<b>275-119-DF01-01</b>	Drinking fountain, gym, north end	1.7
<b>275-119-DF02-01</b>	Drinking fountain, gym, south end	3.6
<b>275-123D-SK01-01</b>	Lounge sink, room 123D	3.4
<b>275-117-DF01-01</b>	Drinking fountain, hallway 117	3.5
<b>275-101F-SK01-01</b>	Nurse sink, room 101F	9.7
<b>275-100-DF01-01</b>	Drinking fountain, hallway 100, across from 104	5.5
<b>275-114-DF01-01</b>	Drinking fountain, room 114	5.2
<b>275-113-DF01-01</b>	Drinking fountain, room 113	7.3
<b>275-100-DF02-01</b>	Drinking fountain, hallway 100, across from 109	6.0
<b>275-200-DF03-01</b>	Drinking fountain, hallway 200, across from 209	2.2
<b>275-200-DF02-01</b>	Drinking fountain, hallway 200, across from 204	5.1
<b>275-200-DF01-01</b>	Drinking fountain, hallway 200, across from 216	6.9

**Sample ID Key:**

Building number – room number – fixture type count – long term count

## Phase I & II Sampling – Action Level 15 µg/L

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 8/30/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
275-121-SK-01	Kitchen sink, east wall, left	4.4		µg/L	
275-121-SK-02	Kitchen sink, east wall, center	3.2		µg/L	
275-121-SK-03	Kitchen sink, east wall, right	3.2		µg/L	
275-119-DF-04	Drinking fountain, gym, south end	4.2		µg/L	
275-119-DF-05	Drinking fountain, gym, north end	2.3		µg/L	
275-123D-SK-06	Lounge sink, room 123D	3.6		µg/L	
275-101F-SK-07	Nurse sink, room 101F	7.1		µg/L	
275-117-DF-08	Drinking fountain, hallway 117, left bubbler	2.5		µg/L	
275-117-DF-09	Drinking fountain, hallway 117, right bubbler	2.2		µg/L	
275-100-DF-10	Drinking fountain, hallway 100, across from 104, left bubbler	4.6		µg/L	
275-100-DF-11	Drinking fountain, hallway 100, across from 104, right bubbler	1.5		µg/L	
275-114-DF-12	Drinking fountain, room 114	4.0		µg/L	
275-113-DF-13	Drinking fountain, room 113	4.5		µg/L	
275-100-DF-14	Drinking fountain, hallway 100, across from 109, left bubbler	7.6		µg/L	
275-100-DF-15	Drinking fountain, hallway 100, across from 109, right bubbler	4.0		µg/L	
275-200-DF-16	Drinking fountain, hallway 200, across from 209, left bubbler	2.1		µg/L	
275-200-DF-17	Drinking fountain, hallway 200, across from 209, right bubbler	1.8		µg/L	
275-200-DF-18	Drinking fountain, hallway 200, across from 204, left bubbler	4.9		µg/L	
275-200-DF-19	Drinking fountain, hallway 200, across from 204, right bubbler	2.1		µg/L	
275-200-DF-20	Drinking fountain, hallway 200, across from 216, left bubbler	8.2		µg/L	
275-200-DF-21	Drinking fountain, hallway 200, across from 216, right bubbler	6.6		µg/L	
Phase II Sampled on 3/3/2017					
275-102-SK-22	Classroom sink, room 102	16.0	9.0	µg/L	Faucet replaced 9/2018
275-103-SK-23	Classroom sink, room 103	4.0		µg/L	
275-104-SK-24	Classroom sink, room 104	6.0		µg/L	

<b>275-105-SK-25</b>	Classroom sink, room 105	5.0		µg/L	
<b>275-106-SK-26</b>	Classroom sink, room 106	6.0		µg/L	
<b>275-107-SK-27</b>	Classroom sink, room 107	2.0		µg/L	
<b>275-108-SK-28</b>	Classroom sink, room 108	8.0		µg/L	
<b>275-109-SK-29</b>	Classroom sink, room 109	14.0		µg/L	
<b>275-111-SK-30</b>	Classroom sink, room 111	9.0		µg/L	
<b>275-112-SK-31</b>	Classroom sink, room 112	15.0	14.0	µg/L	Faucet replaced 9/2018
<b>275-113-SK-32</b>	Classroom sink, room 113	7.0		µg/L	
<b>275-114-SK-33</b>	Classroom sink, room 114	9.0		µg/L	
<b>275-115-SK-34</b>	Classroom sink, room 115	12.0		µg/L	
<b>275-217-SK-35</b>	Office sink, room 217	14.0		µg/L	
<b>275-201A-SK-36</b>	LMC/IMC office sink, room 201A	9.0		µg/L	
<b>275-202-SK-37</b>	Classroom sink, room 202	6.0		µg/L	
<b>275-203-SK-38</b>	Classroom sink, room 203	4.0		µg/L	
<b>275-204-SK-39</b>	Classroom sink, room 204	6.0		µg/L	
<b>275-205-SK-40</b>	Classroom sink, room 205	4.0		µg/L	
<b>275-206-SK-41</b>	Classroom sink, room 206	3.0		µg/L	
<b>275-207-SK-42</b>	Classroom sink, room 207	5.0		µg/L	
<b>275-208-SK-43</b>	Classroom sink, room 208	13.0		µg/L	
<b>275-209-SK-44</b>	Classroom sink, room 209	14.0		µg/L	
<b>275-210-SK-45</b>	Classroom sink, room 210	9.0		µg/L	
<b>275-211-SK-46</b>	Classroom sink, room 211	7.0		µg/L	
<b>275-212-SK-47</b>	Classroom sink, room 212	8.0		µg/L	
<b>275-213-SK-48</b>	Classroom sink, room 213	10.0		µg/L	
<b>275-214-SK-49</b>	Classroom sink, room 214	7.0		µg/L	
<b>275-215-SK-50</b>	Classroom sink, room 215	4.0		µg/L	
<b>275-216-SK-51</b>	Classroom sink, room 216	11.0		µg/L	