DEVICES IN CLOSET



SINGLE STROBE
IN DATA CLOSET

*NOTE: MR51E TO BE INSTALLED IN STI-EM08073.5 ENCLOSURE



DEVICES - 1-#18 AWG 4 CONDUCTOR STRANDED, NON-SHIELDED, PLENUM RATED CABLE (TYPICAL)

FIELD DEVICES



STROBE
SYSTEM SENSOR
SWK-P w/BLUE
LENSE

*PIN OUT WILL VARY FROM MR51E

MULTIPLE STROBES
IN DATA CLOSET







STROBE
SYSTEM SENSOR
SWK-P w/BLUE
LENSE



STROBE
SYSTEM SENSOR
SWK-P w/BLUE
LENSE

*NOTE: EP1502 & AL600ULXB TO BE INSTALLED IN ALTRONIX TROVE1M1 ENCLOSURE

DPS Denver Public Schools	FACILITY PLANNING DEPT. Asset Management Program				
DRAWN BY ADH	SPECIFICATION SECTION ELECTRONIC SAFETY AND SECURITY				
DATE 06/2019	SCALE no scale	DWG NO. 28 47 00-1		REV 0	
CHECKED	DATE			SHEET 1 of 1	