

Green Valley Elementary (282)

All results below 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/6/2016				
Sample ID	Sample Description	Lead Result	Units	Action
282-135-SK-01	Kitchen prep sink, west wall	0.2	µg/L	
282-100-DF-02	Drinking fountain, hallway 100, outside of gymnasium, left bubbler	0.2	µg/L	
282-100-DF-03	Drinking fountain, hallway 100, outside of gymnasium, right bubbler	<0.1* ¹	µg/L	
282-136-DF-04	Drinking fountain, gymnasium, next to double doors	0.2	µg/L	
282-139-DF-05	Drinking fountain, hallway 136, across from room 140, left bubbler (right side INOP)	0.2	µg/L	
282-155-DF-06	Drinking fountain, hallway 155, across from room 157, left bubbler	<0.1	µg/L	
282-155-DF-07	Drinking fountain, hallway 155, across from room 157, right bubbler	0.1	µg/L	
282-101E-SK-08	Staff lounge sink, room 101D	0.2	µg/L	
282-101F-SK-09	Nurse sink, room 101F	0.2	µg/L	
282-118-DF-10	Drinking fountain, room 118	0.4	µg/L	
282-117-DF-11	Drinking fountain, room 117	<0.1	µg/L	
282-116-DF-12	Drinking fountain, room 116	1.0	µg/L	
282-115-DF-13	Drinking fountain, room 115	0.2	µg/L	
282-109-DF-14	Drinking fountain, room 109	0.2	µg/L	
282-108-DF-15	Drinking fountain, room 108	0.1	µg/L	
282-104-DF-16	Drinking fountain, hallway 104, across from room 106, left bubbler	<0.1	µg/L	
282-104-DF-17	Drinking fountain, hallway 104, across from room 106, right bubbler	0.3	µg/L	
282-122-DF-18	Drinking fountain, hallway 122, across from room 124, left bubbler	<0.1	µg/L	
282-122-DF-19	Drinking fountain, hallway 122, across from room 124, right bubbler	0.2	µg/L	
Phase II Sampled on 4/20/2017				
282-129-SK-20	Classroom sink, room 129	<1.0* ²	µg/L	
282-130-SK-21	Classroom sink, room 130	<1.0	µg/L	
282-131-SK-22	Classroom sink, room 131	<1.0	µg/L	
282-132-SK-23	Classroom sink, room 132	<1.0	µg/L	
282-123-SK-24	Classroom sink, room 123	<1.0	µg/L	
282-124-SK-25	Classroom sink, room 124	<1.0	µg/L	
282-125-SK-26	Classroom sink, room 125	<1.0	µg/L	
282-118-SK-27	Classroom sink, room 118	<1.0	µg/L	
282-117-SK-28	Classroom sink, room 117	<1.0	µg/L	
282-116-SK-29	Classroom sink, room 116	<1.0	µg/L	
282-115-SK-30	Classroom sink, room 115	<1.0	µg/L	
282-109-SK-31	Classroom sink, room 109	<1.0	µg/L	

282-108-SK-32	Classroom sink, room 108	<1.0	µg/L
282-107-SK-33	Classroom sink, room 107	<1.0	µg/L
282-106-SK-34	Classroom sink, room 106	<1.0	µg/L
282-105-SK-35	Classroom sink, room 105	<1.0	µg/L
282-159-SK-36	Classroom sink, room 159	<1.0	µg/L
282-158-SK-37	Classroom sink, room 158	<1.0	µg/L
282-157-SK-38	Classroom sink, room 157	<1.0	µg/L
282-156-SK-39	Classroom sink, room 156	<1.0	µg/L
282-153-SK-40	Classroom sink, room 153	<1.0	µg/L
282-152-SK-41	Classroom sink, room 152	<1.0	µg/L
282-151-SK-42	Classroom sink, room 151	<1.0	µg/L
282-148-SK-43	Faculty workroom sink, room 148	<1.0	µg/L
282-147-SK-44	Classroom sink, room 147	<1.0	µg/L
282-146-SK-45	Classroom sink, room 146	<1.0	µg/L
282-141-SK-46	Classroom sink, room 141	<1.0	µg/L
282-140-SK-47	Classroom sink, room 140	<1.0	µg/L
282-162-SK-48	Classroom sink, room 162	<1.0	µg/L

*1. Result less than <0.1 ppb which is the lowest level that can be reported by the external lab.

*2. Result less than <1.0 ppb which is the lowest level that can be reported by the lab.