

Traylor Elementary (283)

August 2017: All issues addressed, results below action level, no further actions at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/22/2016					
Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
283-121-df-01	Drinking fountain, cafeteria, south wall, next to gym and kitchen	7.3		µg/L	
283-121-df-02	Drinking fountain, cafeteria, west wall	1.2		µg/L	
283-123-df-03	Drinking fountain, gymnasium, left bubbler	4.5		µg/L	
283-123-df-04	Drinking fountain, gymnasium, right bubbler	2.0		µg/L	
283-120-df-05	Drinking fountain, hallway 120, next to cafeteria	<1.0*1		µg/L	
283-100-df-06	Drinking fountain, hallway 100, next to room 111	<1.0		µg/L	
283-100-df-07	Drinking fountain, hallway 100, next to room 106	5.0		µg/L	
283-200-df-08	Drinking fountain, hallway 200, next to room 206	<1.0		µg/L	
283-200-df-09	Drinking fountain, hallway 200, next to room 212	<1.0		µg/L	
283-100F-SK-10	Lounge sink, room 100F	2.5		µg/L	
283-122-SK-11	Kitchen sink, right faucet	2.1		µg/L	
283-122-SK-12	Kitchen sink, left faucet	1.9		µg/L	
283-122-SK-13	Kitchen, kettle faucet	6.9		µg/L	
283-122-SK-14	Kitchen, prep sprayer	4.1		µg/L	
Phase II Sampled on 3/24/2017					
283-113-SK-15	Classroom sink, room 113	2.0		µg/L	
283-114-SK-16	Classroom sink, room 114	3.0		µg/L	
283-112-SK-17	Classroom sink, room 112	<1.0		µg/L	
283-111-SK-18	Classroom sink, room 111	3.0		µg/L	
283-110-SK-19	Classroom sink, room 110	2.0		µg/L	
283-104-SK-20	Classroom sink, room 104	2.0		µg/L	
283-109-SK-21	Classroom sink, room 109	2.0		µg/L	
283-105-SK-22	Classroom sink, room 105	16.0	<2.0*2	µg/L	Faucet replaced 7/25/2017
283-108-SK-23	Classroom sink, room 108	2.0		µg/L	
283-107-SK-24	Classroom sink, room 107	2.0		µg/L	
283-106-SK-25	Classroom sink, room 106	3.0		µg/L	
283-216-SK-26	Classroom sink, room 216	<1.0		µg/L	
283-201-SK-27	Classroom sink, room 201	3.0		µg/L	
283-215-SK-28	Classroom sink, room 215	1.0		µg/L	
283-202-SK-29	Classroom sink, room 202	1.0		µg/L	

283-214-SK-30	Classroom sink, room 214	4.0	µg/L
283-210-SK-31	Classroom sink, room 210	3.0	µg/L
283-204-SK-32	Classroom sink, room 204	1.0	µg/L
283-205-SK-33	Classroom sink, room 205	4.0	µg/L
283-209-SK-34	Classroom sink, room 209	2.0	µg/L
283-206-SK-35	Classroom sink, room 206	3.0	µg/L
283-208-SK-36	Classroom sink, room 208	5.0	µg/L
283-207-SK-37	Classroom sink, room 207	10.0	µg/L
283-103C-SK-38	Admin office sink, room 103C	<1.0	µg/L
283-103F-SK-39	Admin workroom sink, room 103F	4.0	µg/L
283-223-SK-40	Classroom sink, room 223	8.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.

*2. Follow up sampling occurred on 8/29/2017 and tested with a Palintest SA1100 scanning analyzer.