

Maxwell Elementary (290)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/5/2016				
Sample ID	Sample Description	Lead Result	Units	Action
290-198-DF-01	Drinking fountain, hallway 198, across from room 182, left bubbler	<1.0* ¹	µg/L	
290-198-DF-02	Drinking fountain, hallway 198, across from room 182, right bubbler	<1.0	µg/L	
290-182-SK-03	Classroom sink, room 182	<1.0	µg/L	
290-184-SK-04	Classroom sink, room 184	1.1	µg/L	
290-185-SK-05	Classroom sink, room 185	<1.0	µg/L	
290-203-SK-06	Classroom sink, room 203	<1.0	µg/L	
290-198-DF-07	Drinking fountain, hallway 198, across from room 206, left bubbler	<1.0	µg/L	
290-198-DF-08	Drinking fountain, hallway 198, across from room 206, right bubbler	<1.0	µg/L	
290-H100-DF-09	Drinking fountain, hallway H100, next to gym entrance, left bubbler	<1.0	µg/L	
290-H100-DF-10	Drinking fountain, hallway H100, next to gym entrance, right bubbler	<1.0	µg/L	
290-168-DF-11	Drinking fountain, gymnasium	<1.0	µg/L	
290-142-SK-12	Nurse sink, room 142	<1.0	µg/L	
290-144-SK-13	Staff lounge sink, room 144	<1.0	µg/L	
290-107-SK-14	Classroom sink, room 107	<1.0	µg/L	
290-106-SK-15	Classroom sink, room 106	<1.0	µg/L	
290-102-SK-16	Classroom sink, room 102	<1.0	µg/L	
290-117-DF-17	Drinking fountain, hallway 117, across from room 102, left bubbler	<1.0	µg/L	
290-117-DF-18	Drinking fountain, hallway 117, across from room 102, right bubbler	<1.0	µg/L	
290-101-DF-19	Drinking fountain, room 101	<1.0	µg/L	
290-148-SK-20	Kitchen sink, left faucet off of 3 compartment	<1.0	µg/L	
290-148-SK-21	Kitchen kettle fill, next to flat top	<1.0	µg/L	
290-148-SK-22	Kitchen food prep sink	<1.0	µg/L	
290-122-DF-23	Drinking fountain, room 122	<1.0	µg/L	
290-123-DF-24	Drinking fountain, room 123	<1.0	µg/L	
290-125-SK-25	Classroom sink, room 125	2.5	µg/L	
290-117-DF-26	Drinking fountain, hallway 117, next to room 131, left bubbler	<1.0	µg/L	
290-117-DF-27	Drinking fountain, hallway 117, next to room 131, right bubbler	<1.0	µg/L	
290-127-SK-28	Classroom sink, room 127	<1.0	µg/L	
Phase II Sampled on 4/21/2017				
290-105-SK-29	Classroom sink, room 105	<1.0	µg/L	
290-104-SK-30	Classroom sink, room 104	<1.0	µg/L	
290-103-SK-31	Classroom sink, room 103	<1.0	µg/L	

290-101-SK-32	Classroom sink, room 101	<1.0	µg/L
290-122-SK-33	Classroom sink, room 122	<1.0	µg/L
290-123-SK-34	Classroom sink, room 123	<1.0	µg/L
290-126-SK-35	Classroom sink, room 126	<1.0	µg/L
290-180-SK-36	Classroom sink, room 180	<1.0	µg/L
290-181-SK-37	Classroom sink, room 181	<1.0	µg/L
290-182-SK-38	Classroom sink, room 182	<1.0	µg/L
290-183-SK-39	Classroom sink, room 183	<1.0	µg/L
290-175-SK-40	Faculty workroom sink, room 175	<1.0	µg/L
290-202-SK-41	Classroom sink, room 202	<1.0	µg/L
290-204-SK-42	Classroom sink, room 204	<1.0	µg/L
290-205-SK-43	Classroom sink, room 205	<1.0	µg/L
290-206-SK-44	Classroom sink, room 206	<1.0	µg/L

*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.