

Denver Center for 21st Century Learning @ Wyman (291)

All results less than 15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 9/21/2016				
Sample ID	Sample Description	Lead Result	Units	Action
291-110-DF-01	Drinking fountain, hallway 110, across from LMC	1.1	µg/L	
291-113-DF-02	Drinking fountain, all purpose room 113, west corner	2.2	µg/L	
291-113-DF-03	Drinking fountain, all purpose room 113, east corner	<1.0* ¹	µg/L	
291-115-DF-04	Drinking fountain, gymnasium, east wall	5.1	µg/L	
291-118-DF-05	Drinking fountain, room 118	<1.0	µg/L	
291-117-DF-06	Drinking fountain, room 117	6.0	µg/L	
291-121-SK-07	Classroom sink, room 121	1.5	µg/L	
291-120-DF-08	Drinking fountain, hallway 120, across from room 122	<1.0	µg/L	
291-123-SK-09	Classroom sink, room 123	1.7	µg/L	
291-101B-SK-10	Nurse sink, room 101B	4.3	µg/L	
291-101K-SK-11	Admin office sink, room 101K	<1.0	µg/L	
291-102-SK-12	Sink, room 102	2.4	µg/L	
291-104-SK-13	Classroom sink, room 104	<1.0	µg/L	
291-100-DF-14	Drinking fountain, hallway 100, next to room 104	10.2	µg/L	
291-105-SK-15	Classroom sink, room 105	10.5	µg/L	
291-107-SK-16	Classroom sink, room 107	<1.0	µg/L	
291-109-SK-17	Classroom sink, room 109	13.6	µg/L	
291-114-SK-18	Kitchen prep sink, south end of kitchen	1.9	µg/L	
291-206-DF-19	Drinking fountain, hallway 206, between restrooms	1.6	µg/L	
Phase II Sampled on 4/13/2017				
291-112-SK-20	Staff office sink, room 112	2.0	µg/L	
291-119-SK-21	Classroom sink, room 119	5.0	µg/L	
291-117-SK-22	Classroom sink, room 117	<1.0	µg/L	
291-118-SK-23	Classroom sink, room 118	1.0	µg/L	
291-108-SK-24	Classroom sink, room 108	1.0	µg/L	
291-103-SK-25	Classroom sink, room 103, southeast corner	1.0	µg/L	
291-103-SK-26	Classroom sink, room 103, southwest corner	3.0	µg/L	
291-124-SK-27	Faculty lounge sink, room 124	1.0	µg/L	
291-122-SK-28	Classroom sink, room 122	<1.0	µg/L	
291-205-SK-29	Classroom sink, room 205	2.0	µg/L	
291-204-SK-30	Classroom sink, room 204	2.0	µg/L	
291-202-SK-31	Classroom sink, room 202, left sink	3.0	µg/L	

291-202-SK-32	Classroom sink, room 202, right sink	4.0	µg/L
291-201-SK-33	Classroom sink, room 201, left sink	6.0	µg/L
291-201-SK-34	Classroom sink, room 201, right sink	3.0	µg/L
291-210-SK-35	Classroom sink, room 210	2.0	µg/L
291-209-SK-36	Classroom sink, room 209	9.0	µg/L

*1. Result less than 1.0 ppb is the lowest level that can be reported by the lab.