

## Isabella Bird (301)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/14/2016				
Sample ID	Sample Description	Lead Result	Units	Action
301-128-DF-01	Drinking fountain, gymnasium, next to restrooms, left bubbler	<1.0* <sup>1</sup>	µg/L	
301-128-DF-02	Drinking fountain, gymnasium, next to restrooms, right bubbler	<1.0	µg/L	
301-127-SK-03	Kitchen prep sink, east wall	<1.0	µg/L	
301-127-SK-04	Kitchen prep sink, west of center wall	<1.0	µg/L	
301-125-SK-05	All-purpose sink, room 125, south wall	<1.0	µg/L	
301-101N-SK-06	Nurse sink, room 101N	<1.0	µg/L	
301-101K-SK-07	Staff lounge sink, room 101K	<1.0	µg/L	
301-100-DF-08	Drinking fountain, hallway 100, next to restrooms, left bubbler	<1.0	µg/L	
301-100-DF-09	Drinking fountain, hallway 100, next to restrooms, right bubbler	<1.0	µg/L	
301-103G-DF-10	Drinking fountain, hallway 103G, next to restrooms, left bubbler	<1.0	µg/L	
301-103G-DF-11	Drinking fountain, hallway 103G, next to restrooms, right bubbler	<1.0	µg/L	
301-117-DF-12	Drinking fountain, classroom 117	<1.0	µg/L	
301-116-DF-13	Drinking fountain, classroom 116	<1.0	µg/L	
301-115-DF-14	Drinking fountain, classroom 115	<1.0	µg/L	
301-114-DF-15	Drinking fountain, classroom 114	<1.0	µg/L	
301-111-DF-16	Drinking fountain, classroom 111	<1.0	µg/L	
301-112-DF-17	Drinking fountain, classroom 112	<1.0	µg/L	
301-113-DF-18	Drinking fountain, classroom 113	<1.0	µg/L	
301-211D-DF-19	Drinking fountain, hallway 211D, next to restrooms, left bubbler	<1.0	µg/L	
301-211D-DF-20	Drinking fountain, hallway 211D, next to restrooms, right bubbler	<1.0	µg/L	
301-208-SK-21	Classroom sink, room 208	<1.0	µg/L	
301-127-SK-22	Kitchen kettle fill faucet	<1.0	µg/L	
Phase II Sampled on 5/4/2017				
301-125A-SK-23	PTA kitchen sink, room 125A	<1.0	µg/L	
301-104-SK-24	Classroom sink, room 104, left sink	<1.0	µg/L	
301-104-SK-25	Classroom sink, room 104, right sink	<1.0	µg/L	
301-105-SK-26	Classroom sink, room 105, left sink	<1.0	µg/L	
301-105-SK-27	Classroom sink, room 105, right sink	<1.0	µg/L	
301-106-SK-28	Classroom sink, room 106, left sink	<1.0	µg/L	
301-106-SK-29	Classroom sink, room 106, right sink	<1.0	µg/L	
301-107-SK-30	Classroom sink, room 107, left sink	<1.0	µg/L	
301-107-SK-31	Classroom sink, room 107, right sink	<1.0	µg/L	
301-108-SK-32	Classroom sink, room 108, left sink	<1.0	µg/L	
301-108-SK-33	Classroom sink, room 108, right sink	<1.0	µg/L	
301-109-SK-34	Classroom sink, room 109, left sink	<1.0	µg/L	
301-109-SK-35	Classroom sink, room 109, right sink	<1.0	µg/L	
301-121-SK-36	Classroom sink, room 121, left sink	<1.0	µg/L	

<b>301-121-SK-37</b>	Classroom sink, room 121, right sink	<1.0	µg/L
<b>301-119-SK-38</b>	Workroom sink, room 119	<1.0	µg/L
<b>301-117-SK-39</b>	Classroom sink, room 117, hand sink next to drinking fountain	<1.0	µg/L
<b>301-117-SK-40</b>	Classroom sink, room 117, counter sink	<1.0	µg/L
<b>301-116-SK-41</b>	Classroom sink, room 116, hand sink next to drinking fountain	<1.0	µg/L
<b>301-116-SK-42</b>	Classroom sink, room 116, counter sink	<1.0	µg/L
<b>301-115-SK-43</b>	Classroom sink, room 115, hand sink next to drinking fountain	<1.0	µg/L
<b>301-115-SK-44</b>	Classroom sink, room 115, counter sink	<1.0	µg/L
<b>301-114-SK-45</b>	Classroom sink, room 114, left sink	1.0	µg/L
<b>301-114-SK-46</b>	Classroom sink, room 114, right sink	<1.0	µg/L
<b>301-113-SK-47</b>	Classroom sink, room 113, counter sink	<1.0	µg/L
<b>301-113-SK-48</b>	Classroom sink, room 113, hand sink	<1.0	µg/L
<b>301-112-SK-49</b>	Classroom sink, room 112, left sink	<1.0	µg/L
<b>301-112-SK-50</b>	Classroom sink, room 112, right sink	<1.0	µg/L
<b>301-111-SK-51</b>	Classroom sink, room 111, left sink	<1.0	µg/L
<b>301-111-SK-52</b>	Classroom sink, room 111, right sink	<1.0	µg/L
<b>301-212-SK-53</b>	Classroom sink, room 212, left sink	<1.0	µg/L
<b>301-212-SK-54</b>	Classroom sink, room 212, right sink	<1.0	µg/L
<b>301-210-SK-55</b>	Classroom sink, room 210, left sink	<1.0	µg/L
<b>301-210-SK-56</b>	Classroom sink, room 210, right sink	<1.0	µg/L
<b>301-209-SK-57</b>	Classroom sink, room 209, left sink	<1.0	µg/L
<b>301-209-SK-58</b>	Classroom sink, room 209, right sink	<1.0	µg/L
<b>301-208-SK-59</b>	Classroom sink, room 208, left sink	<1.0	µg/L
<b>301-207-SK-60</b>	Classroom sink, room 207, left sink	<1.0	µg/L
<b>301-207-SK-61</b>	Classroom sink, room 207, right sink	<1.0	µg/L
<b>301-206-SK-62</b>	Classroom sink, room 206, right sink	<1.0	µg/L
<b>301-206-SK-63</b>	Classroom sink, room 206, left sink	<1.0	µg/L
<b>301-205-SK-64</b>	Classroom sink, room 205, left sink	<1.0	µg/L
<b>301-205-SK-35</b>	Classroom sink, room 205, right sink	<1.0	µg/L
<b>301-204-SK-66</b>	Classroom sink, room 204, left sink	<1.0	µg/L
<b>301-204-SK-67</b>	Classroom sink, room 204, right sink	<1.0	µg/L
<b>301-203-SK-68</b>	Classroom sink, room 203, left sink	<1.0	µg/L
<b>301-203-SK-69</b>	Classroom sink, room 203, right sink	<1.0	µg/L
<b>301-202-SK-70</b>	Classroom sink, room 202, left sink	<1.0	µg/L
<b>301-202-SK-71</b>	Classroom sink, room 202, right sink	<1.0	µg/L
<b>301-214-SK-72</b>	Classroom sink, room 214, far left sink	<1.0	µg/L
<b>301-214-SK-73</b>	Classroom sink, room 214, center left sink	<1.0	µg/L
<b>301-214-SK-74</b>	Classroom sink, room 214, center right sink	<1.0	µg/L
<b>301-214-SK-75</b>	Classroom sink, room 214, far right sink	<1.0	µg/L

\*1. Result less than 1.0 ppb which is the lowest level that can be reported by the lab.