

## High Tech Elementary at Conservatory Green (302)

All results <15 ppb – No further action at this time.

### Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 11/4/2016

Sample ID	Sample Description	Lead Result	Units	Action
302-118-SK-01	Kitchen kettle fill, room 118, center of kitchen	0.3	µg/L	
302-118-SK-02	Kitchen prep sink, room 118, near 118B	0.6	µg/L	
302-115-DF-03	Drinking fountain, gymnasium 115, next to 115F, left bubbler	<0.1*	µg/L	
302-115-DF-04	Drinking fountain, gymnasium 115, next to 115F, right bubbler	<0.1	µg/L	
302-115-DF-05	Drinking fountain, gymnasium 115, next to 115E, left bubbler	<0.1	µg/L	
302-115-DF-06	Drinking fountain, gymnasium 115, next to 115E, right bubbler	0.1	µg/L	
302-100-DF-07	Drinking fountain, hallway 100, next to room 100D, left bubbler	0.2	µg/L	
302-100-DF-08	Drinking fountain, hallway 100, next to room 100D, center bubbler	0.2	µg/L	
302-100-DF-09	Drinking fountain, hallway 100, next to room 100D, right bubbler	0.1	µg/L	
302-104-DF-10	Drinking fountain, room 104	0.2	µg/L	
302-111-DF-11	Drinking fountain, room 110	0.3	µg/L	
302-106-DF-12	Drinking fountain, room 106	0.1	µg/L	
302-109-DF-13	Drinking fountain, room 109	<0.1	µg/L	
302-107-DF-14	Drinking fountain, room 107	0.2	µg/L	
302-108-DF-15	Drinking fountain, room 108	0.3	µg/L	
302-101B-SK-16	LMC/IMC workroom sink, room 101B	0.2	µg/L	
302-135L-SK-17	Faculty lounge sink, room 135L	0.1	µg/L	
302-135BB-SK-18	Nurse sink, room 135BB	0.3	µg/L	
302-124-DF-19	Drinking fountain, hallway 124, next to 126, left bubbler	<0.1	µg/L	
302-124-DF-20	Drinking fountain, hallway 124, next to 126, center bubbler	<0.1	µg/L	
302-124-DF-21	Drinking fountain, hallway 124, next to 126, right bubbler	<0.1	µg/L	
302-128-SK-22	Classroom sink, room 128	0.5	µg/L	
302-130-SK-23	Classroom sink, room 130	0.2	µg/L	
302-131-SK-24	Classroom sink, room 131	0.2	µg/L	
302-202-DF-25	Drinking fountain, hallway 202, next to 202E, far left bubbler	<0.1	µg/L	
302-202-DF-26	Drinking fountain, hallway 202, next to 202E, center left bubbler	<0.1	µg/L	
302-202-DF-27	Drinking fountain, hallway 202, next to 202E, center right bubbler	<0.1	µg/L	
302-202-DF-28	Drinking fountain, hallway 202, next to 202E, far right bubbler	<0.1	µg/L	
302-226-SK-29	Classroom sink, room 226	0.2	µg/L	
302-224-DF-30	Drinking fountain, hallway 224, next to room 227, left bubbler	<0.1	µg/L	
302-224-DF-31	Drinking fountain, hallway 224, next to room 227, center bubbler	<0.1	µg/L	
302-224-DF-32	Drinking fountain, hallway 224, next to room 227, right bubbler	<0.1	µg/L	

<b>302-229-SK-33</b>	Classroom sink, room 229	0.3	µg/L
<b>302-230-SK-34</b>	Classroom sink, room 230	0.1	µg/L
<b>302-231-SK-35</b>	Classroom sink, room 231	0.2	µg/L
<b>302-233-SK-36</b>	Classroom sink, room 233	0.2	µg/L
<b>302-234-SK-37</b>	Classroom sink, room 234	0.2	µg/L
<b>302-235-SK-38</b>	Classroom sink, room 235	0.2	µg/L
<b>302-119-SK-39</b>	Community room sink, north wall, room 119	<0.1	µg/L
<b>Phase II Sampled on 10/4/2017</b>			
<b>302-109-SK-40</b>	Classroom sink, room 109, counter sink	0.2	µg/L
<b>302-109-SK-41</b>	Classroom sink, room 109, hand sink	0.6	µg/L
<b>302-107-SK-42</b>	Classroom sink, room 107, counter sink	0.8	µg/L
<b>302-107-SK-43</b>	Classroom sink, room 107, hand sink	1.4	µg/L
<b>302-106-SK-44</b>	Classroom sink, room 106, counter sink	0.2	µg/L
<b>302-106-SK-45</b>	Classroom sink, room 106, hand sink	0.3	µg/L
<b>302-110-SK-46</b>	Classroom sink, room 110, counter sink	0.3	µg/L
<b>302-110-SK-47</b>	Classroom sink, room 110, hand sink	0.2	µg/L
<b>302-104-SK-48</b>	Classroom sink, room 104, counter sink	0.6	µg/L
<b>302-104-SK-49</b>	Classroom sink, room 104, hand sink	0.4	µg/L
<b>302-103-SK-50</b>	Art room sink, room 103, left sink	0.2	µg/L
<b>302-103-SK-51</b>	Art room sink, room 103, right sink	0.4	µg/L
<b>302-102-SK-52</b>	Art room sink, room 102, south wall, left sink	0.3	µg/L
<b>302-102-SK-53</b>	Art room sink, room 102, south wall, center sink	0.4	µg/L
<b>302-102-SK-54</b>	Art room sink, room 102, south wall, right sink	0.1	µg/L
<b>302-102-SK-55</b>	Art room sink, room 102, north wall	0.9	µg/L
<b>302-112-SK-56</b>	Music room sink, room 112	0.8	µg/L
<b>302-119-SK-57</b>	Community room sink, room 119	<0.1	µg/L
<b>302-121-SK-58</b>	Classroom sink, room 121	1.5	µg/L
<b>302-134-SK-59</b>	Classroom sink, room 134	0.5	µg/L
<b>302-133-SK-60</b>	Classroom sink, room 133	0.9	µg/L
<b>302-132-SK-61</b>	Classroom sink, room 132	0.2	µg/L
<b>302-129-SK-62</b>	Classroom sink, room 129	0.1	µg/L
<b>302-125-SK-63</b>	Classroom sink, room 125	0.4	µg/L
<b>302-125A-SK-64</b>	Workroom sink, room 125A	0.1	µg/L
<b>302-108-SK-65</b>	Classroom sink, room 107, counter sink	0.2	µg/L
<b>302-108-SK-66</b>	Classroom sink, room 107, hand sink	0.2	µg/L
<b>302-218-SK-67</b>	Classroom sink, room 218	0.6	µg/L
<b>302-217-SK-68</b>	Classroom sink, room 217	0.2	µg/L
<b>302-216-SK-69</b>	Classroom sink, room 216	0.3	µg/L
<b>302-215-SK-70</b>	Classroom sink, room 215	0.2	µg/L
<b>302-213-SK-71</b>	Classroom sink, room 213	0.2	µg/L
<b>302-212-SK-72</b>	Classroom sink, room 212	0.4	µg/L
<b>302-211-SK-73</b>	Classroom sink, room 211	0.4	µg/L

<b>302-210-SK-74</b>	Classroom sink, room 210	0.4	µg/L
<b>302-209-SK-75</b>	Classroom sink, room 209	0.8	µg/L
<b>302-207-SK-76</b>	Classroom sink, room 207	0.1	µg/L
<b>302-206-SK-77</b>	Classroom sink, room 206	0.6	µg/L
<b>302-201-SK-78</b>	Classroom sink, room 201, left sink	0.1	µg/L
<b>302-201-SK-79</b>	Classroom sink, room 201, right sink	0.2	µg/L
<b>302-220-SK-80</b>	Science lab sink, room 220, north wall, left sink	0.4	µg/L
<b>302-220-SK-81</b>	Science lab sink, room 220, north wall, right sink	0.4	µg/L
<b>302-220-SK-82</b>	Science lab sink, room 220, east wall, left sink	2.6	µg/L
<b>302-220-SK-83</b>	Science lab sink, room 220, east wall, right sink	1.9	µg/L
<b>302-220A-SK-84</b>	Science prep room sink, room 220A	0.8	µg/L
<b>302-222A-SK-85</b>	Science prep room sink, room 222A	0.5	µg/L
<b>302-222-SK-86</b>	Science lab sink, room 222, north wall, left sink	0.3	µg/L
<b>302-222-SK-87</b>	Science lab sink, room 222, north wall, right sink	0.3	µg/L
<b>302-222-SK-88</b>	Science lab sink, room 222, east wall, left sink	0.2	µg/L
<b>302-222-SK-89</b>	Science lab sink, room 222, east wall, right sink	0.2	µg/L
<b>302-222-SK-90</b>	Science lab sink, room 222, south wall, left sink	0.1	µg/L
<b>302-222-SK-91</b>	Science lab sink, room 222, south wall, right sink	0.1	µg/L
<b>302-223-SK-92</b>	Science lab sink, room 223, west wall, left sink	0.2	µg/L
<b>302-223-SK-93</b>	Science lab sink, room 223, west wall, right sink	0.3	µg/L
<b>302-223-SK-94</b>	Science lab sink, room 223, north wall, left sink	0.2	µg/L
<b>302-223-SK-95</b>	Science lab sink, room 223, north wall, right sink	0.2	µg/L
<b>302-223-SK-96</b>	Science lab sink, room 223, south wall, left sink	0.1	µg/L
<b>302-223-SK-97</b>	Science lab sink, room 223, south wall, right sink	0.2	µg/L
<b>302-237-SK-98</b>	Classroom sink, room 237	0.1	µg/L
<b>302-236-SK-99</b>	Classroom sink room 236	0.1	µg/L
<b>302-225-SK-100</b>	Classroom sink, room 225	0.2	µg/L
<b>302-226-SK-101</b>	Classroom sink, room 226	0.1	µg/L
<b>302-232-SK-102</b>	Classroom sink, room 232	0.2	µg/L

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.