

Montbello Career and Technical HS at CAE Bldg. (303)

All results <15 ppb – No further action at this time.

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/11/2016				
Sample ID	Sample Description	Lead Result	Units	Action
303-127A-DF-01	Drinking fountain, hallway 127A, next to restroom 113E, left bubbler	<0.1	µg/L	
303-127A-DF-02	Drinking fountain, hallway 127A, next to restroom 113E, right bubbler	<0.1	µg/L	
303-104-SK-03	Faculty lounge sink, room 104	0.2	µg/L	
303-101-DF-04	Drinking fountain, hallway 101, next to room 103, left bubbler	<0.1	µg/L	
303-101-DF-05	Drinking fountain, hallway 101, next to room 103, right bubbler	<0.1	µg/L	
303-101-DF-06	Drinking fountain, hallway 101, next to room 101A	<0.1	µg/L	
303-200-SK-07	Sink, lobby 200, east wall	0.9	µg/L	
303-201-DF-08	Drinking fountain, hallway 201, next to room 201D	0.2	µg/L	
303-201-DF-09	Drinking fountain, hallway 201, next to room 216, left bubbler	<0.1	µg/L	
303-201-DF-10	Drinking fountain, hallway 201, next to room 216, right bubbler	<0.1	µg/L	
Phase II Sampled on 10/6/2017				
303-113-SK-11	Shop sink, room 113	<1.0	µg/L	
303-115A-SK-12	Storage room sink, room 115A	4.0	µg/L	
303-103A-SK-13	Nurse office sink, room 103A	<1.0	µg/L	

*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.