

## DSST @ Byers (402)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 10/19/2016				
Sample ID	Sample Description	Lead Result	Units	Action
402-113A-SK-01	Kitchen sink, room 113A, north wall	<1.0*	µg/L	
402-113-SK-02	Kitchen sink, room 113, north wall	<1.0	µg/L	
402-112-DF-03	Drinking fountain, cafeteria, south wall, left bubbler	<1.0	µg/L	
402-112-DF-04	Drinking fountain, cafeteria, south wall, right bubbler	<1.0	µg/L	
402-114G-SK-05	Break room sink, room 114G, north wall	<1.0	µg/L	
402-117-DF-06	Drinking fountain, hallway 117, next to room 120, left bubbler	<1.0	µg/L	
402-117-DF-07	Drinking fountain, hallway 117, next to room 120, right bubbler	<1.0	µg/L	
402-105-DF-08	Drinking fountain, hallway 105, next to room 107, left bubbler	<1.0	µg/L	
402-105-DF-09	Drinking fountain, hallway 105, next to room 107, right bubbler	<1.0	µg/L	
402-205-DF-10	Drinking fountain, hallway 205, next to room 207, left bubbler	<1.0	µg/L	
402-205-DF-11	Drinking fountain, hallway 205, next to room 207, right bubbler	<1.0	µg/L	
402-223-DF-12	Drinking fountain, hallway 223, across from room 224, left bubbler	<1.0	µg/L	
402-223-DF-13	Drinking fountain, hallway 223, across from room 224, right bubbler	<1.0	µg/L	
402-228-DF-14	Drinking fountain, hallway 228, next to room 231, left bubbler	<1.0	µg/L	
402-228-DF-15	Drinking fountain, hallway 228, next to room 231, right bubbler	<1.0	µg/L	
402-06-DF-16	Drinking fountain, hallway 06, next to room 07	<1.0	µg/L	
402-00-DF-17	Drinking fountain, hallway 00, across from room OOD, left bubbler	<1.0	µg/L	
402-00-DF-18	Drinking fountain, hallway 00, across from room OOD, right bubbler	<1.0	µg/L	
402-14-DF-19	Drinking fountain, hallway 14, north wall next to room 16, left bubbler	<1.0	µg/L	
402-14-DF-20	Drinking fountain, hallway 14, north wall next to room 16, right bubbler	<1.0	µg/L	
402-17-DF-21	Drinking fountain, room 17, left bubbler	<1.0	µg/L	
402-17-DF-22	Drinking fountain, room 17, right bubbler	<1.0	µg/L	
402-21-DF-23	Drinking fountain, room 21, left bubbler	<1.0	µg/L	
402-21-DF-24	Drinking fountain, room 21, right bubbler	<1.0	µg/L	
402-19-DF-25	Drinking fountain, gymnasium, north wall, left bubbler	<1.0	µg/L	
402-19-DF-26	Drinking fountain, gymnasium, north wall, right bubbler	<1.0	µg/L	
402-19-DF-27	Drinking fountain, gymnasium, south wall, left bubbler	<1.0	µg/L	
402-19-DF-28	Drinking fountain, gymnasium, south wall, right bubbler	<1.0	µg/L	
402-00-DF-29	Drinking fountain, hallway 00, across from room 23, left bubbler	<1.0	µg/L	
402-00-DF-30	Drinking fountain, hallway 00, across from room 23, right bubbler	<1.0	µg/L	

402-24-DF-31	Drinking fountain, hallway 24, next to room 27, left bubbler	<1.0	µg/L
402-24-DF-32	Drinking fountain, hallway 24, next to room 27, right bubbler	<1.0	µg/L
402-28-DF-33	Drinking fountain, all purpose room 28, west wall, left bubbler	<1.0	µg/L
402-28-DF-34	Drinking fountain, all purpose room 28, west wall, right bubbler	<1.0	µg/L
402-29-SK-35	Drinking fountain, hallway 29, next to room 29F	<1.0	µg/L
<b>Phase II Sampled on 9/12/2017</b>			
402-210-SK-36	Science lab sink, room 210, south wall	<1.0	µg/L
402-210-SK-37	Science lab sink, room 210, east wall, far right sink	<1.0	µg/L
402-210-SK-38	Science lab sink, room 210, east wall, center right sink	<1.0	µg/L
402-210-SK-39	Science lab sink, room 210, east wall, center sink	<1.0	µg/L
402-210-SK-40	Science lab sink, room 210, east wall, center left sink	<1.0	µg/L
402-210-SK-41	Science lab sink, room 210, east wall, far left sink	<1.0	µg/L
402-210-SK-42	Science lab sink, room 210, north wall	<1.0	µg/L
402-210-SK-43	Science lab sink, room 210, demonstration sink	<1.0	µg/L
402-210A-SK-44	Science prep room sink, room 210A	<1.0	µg/L
402-202-SK-45	Science lab sink, room 202, north wall	<1.0	µg/L
402-202-SK-46	Science lab sink, room 202, west wall, far right sink	<1.0	µg/L
402-202-SK-47	Science lab sink, room 202, west wall, center right sink	<1.0	µg/L
402-202-SK-48	Science lab sink, room 202, west wall, center sink	<1.0	µg/L
402-202-SK-49	Science lab sink, room 202, west wall, center left sink	<1.0	µg/L
402-202-SK-50	Science lab sink, room 202, west wall, far left sink	<1.0	µg/L
402-202-SK-51	Science lab sink, room 202, south wall	<1.0	µg/L
402-202-SK-52	Science lab sink, room 202, demonstration sink	<1.0	µg/L
402-234-SK-53	Science lab sink, room 234, north wall, right sink	<1.0	µg/L
402-234-SK-54	Science lab sink, room 234, north wall, left sink	<1.0	µg/L
402-234-SK-55	Science lab sink, room 234, west wall, far right sink	<1.0	µg/L
402-234-SK-56	Science lab sink, room 234, west wall, center right sink	<1.0	µg/L
402-234-SK-57	Science lab sink, room 234, west wall, center left sink	<1.0	µg/L
402-234-SK-58	Science lab sink, room 234, west wall, far left sink	<1.0	µg/L
402-234-SK-59	Science lab sink, room 234, south wall	<1.0	µg/L
402-234-SK-60	Science lab sink, room 234, demonstration sink	<1.0	µg/L
402-225-SK-61	Workroom sink, room 225	<1.0	µg/L
402-227-SK-62	Classroom sink, room 227	<1.0	µg/L
402-111-SK-63	Science lab sink, room 111, west wall, right sink	<1.0	µg/L
402-111-SK-64	Science lab sink, room 111, east wall, far left sink	<1.0	µg/L
402-111-SK-65	Science lab sink, room 111, east wall, center left sink	<1.0	µg/L
402-111-SK-66	Science lab sink, room 111, east wall, center sink	<1.0	µg/L
402-111-SK-67	Science lab sink, room 111, east wall, center right sink	<1.0	µg/L
402-111-SK-68	Science lab sink, room 111, east wall, far right sink	<1.0	µg/L
402-111-SK-69	Science lab sink, room 111, east wall, demonstration sink	<1.0	µg/L
402-111-SK-70	Science lab sink, room 111, west wall, left sink	<1.0	µg/L
402-111A-SK-71	Science prep room sink, room 111A	<1.0	µg/L

<b>402-101-SK-72</b>	Science lab sink, room 101, north wall	<1.0	µg/L
<b>402-101-SK-73</b>	Science lab sink, room 101, west wall, far right sink	<1.0	µg/L
<b>402-101-SK-74</b>	Science lab sink, room 101, west wall, center right sink	<1.0	µg/L
<b>402-101-SK-75</b>	Science lab sink, room 101, west wall, center sink	<1.0	µg/L
<b>402-101-SK-76</b>	Science lab sink, room 101, west wall, center left sink	<1.0	µg/L
<b>402-101-SK-77</b>	Science lab sink, room 101, west wall, far left sink	<1.0	µg/L
<b>402-101-SK-78</b>	Science lab sink, room 101, south wall	<1.0	µg/L
<b>402-101-SK-79</b>	Science lab sink, room 101, demonstration sink	<1.0	µg/L
<b>402-124-SK-80</b>	Classroom sink, room 124	<1.0	µg/L
<b>402-122-SK-81</b>	Classroom sink, room 122	<1.0	µg/L
<b>402-09-SK-82</b>	Classroom sink, room 09, east wall	<1.0	µg/L
<b>402-09-SK-83</b>	Classroom sink, room 09, north wall, right sink	<1.0	µg/L
<b>402-09-SK-84</b>	Classroom sink, room 09, north wall, left sink	<1.0	µg/L
<b>402-08-SK-85</b>	Classroom sink, room 08	<1.0	µg/L
<b>402-07-SK-86</b>	Classroom sink, room 07	<1.0	µg/L
<b>402-13-SK-87</b>	Concessions sink, room 13	<1.0	µg/L
<b>402-34-SK-88</b>	Art room sink, room 34, north wall, right sink	<1.0	µg/L
<b>402-34-SK-89</b>	Art room sink, room 34, north wall, left sink	<1.0	µg/L
<b>402-34-SK-90</b>	Art room sink, room 34, south wall, left sink	<1.0	µg/L
<b>402-34-SK-91</b>	Art room sink, room 34, south wall, right sink	2.0	µg/L
<b>402-17-SK-92</b>	Training room sink, room 17	<1.0	µg/L
<b>402-33-SK-93</b>	Classroom sink, room 33	<1.0	µg/L
<b>402-31-SK-94</b>	Classroom sink, room 31	<1.0	µg/L
<b>402-30-SK-95</b>	Classroom sink, room 30, east wall, left sink	<1.0	µg/L
<b>402-30-SK-96</b>	Classroom sink, room 30, east wall, right sink	<1.0	µg/L

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.