

Hamilton Middle School (406)

Sample ID Key:

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled 10/27/2016

Sample ID	Sample Description	Lead Result	Units	Action
406-22A-DF-01	Drinking fountain, boys locker room 22A	0.3	µg/L	
406-21A-DF-02	Drinking fountain, girls locker room 21A	1.1	µg/L	
406-1-DF-03	Drinking fountain, hallway 1, across from room 6A	3.2	µg/L	
406-1-DF-04	Drinking fountain, hallway 1, next to room 3	3.7	µg/L	
406-1-DF-05	Drinking fountain, hallway 1, next to room 27	5.7	µg/L	
406-140-DF-06	Drinking fountain, hallway 140, next to stair A, across from room 129	0.2	µg/L	
406-146-DF-07	Drinking fountain, cafeteria 146, south wall, east of double doors	6.6	µg/L	
406-146-DF-08	Drinking fountain, cafeteria 146, south wall, west of double doors	3.5	µg/L	
406-142-DF-09	Drinking fountain, hallway 142, next to room 122	5.7	µg/L	
406-151-DF-10	Drinking fountain, north gymnasium 151, west wall	2.4	µg/L	
406-151-DF-11	Drinking fountain, north gymnasium 151, east wall	2.6	µg/L	
406-150-DF-12	Drinking fountain, south gymnasium 150, west wall	4.1	µg/L	
406-150-DF-13	Drinking fountain, south gymnasium 150, east wall	0.6	µg/L	
406-146A-SK-14	Kitchen prep sink, room 146A, east wall	3.2	µg/L	
406-146A-SK-15	Kitchen kettle fill, center of room 146A	7.0	µg/L	
406-146A-SK-16	Kitchen prep sink, room 146A, west wall	3.1	µg/L	
406-142-DF-17	Drinking fountain, hallway 142, next to room 127	4.2	µg/L	
406-101B-SK-18	Admin office sink, room 101B	0.9	µg/L	
406-102D-SK-19	Nurse sink, room 102D	1.9	µg/L	
406-140-DF-20	Drinking fountain, hallway 140, next to stair B, across from room 102	0.2	µg/L	
406-120-SK-21	Faculty lounge sink, room 120	3.0	µg/L	
406-140-DF-22	Drinking fountain, hallway 140, next to room 115	0.8	µg/L	
406-141-DF-23	Drinking fountain, hallway 141, next to room 111	2.1	µg/L	
406-143A-SK-24	Community room sink, room 143A	6.9	µg/L	
406-230-DF-25	Drinking fountain, hallway 230, next to room 227	0.5	µg/L	
406-230-DF-26	Drinking fountain, hallway 230, next to stair B, across from room 203	1.9	µg/L	
406-230-DF-27	Drinking fountain, hallway 230, next to room 216	0.7	µg/L	
406-230-DF-28	Drinking fountain, hallway 230, across from room 210, left bubbler	2.1	µg/L	
406--230-DF-29	Drinking fountain, hallway 230, across from room 210, right bubbler	1.7	µg/L	
406-231F-SK-30	LMC/IMC sink, room 231F	5.0	µg/L	
Phase II Sampled 9/27/2017				
406-22B-SK-31	Gym office sink, room 22B	7.7	µg/L	
406-21D-SK-32	Gym office sink, room 21D	2.0	µg/L	
406-23-SK-33	Classroom sink, room 23	5.1	µg/L	
406-25-SK-34	Classroom sink, room 25	0.3	µg/L	
406-26-SK-35	Classroom sink, room 26, northwest corner	3.7	µg/L	
406-26-SK-36	Classroom sink, room 26, northeast corner	0.9	µg/L	

406-27-SK-37	Classroom sink, room 27, northwest corner	0.7	µg/L	
406-27-SK-38	Classroom sink, room 27, northeast corner	2.6	µg/L	
406-105-SK-39	Science lab sink, room 105, east wall, far left sink	3.4	µg/L	
406-105-SK-40	Science lab sink, room 105, east wall, center left sink	5.3	µg/L	
406-105-SK-41	Science lab sink, room 105, east wall, center right sink	3.2	µg/L	
406-105-SK-42	Science lab sink, room 105, east wall, far right sink	5.5	µg/L	
406-105-SK-43	Science lab sink, room 105, south demonstration table, left faucet	>50.0	µg/L	Science Lab Sink Notice
406-105-SK-44	Science lab sink, room 105, south demonstration table, right faucet	>50.0	µg/L	Science Lab Sink Notice
406-105A-SK-45	Science prep sink, room 106A	16.7	µg/L	Science Lab Sink Notice
406-106-SK-46	Science lab sink, room 106, north demonstration table, left faucet	7.7	µg/L	
406-106-SK-47	Science lab sink, room 106, north demonstration table, right faucet	4.4	µg/L	
406-106-SK-48	Science lab sink, room 106, east wall, far left sink	8.7	µg/L	
406-106-SK-49	Science lab sink, room 106, east wall, center left sink	3.0	µg/L	
406-106-SK-50	Science lab sink, room 106, east wall, center right sink	7.0	µg/L	
406-106-SK-51	Science lab sink, room 106, east wall, far right sink	6.4	µg/L	
406-108-SK-52	Science lab sink, room 108, east wall, center left sink	3.1	µg/L	
406-108-SK-53	Science lab sink, room 108, east wall, center right sink	5.3	µg/L	
406-108-SK-54	Science lab sink, room 108, east wall, far right sink	6.5	µg/L	
406-123-SK-55	Classroom sink, room 123, east wall	2.3	µg/L	
406-123-SK-56	Classroom sink, room 123, south wall	3.2	µg/L	
406-124-SK-57	Classroom sink, room 124, south wall, west of door, left faucet	6.8	µg/L	
406-124-SK-58	Classroom sink, room 124, south wall, west of door, right faucet	2.4	µg/L	
406-124-SK-59	Classroom sink, room 124, south wall, east of door	1.5	µg/L	
406-125A-SK-60	Classroom sink, room 125A (125W), south wall	2.4	µg/L	
406-125A-SK-61	Classroom sink, room 125A (125W), north wall, left faucet	1.9	µg/L	
406-125A-SK-62	Classroom sink, room 125A (125W), north wall, right faucet	2.4	µg/L	
406-202B-SK-63	Storage room sink, room 202B	5.3	µg/L	
406-202-SK-64	Classroom sink, room 202	4.9	µg/L	
406-200-SK-65	Classroom sink, room 200	2.1	µg/L	
406-204-SK-66	Science lab sink, room 204, north demonstration table, left faucet	41.2	µg/L	Science Lab Sink Notice
406-204-SK-67	Science lab sink, room 204, north demonstration table, right faucet	19.8	µg/L	Science Lab Sink Notice
406-204-SK-68	Science lab sink, room 204, east wall, far left sink	10.5	µg/L	
406-204-SK-69	Science lab sink, room 204, east wall, center left sink	14.1	µg/L	
406-204-SK-70	Science lab sink, room 204, east wall, center right sink	13.8	µg/L	
406-204-SK-71	Science lab sink, room 204, east wall, far right sink	8.3	µg/L	
406-205-SK-72	Science lab sink, room 205, east wall, far left sink	7.4	µg/L	
406-205-SK-73	Science lab sink, room 205, east wall, center left sink	8.2	µg/L	
406-205-SK-74	Science lab sink, room 205, east wall, center right sink	5.3	µg/L	
406-205-SK-75	Science lab sink, room 205, east wall, far right sink	14.9	µg/L	
406-206B-SK-76	Science prep sink, room 206B	25.4	µg/L	Science Lab Sink Notice
406-206-SK-77	Science lab sink, room 206, north demonstration table, left faucet	13.9	µg/L	

406-206-SK-78	Science lab sink, room 206, north demonstration table, right faucet	46.4	µg/L	Science Lab Sink Notice
406-206-SK-79	Science lab sink, room 206, east wall, far left sink	9.3	µg/L	
406-206-SK-80	Science lab sink, room 206, east wall, center left sink	3.9	µg/L	
406-206-SK-81	Science lab sink, room 206, east wall, center right sink	3.0	µg/L	
406-206-SK-82	Science lab sink, room 206, east wall, far right sink	11.0	µg/L	