

## Noel Middle School (424)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/3/2016				
Sample ID	Sample Description	Lead Result	Units	Action
424-153-DF-01	Drinking fountain, hallway 153, next to room 153A	0.2	µg/L	
424-153-DF-02	Drinking fountain, hallway 153, next to room 153A	0.1	µg/L	
424-144-DF-03	Drinking fountain, gymnasium 144, south corner by hallway 153, left bubbler	0.2	µg/L	
424-144-DF-04	Drinking fountain, gymnasium 144, south corner by hallway 153, right bubbler	0.1	µg/L	
424-144-DF-05	Drinking fountain, gymnasium 144, west corner, next to room 144A, left bubbler	0.5	µg/L	
424-144-DF-06	Drinking fountain, gymnasium 144, west corner, next to room 144A, right bubbler	0.6	µg/L	
424-145-DF-07	Drinking fountain, girls locker room 145, left bubbler	0.6	µg/L	
424-145-DF-08	Drinking fountain, girls locker room 145, right bubbler	0.2	µg/L	
424-143-DF-09	Drinking fountain, boys locker room 143, left bubbler	1.2	µg/L	
424-143-DF-10	Drinking fountain, boys locker room 143, right bubbler	0.6	µg/L	
424-131-DF-11	Drinking fountain, hallway 131, across from room 134, left bubbler	0.9	µg/L	
424-131-DF-12	Drinking fountain, hallway 131, across from room 134, right bubbler	0.4	µg/L	
424-155-SK-13	Kitchen prep sink, room 155, center of kitchen	2.0	µg/L	
424-155-SK-14	Kitchen sink, room 155, south wall, next to room 155F	0.2	µg/L	
424-134-DF-15	Drinking fountain, room 134, left bubbler	0.2	µg/L	
424-134-DF-16	Drinking fountain, room 134, right bubbler	0.2	µg/L	
424-148-SK-17	Community room sink, north corner, on right	0.8	µg/L	
424-102-DF-18	Drinking fountain, hallway 102, across from room 107, left bubbler	<0.1*	µg/L	
424-102-DF-19	Drinking fountain, hallway 102, across from room 107, right bubbler	<0.1	µg/L	
424-102-DF-20	Drinking fountain, hallway 102, next to 102D, left bubbler	0.3	µg/L	
424-102-DF-21	Drinking fountain, hallway 102, next to 102D, right bubbler	0.1	µg/L	
424-200-DF-22	Drinking fountain, hallway 200, next to room 200F, left bubbler	0.8	µg/L	
424-200-DF-23	Drinking fountain, hallway 200, next to room 200F, right bubbler	0.2	µg/L	
424-200-DF-24	Drinking fountain, hallway 200, next to room 200G, right bubbler	0.4	µg/L	
Phase II Sampled on 9/28/2017				
424-149A-SK-25	Nurse sink, room 149A	0.8	µg/L	
424-149L-SK-26	Nurse sink, room 149L	0.5	µg/L	
424-149K-SK-27	Nurse sink, room 149K	0.7	µg/L	
424-149J-SK-28	Admin office sink, room 149J	1.2	µg/L	
424-148-SK-29	Admin office sink, room 148	0.6	µg/L	
424-134-SK-30	Classroom sink, room 134	0.3	µg/L	
424-136-SK-31	Classroom sink, room 136, northeast wall	1.4	µg/L	
424-136-SK-32	Classroom sink, room 136, southwest wall, left sink	0.5	µg/L	
424-136-SK-33	Classroom sink, room 136, southwest wall, right sink	1.8	µg/L	
424-138B-SK-34	Office sink, room 138B	0.4	µg/L	
424-137-SK-35	Classroom sink, room 137, northeast wall, left sink	0.4	µg/L	
424-137-SK-36	Classroom sink, room 137, northeast wall, right sink	0.3	µg/L	

<b>424-137-SK-37</b>	Classroom sink, room 137, northwest wall	0.6	µg/L
<b>424-143AA-SK-38</b>	Gymnasium office sink, room 143AA	0.5	µg/L
<b>424-145AA-SK-39</b>	Gymnasium office sink, room 145AA	2.4	µg/L
<b>424-124-SK-40</b>	Classroom sink, room 124, southeast wall	0.7	µg/L
<b>424-124-SK-41</b>	Classroom sink, room 124, southwest wall, left sink	0.4	µg/L
<b>424-124-SK-42</b>	Classroom sink, room 124, southwest wall, right sink	1.6	µg/L
<b>424-124-SK-43</b>	Classroom sink, room 124, northwest wall	1.5	µg/L
<b>424-124-SK-44</b>	Classroom sink, room 124, east wall	0.5	µg/L
<b>424-106-SK-45</b>	Classroom sink, room 106, southwest wall	2.1	µg/L
<b>424-106-SK-46</b>	Classroom sink, room 106, northwest wall	1.9	µg/L
<b>424-106-SK-47</b>	Classroom sink, room 106, northeast wall, left sink	1.0	µg/L
<b>424-106-SK-48</b>	Classroom sink, room 106, northeast wall, right sink	1.8	µg/L
<b>424-106-SK-49</b>	Classroom sink, room 106, southeast wall, left sink	3.4	µg/L
<b>424-106-SK-50</b>	Classroom sink, room 106, southeast wall, right sink	2.4	µg/L
<b>424-118-SK-51</b>	Classroom sink, room 118, south wall	0.5	µg/L
<b>424-118-SK-52</b>	Classroom sink, room 118, west wall	0.9	µg/L
<b>424-118-SK-53</b>	Classroom sink, room 118, north wall, left sink	0.4	µg/L
<b>424-118-SK-54</b>	Classroom sink, room 118, north wall, right sink	4.7	µg/L
<b>424-118-SK-55</b>	Classroom sink, room 118, east wall	1.0	µg/L
<b>424-118A-SK-56</b>	Prep room sink, room 118A	0.8	µg/L
<b>424-214-SK-57</b>	Science lab sink, room 214, south wall	0.5	µg/L
<b>424-214-SK-58</b>	Science lab sink, room 214, west wall	0.9	µg/L
<b>424-214-SK-59</b>	Science lab sink, room 214, north wall, left sink	1.4	µg/L
<b>424-214-SK-60</b>	Science lab sink, room 214, north wall, right sink	0.9	µg/L
<b>424-214-SK-61</b>	Science lab sink, room 214, east wall	1.1	µg/L
<b>424-214A-SK-62</b>	Prep room sink, room 214A	0.6	µg/L
<b>424-203-SK-63</b>	Classroom sink, room 203, southwest wall	1.6	µg/L
<b>424-203-SK-64</b>	Classroom sink, room 203, east wall	0.8	µg/L
<b>424-203-SK-65</b>	Classroom sink, room 203, northeast wall, right sink	2.0	µg/L
<b>424-203-SK-66</b>	Classroom sink, room 203, northeast wall, left sink	2.0	µg/L
<b>424-203-SK-67</b>	Classroom sink, room 203, northwest wall	1.1	µg/L
<b>424-203A-SK-68</b>	Prep room sink, room 203A	2.7	µg/L
<b>424-225A-SK-69</b>	Prep room sink, room 225A	1.5	µg/L
<b>424-225-SK-70</b>	Science lab sink, room 225, north wall	1.1	µg/L
<b>424-225-SK-71</b>	Science lab sink, room 225, east wall	0.7	µg/L
<b>424-225-SK-72</b>	Science lab sink, room 225, south wall, left sink	3.2	µg/L
<b>424-225-SK-73</b>	Science lab sink, room 225, south wall, right sink	0.5	µg/L
<b>424-225-SK-74</b>	Science lab sink, room 225, west wall	1.6	µg/L

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.