

## DSST Stapleton Middle and High School (430)

All results <15 ppb – No further action at this time.

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

Phase I Sampled on 11/3/2016				
Sample ID	Sample Description	Lead Result	Units	Action
430-173-SK-01	Kitchen sink, room 173, center, left faucet	1.2	µg/L	
430-173-SK-02	Kitchen sink, room 173, center, right faucet	0.7	µg/L	
430-173-SK-03	Kitchen sink, room 173, east wall, left faucet	2.5	µg/L	
430-173-SK-04	Kitchen sink, room 173, east wall, right faucet	2.5	µg/L	
430-168C-SK-05	Faculty lounge, room 168C	0.3	µg/L	
430-141-SK-06	Classroom sink, room 141	0.4	µg/L	
430-145-DF-07	Drinking fountain, hallway 145, across from elevator, left bubbler	<0.1*	µg/L	
430-145-DF-08	Drinking fountain, hallway 145, across from elevator, right bubbler	0.1	µg/L	
430-206-DF-09	Drinking fountain, hallway 206, next to room 211, left bubbler	0.1	µg/L	
430-206-DF-10	Drinking fountain, hallway 206, next to room 211, right bubbler	0.1	µg/L	
430-130-DF-11	Drinking fountain, hallway 130, across from room 131A, left bubbler	0.2	µg/L	
430-130-DF-12	Drinking fountain, hallway 130, across from room 131A, right bubbler	0.2	µg/L	
430-131A-SK-13	Lounge sink, room 131A	0.6	µg/L	
430-175-DF-14	Drinking fountain, cafeteria 175, southwest corner, left bubbler	0.5	µg/L	
430-175-DF-15	Drinking fountain, cafeteria 175, southwest corner, right bubbler	0.6	µg/L	
430-100-DF-16	Drinking fountain, lobby 100, across from room 103, left bubbler	0.1	µg/L	
430-100-DF-17	Drinking fountain, lobby 100, across from room 103, right bubbler	0.2	µg/L	
Phase II Sampled on 9/28/2017				
430-159-SK-18	Classroom sink, room 159	0.4	µg/L	
430-160-SK-19	Classroom sink, room 160	0.3	µg/L	
430-161-SK-20	Classroom sink, room 161	0.3	µg/L	
430-153-SK-21	Classroom sink, room 153	0.4	µg/L	
430-152-SK-22	Classroom sink, room 152	0.4	µg/L	
430-164-SK-23	Classroom sink, room 164	<0.1	µg/L	
430-165-SK-24	Science lab sink, room 165, north wall	0.3	µg/L	
430-166-SK-25	Science lab sink, room 166, north wall	0.3	µg/L	
430-166-SK-26	Science lab sink, room 166, demonstration sink	0.4	µg/L	
430-165A-SK-27	Science prep room sink, room 165A	0.6	µg/L	
430-151-SK-28	Classroom sink, room 151	0.3	µg/L	
430-144-SK-29	Classroom sink, room 144	0.6	µg/L	
430-210-SK-30	Classroom sink, room 210	0.4	µg/L	
430-204-SK-31	Classroom sink, room 204	0.3	µg/L	

<b>430-201-SK-32</b>	Classroom sink, room 201	0.2	µg/L
<b>430-131-SK-33</b>	Science lab sink, room 131, north wall	0.3	µg/L
<b>430-131-SK-34</b>	Science lab sink, room 131, east wall	0.4	µg/L
<b>430-131-SK-35</b>	Science lab sink, room 131, south wall	0.7	µg/L
<b>430-129-SK-36</b>	Classroom sink, room 129	0.2	µg/L
<b>430-127-SK-37</b>	Classroom sink, room 127	0.4	µg/L
<b>430-118-SK-38</b>	Art room sink, room 118, north sink	0.3	µg/L
<b>430-118-SK-39</b>	Art room sink, room 118, east sink	0.3	µg/L
<b>430-117-SK-40</b>	Classroom sink, room 117	0.3	µg/L

\*Result less than 0.1 ppb which is the lowest level that can be reported by the lab.