

## West High School (458)

**Sample ID Key:**

Building number – room number – fixture type (DF = drinking fountain, SK = sink) – consecutive sample number

### Phase I Sampled on 10/22/2016

Sample ID	Sample Description	Lead Result	Follow Up Result	Units	Action
458-115E-SK-01	Kitchen prep sink, room 115E southeast corner	1.3		µg/L	
458-115E-SK-02	Kitchen prep sink, room 115E, southwest corner	<1.0*		µg/L	
458-115E-SK-03	Kitchen kettle fill, center of room 115E	5.1		µg/L	
458-115-DF-04	Drinking fountain, cafeteria 115, southeast corner	5.3		µg/L	
458-115-DF-05	Drinking fountain, cafeteria 115, northeast corner	10.8		µg/L	
458-100-DF-06	Drinking fountain, hallway 100, across from room 102	1.1		µg/L	
458-101-SK-07	Classroom sink, room 101, northeast corner	9.3		µg/L	
458-101-SK-08	Classroom sink, room 101, southeast corner	9.1		µg/L	
458-101-SK-09	Classroom sink, west wall, next to hallway door	23.3	9.0	µg/L	Faucet replaced 11/2018
458-100-DF-10	Drinking fountain, hallway 100, next to room 100F, left bubbler	<1.0		µg/L	
458-100-DF-11	Drinking fountain, hallway 100, next to room 100F, right bubbler	<1.0		µg/L	
458-011-DF-12	Drinking fountain, hallway 011, next to room 011C	4.3		µg/L	
458-151-DF-13	Drinking fountain, gymnasium 151, north wall	1.7		µg/L	
458-151-DF-14	Drinking fountain, gymnasium 151, south wall	2.5		µg/L	
458-153-DF-15	Drinking fountain, fitness center room 153	4.7		µg/L	
458-156-DF-16	Drinking fountain, swim pool 156, north wall	2.4		µg/L	
458-225-DF-17	Drinking fountain, hallway 225, next to room 225A	<1.0		µg/L	
458-226-DF-18	Drinking fountain, LMC/IMC 226, next to front desk, left bubbler	1.2		µg/L	
458-226-DF-19	Drinking fountain, LMC/IMC 226, next to front desk, right bubbler	<1.0		µg/L	
458-226D-SK-20	Sink, staff workroom 226D, north wall	<1.0		µg/L	
458-226D-DF-21	Drinking fountain, staff workroom 226D, north wall	<1.0		µg/L	
458-200-DF-22	Drinking fountain, hallway 200, across from room 246	<1.0		µg/L	
458-200-DF-23	Bottle fill, hallway 200, across from room 246	<1.0		µg/L	
458-236-DF-24	Drinking fountain, room 236	4.7		µg/L	
458-237-DF-25	Drinking fountain, room 237	8.0		µg/L	
458-200-DF-26	Drinking fountain, hallway 200, across from room 201J, left bubbler	<1.0		µg/L	
458-200-DF-27	Drinking fountain, hallway 200, across from room 201J, right bubbler	<1.0		µg/L	
458-212AB-SK-28	Faculty lounge sink, room 212AB	5.1		µg/L	
458-300-DF-29	Drinking fountain, hallway 300, across from room 303, left bubbler	<1.0		µg/L	
458-300-DF-30	Drinking fountain, hallway 300, across from room 303, right bubbler	<1.0		µg/L	
458-304A-SK-31	Lounge sink, room 304A	3.0		µg/L	

458-304A-DF-32	Plumbed water cooler, lounge, room 304A	<1.0		µg/L	
458-300-DF-33	Drinking fountain, hallway 300, across from room 350, left bubbler	<1.0		µg/L	
458-300-DF-34	Drinking fountain, hallway 300, across from room 350, right bubbler	<1.0		µg/L	
458A-170-DF-35	Drinking fountain, Butler building lobby, room 170	2.0		µg/L	
458A-171-DF-36	Drinking fountain, Butler building room 171, left bubbler	2.0		µg/L	
458A-171-DF-37	Drinking fountain, Butler building room 171, right bubbler	1.0		µg/L	
<b>Phase II Sampled on 10/21/2017</b>					
458-128-SK-38	Classroom sink, room 128	16.3	14.0	µg/L	Faucet replaced 4/2018
458-128A-SK-39	Storage room sink, room 128A	0.5		µg/L	
458-131-SK-40	Science lab sink, room 131, north wall, right sink	24.1		µg/L	Lab Sink – No Drinking Notice
458-131-SK-41	Science lab sink, room 131, north wall, left sink	8.6		µg/L	
458-131-SK-42	Science lab sink, room 131, west wall	11.7		µg/L	
458-131-SK-43	Science lab sink, room 131, south wall, right sink	3.3		µg/L	
458-131-SK-44	Science lab sink, room 131, south wall, left sink	6.8		µg/L	
458-129-SK-45	Science lab sink, room 129, north wall	5.2		µg/L	
458-129-SK-46	Science lab sink, room 129, south wall, left sink	>50.0		µg/L	Lab Sink – No Drinking Notice
458-129-SK-47	Science lab sink, room 129, south wall, right sink	22.8		µg/L	Lab Sink – No Drinking Notice
458-130-SK-48	Science lab sink, room 130	19.7		µg/L	Lab Sink – No Drinking Notice
458-125-SK-49	Science lab sink, room 125, third row, right island, right sink	0.1		µg/L	
458-125-SK-50	Science lab sink, room 125, third row, right island, left sink	0.2		µg/L	
458-125-SK-51	Science lab sink, room 125, third row, left island, right sink	0.3		µg/L	
458-125-SK-52	Science lab sink, room 125, third row, left island, left sink	0.2		µg/L	
458-125-SK-53	Science lab sink, room 125, second row, right island, right sink	0.2		µg/L	
458-125-SK-54	Science lab sink, room 125, second row, right island, left sink	0.5		µg/L	
458-125-SK-55	Science lab sink, room 125, second row, left island, right sink	0.4		µg/L	
458-125-SK-56	Science lab sink, room 125, second row, left island, left sink	0.2		µg/L	
458-125-SK-57	Science lab sink, room 125, first row, demonstration sink	0.1		µg/L	
458-124-SK-58	Science prep sink, room 124	12.5		µg/L	
458-123-SK-59	Science lab sink, room 123, third row, right island, right sink	0.4		µg/L	
458-123-SK-60	Science lab sink, room 123, third row, right island, left sink	0.2		µg/L	
458-123-SK-61	Science lab sink, room 123, third row, left island, right sink	0.3		µg/L	
458-123-SK-62	Science lab sink, room 123, third row, left island, left sink	0.2		µg/L	
458-123-SK-63	Science lab sink, room 123, second row, right island, right sink	0.7		µg/L	
458-123-SK-64	Science lab sink, room 123, second row, right island, left sink	0.2		µg/L	
458-123-SK-65	Science lab sink, room 123, second row, left island, right sink	0.2		µg/L	
458-123-SK-66	Science lab sink, room 123, second row, left island, left sink	0.5		µg/L	
458-123-SK-67	Science lab sink, room 123, first row, demonstration sink	0.3		µg/L	
458-122-SK-68	Science lab sink, room 122, north wall, right sink	8.9		µg/L	
458-122-SK-69	Science lab sink, room 122, north wall, left sink	>50.0		µg/L	Lab Sink – No Drinking Notice
458-122-SK-70	Science lab sink, room 122, west wall, center sink	6.3		µg/L	

<b>458-122-SK-71</b>	Science lab sink, room 122, south wall, right sink	11.0	µg/L	
<b>458-122-SK-72</b>	Science lab sink, room 122, south wall, left sink	7.7	µg/L	
<b>458-122-SK-73</b>	Science lab sink, room 122, east island, demonstration sink	>50.0	µg/L	Lab Sink – No Drinking Notice
<b>458-132-SK-74</b>	Science lab sink, room 132, east wall, right sink	0.2	µg/L	
<b>458-132-SK-75</b>	Science lab sink, room 132, east wall, left sink	0.2	µg/L	
<b>458-132-SK-76</b>	Science lab sink, room 132, west wall, right sink	0.5	µg/L	
<b>458-132-SK-77</b>	Science lab sink, room 132, west wall, left sink	0.3	µg/L	
<b>458-135-SK-78</b>	Classroom sink, room 135	11.4	µg/L	
<b>458-134-SK-79</b>	Science lab sink, room 134, east wall	0.8	µg/L	
<b>458-134-SK-80</b>	Science lab sink, room 134, north wall	1.1	µg/L	
<b>458-134-SK-81</b>	Science lab sink, room 134, west wall, right sink	0.3	µg/L	
<b>458-134-SK-82</b>	Science lab sink, room 134, west wall, left sink	0.3	µg/L	
<b>458-134A-SK-83</b>	Science prep sink, room 134A	12.1	µg/L	
<b>458-102-SK-84</b>	Classroom sink, room 102, east wall, left sink	8.7	µg/L	
<b>458-102-SK-85</b>	Classroom sink, room 102, east wall, right sink	9.3	µg/L	
<b>458-112-SK-86</b>	Science lab sink, room 112, demonstration sink	8.0	µg/L	
<b>458-113-SK-87</b>	Science lab sink, room 113, demonstration sink	5.4	µg/L	
<b>458-210-SK-88</b>	Classroom sink, room 210	5.5	µg/L	
<b>458-246D-SK-89</b>	Office sink, room 246D	2.9	µg/L	
<b>458-246B-SK-90</b>	Office sink, room 246B	13.7	µg/L	
<b>458-246C-SK-91</b>	Office sink, room 246C	4.4	µg/L	
<b>458-235-SK-92</b>	Classroom sink, room 235, south wall, right sink	1.2	µg/L	
<b>458-235-SK-93</b>	Classroom sink, room 235, south wall, left sink	3.3	µg/L	
<b>458-235-SK-94</b>	Classroom sink, room 235, north wall, right sink	15.1	9.0 µg/L	Faucet replaced 4/2018
<b>458-235-SK-95</b>	Classroom sink, room 235, north wall, left sink	2.0	µg/L	
<b>458-234-SK-96</b>	Shop sink, room 234, west wall	0.6	µg/L	
<b>458-234-SK-97</b>	Shop sink, room 234, south wall, right sink	0.4	µg/L	
<b>458-234-SK-98</b>	Shop sink, room 234, south wall, left sink	1.2	µg/L	
<b>458-233-SK-99</b>	Classroom sink, room 233, east island	0.8	µg/L	
<b>458-233B-SK-100</b>	Classroom sink, room 233B, north wall, right sink	4.9	µg/L	
<b>458-233B-SK-101</b>	Classroom sink, room 233B, north wall, left sink	1.6	µg/L	
<b>458-334-SK-102</b>	Classroom sink, room 334	1.6	µg/L	
<b>458-336-SK-103</b>	Classroom sink, room 336	1.0	µg/L	

\*Result less than 1.0 ppb which is the lowest level that can be reported by the lab.